

KANSAS CITY INTL, MO, USA

WMO: 724460

Lat: 39.297N

Lon: 94.731W

Elev: 1005

StdP: 14.17

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 03947

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 2.4	(c) 7.2	(d) -6.4	(e) 4.0	(f) 4.5	(g) -2.2	(h) 5.1	(i) 9.3	(j) 26.8	(k) 42.3	(l) 25.0	(m) 39.3	(n) 9.0	(o) 310	(p) 0.562

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 18.5	(c) 95.6	(d) 76.7	(e) 92.4	(f) 76.3	(g) 89.6	(h) 75.5	(i) 80.0	(j) 90.7	(k) 78.4	(l) 89.0	(m) 77.1	(n) 87.2	(o) 11.4	(p) 190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
76.9	145.4	87.0	75.3	137.8	85.7	73.9	131.2	83.7	44.2	90.6	42.7	89.3	41.1	87.0	84.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 25.2	(b) 22.5	(c) 19.8	(e) -4.5	(f) 99.8	(g) 4.4	(h) 3.4	(i) -7.7	(j) 102.3	(k) -10.3	(l) 104.3	(m) -12.7	(n) 106.2	(o) -15.9	(p) 108.7		
(4) 25.2	(5) 22.5	(6) 19.8	(7) -4.5	(8) 99.8	(9) 4.4	(10) 3.4	(11) -7.7	(12) 102.3	(13) -10.3	(14) 104.3	(15) -12.7	(16) 106.2	(17) -15.9	(18) 108.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	55.2	29.3	33.7	44.6	55.2	65.0	74.3	78.5	77.1	69.0	56.9	44.4	33.2	
	DBStd	19.54	12.12	12.14	11.76	9.70	8.04	6.00	5.64	5.67	7.81	9.28	10.26	11.02	
	HDD50	2207	646	469	243	56	3	0	0	0	1	38	224	527	
	HDD65	4977	1108	876	635	316	102	6	0	1	48	281	619	985	
	CDD50	4112	3	13	77	212	468	730	883	840	571	252	56	7	
	CDD65	1409	0	0	4	22	103	286	419	376	167	31	1	0	
	CDH74	13625	0	1	32	193	863	2715	4465	3694	1421	235	6	0	
	CDH80	5414	0	0	2	34	225	1012	2001	1605	482	53	0	0	
Wind	WSAvg	10.2	10.6	10.8	11.7	12.1	10.2	9.8	8.5	8.3	9.0	10.1	10.7	10.3	
Precipitation	PrecAvg	37.8	1.1	1.3	2.5	3.4	4.9	4.6	4.4	3.8	4.6	3.2	2.0	1.7	
	PrecMax	60.2	3.0	3.3	9.1	7.0	12.8	10.6	15.5	9.6	11.6	8.6	5.6	5.4	
	PrecMin	23.7	0.0	0.2	0.3	0.8	1.1	1.8	0.1	0.3	0.4	0.2	0.0	0.0	
	PrecStd	9.8	0.7	0.7	1.6	1.8	2.6	2.2	3.6	2.2	3.5	2.3	1.5	1.2	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	63.3	70.3	78.2	84.3	89.3	94.7	100.5	100.5	93.9	85.4	74.1	65.0	
		MCWB	51.5	54.3	61.9	65.7	72.7	76.3	75.5	76.3	74.0	69.6	61.1	57.3	
	2%	DB	57.2	63.2	72.9	79.2	85.4	91.2	96.2	95.3	88.9	80.2	69.2	59.1	
		MCWB	48.2	52.4	59.2	63.1	70.7	75.7	77.4	76.2	73.5	66.3	58.6	52.3	
	5%	DB	51.8	57.5	68.2	75.4	82.3	88.8	92.9	91.8	85.5	75.7	64.6	53.9	
		MCWB	44.1	48.5	57.0	61.7	68.9	74.8	77.5	76.0	72.5	64.6	55.0	47.2	
	10%	DB	46.2	52.1	63.4	71.6	79.0	86.0	89.6	88.4	82.0	71.8	60.3	49.1	
		MCWB	40.1	44.4	53.6	59.8	67.2	73.4	76.5	75.0	70.2	62.4	53.1	42.9	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	56.0	59.1	65.2	69.3	75.7	79.9	82.3	81.2	77.4	72.6	64.3	59.8
			MCDB	60.2	65.0	74.1	79.5	85.8	90.1	91.9	92.2	88.6	82.0	70.4	63.7
2%		WB	48.9	53.6	61.9	66.7	73.2	78.0	80.5	79.3	75.5	69.6	60.2	53.7	
		MCDB	55.7	60.0	69.8	75.5	82.5	88.1	91.0	90.4	86.0	76.8	66.3	57.5	
5%		WB	44.3	49.1	58.8	64.1	71.0	76.3	79.1	77.6	73.9	66.7	57.5	47.8	
		MCDB	51.4	57.7	66.5	72.7	79.5	86.0	89.7	88.8	83.0	73.3	62.5	52.9	
10%		WB	40.2	44.2	54.2	61.2	68.8	74.7	77.7	76.1	72.0	63.7	53.7	43.3	
		MCDB	46.2	51.8	62.7	70.0	77.1	84.0	87.8	86.1	79.9	69.7	59.9	48.8	
Mean Daily Temperature Range		5% DB	MDBR	17.4	18.2	20.0	19.9	18.9	18.4	18.5	19.0	19.9	19.6	18.4	16.6
			MCDBR	25.2	25.6	26.1	24.8	22.0	20.5	21.7	22.8	21.7	23.0	23.5	23.1
	MCWBR		17.6	16.9	15.5	14.4	11.4	9.7	8.8	9.2	10.0	12.4	15.0	16.7	
	5% WB	MCDBR	23.5	24.0	21.8	21.6	19.2	18.9	19.0	20.3	19.2	19.1	20.3	20.8	
		MCWBR	17.3	17.5	14.2	14.3	11.3	10.0	9.3	9.5	10.1	12.4	15.2	16.9	
Clear-Sky Solar Irradiance	taub	0.291	0.303	0.334	0.386	0.423	0.429	0.434	0.433	0.384	0.341	0.301	0.287		
	taud	2.465	2.439	2.414	2.287	2.242	2.261	2.260	2.273	2.360	2.472	2.528	2.502		
	Ebn at Noon	281	293	293	282	272	270	268	265	272	275	276	275		
	Edh at Noon	25	30	34	41	44	43	43	41	35	29	23	23		
All-Sky Solar Radiation	RadAvg	688	944	1225	1563	1809	2042	2036	1802	1515	1073	756	597		
	RadStd	68	96	106	106	101	158	153	132	89	102	121	70	57	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (27 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page