

KANSAS CITY INTL, MO, USA

WMO: 724460

Lat: 39.297N

Lon: 94.731W

Elev: 306

StdP: 97.70

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 03947

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-16.5	-13.8	-21.4	0.6	-15.3	-19.0	0.7	-12.6	12.0	5.7	11.2	4.0	4.0	310	0.562

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.3	35.3	24.8	33.6	24.6	32.0	24.2	26.6	32.6	25.8	31.7	25.0	30.7	5.1	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.9	20.8	30.6	24.1	19.7	29.8	23.3	18.7	28.7	85.0	32.6	81.5	31.8	77.8	30.5	29.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.3	10.1	8.9	-20.3	37.7	2.4	1.9	-22.0	39.0	-23.5	40.2	-24.8	41.2	-26.6	42.6
			-20.7	27.7	2.3	0.9	-22.4	28.4	-23.8	28.9	-25.1	29.4	-26.8	30.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	12.9	-1.5	1.0	7.0	12.9	18.3	23.5	25.8	25.1	20.6	13.8	6.9	0.7	(6)
(7)		DBStd	10.86	6.73	6.74	6.53	5.39	4.47	3.33	3.13	3.15	4.34	5.15	5.70	6.12	(7)
(8)		HDD10.0	1226	359	261	135	31	2	0	0	1	21	124	293		(8)
(9)		HDD18.3	2765	616	487	353	176	57	3	0	1	27	156	344	547	(9)
(10)		CDD10.0	2284	2	7	43	118	260	406	491	467	317	140	31	4	(10)
(11)		CDD18.3	783	0	0	2	12	57	159	233	209	93	17	1	0	(11)
(12)		CDH23.3	7569	0	1	18	107	479	1508	2481	2052	789	131	3	0	(12)
(13)		CDH26.7	3008	0	0	1	19	125	562	1112	892	268	29	0	0	(13)
(14)	Wind	WSAvg	4.5	4.7	4.8	5.2	5.4	4.6	4.4	3.8	3.7	4.0	4.5	4.8	4.6	(14)
(15)	Precipitation	PrecAvg	961	29	32	64	87	124	117	113	97	117	81	51	42	(15)
(16)		PrecMax	1530	75	83	231	177	324	268	393	243	294	219	141	138	(16)
(17)		PrecMin	601	0	5	8	20	27	46	3	8	10	5	0	1	(17)
(18)		PrecStd	249	19	19	41	46	65	56	91	57	89	59	37	30	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.4	21.3	25.7	29.1	31.8	34.8	38.0	38.0	34.4	29.7	23.4	18.3	(19)
(20)		MCWB	10.8	12.4	16.6	18.7	22.6	24.6	24.2	24.6	23.3	20.9	16.2	14.1	(20)	
(21)		2%	DB	14.0	17.3	22.7	26.2	29.6	32.9	35.7	35.2	31.6	26.8	20.7	15.0	(21)
(22)		MCWB	9.0	11.3	15.1	17.3	21.5	24.3	25.2	24.5	23.1	19.0	14.8	11.3	(22)	
(23)		5%	DB	11.0	14.2	20.1	24.1	28.0	31.5	33.8	33.2	29.7	24.3	18.1	12.1	(23)
(24)		MCWB	6.7	9.2	13.9	16.5	20.5	23.8	25.3	24.5	22.5	18.1	12.8	8.5	(24)	
(25)		10%	DB	7.9	11.2	17.5	22.0	26.1	30.0	32.0	31.3	27.8	22.1	15.7	9.5	(25)
(26)		MCWB	4.5	6.9	12.0	15.5	19.6	23.0	24.7	23.9	21.2	16.9	11.7	6.0	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.4	15.1	18.5	20.7	24.3	26.6	28.0	27.3	25.2	22.5	18.0	15.4	(27)
(28)		MCDWB	15.7	18.3	23.4	26.4	29.9	32.3	33.3	33.4	31.5	27.8	21.4	17.6	(28)	
(29)		2%	WB	9.4	12.0	16.6	19.3	22.9	25.6	26.9	26.3	24.2	20.9	15.7	12.1	(29)
(30)		MCDWB	13.2	15.5	21.0	24.2	28.0	31.2	32.8	32.4	30.0	24.9	19.1	14.2	(30)	
(31)		5%	WB	6.8	9.5	14.9	17.8	21.7	24.6	26.2	25.3	23.3	19.3	14.1	8.8	(31)
(32)		MCDWB	10.8	14.3	19.2	22.6	26.4	30.0	32.1	31.6	28.4	22.9	17.0	11.6	(32)	
(33)		10%	WB	4.6	6.8	12.3	16.2	20.5	23.7	25.4	24.5	22.2	17.6	12.0	6.3	(33)
(34)		MCDWB	7.9	11.0	17.1	21.1	25.1	28.9	31.0	30.0	26.6	21.0	15.5	9.3	(34)	
(35)	Mean Daily Temperature Range		MDBR	9.7	10.1	11.1	11.1	10.5	10.2	10.3	10.5	11.0	10.9	10.2	9.2	(35)
(36)		5% DB	MCDBR	14.0	14.2	14.5	13.8	12.2	11.4	12.1	12.7	12.0	12.8	13.0	12.8	(36)
(37)			MCWBR	9.8	9.4	8.6	8.0	6.3	5.4	4.9	5.1	5.6	6.9	8.4	9.3	(37)
(38)			MCDBR	13.1	13.3	12.1	12.0	10.7	10.5	10.6	11.3	10.7	10.6	11.3	11.6	(38)
(39)		5% WB	MCWBR	9.6	9.7	7.9	7.9	6.3	5.6	5.2	5.3	5.6	6.9	8.4	9.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.291	0.303	0.334	0.386	0.423	0.429	0.434	0.433	0.384	0.341	0.301	0.287	(40)	
(41)		taud	2.465	2.439	2.414	2.287	2.242	2.261	2.260	2.273	2.360	2.472	2.528	2.502	(41)	
(42)		Ebn at Noon	887	923	923	889	859	852	844	834	858	867	870	867	(42)	
(43)		Edh at Noon	79	93	106	129	138	135	134	129	111	90	74	71	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.17	2.98	3.86	4.93	5.70	6.44	6.42	5.68	4.78	3.38	2.38	1.88	(44)	
(45)		RadStd	0.21	0.30	0.34	0.32	0.50	0.48	0.41	0.28	0.32	0.38	0.22	0.18	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (27 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page