

ROSECRANS, MO, USA

WMO: 724490

Lat: 39.774N

Lon: 94.923W

Elev: 249

StdP: 98.37

Time Zone: -6.00 (NAC)

Period: 96-19

WBAN: 13993

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-17.5	-14.6	-22.1	0.5	-16.9	-19.3	0.7	-13.5	12.7	-2.1	11.6	-1.2	3.1	320	0.532

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.8	34.7	25.1	33.3	24.7	32.2	24.2	26.7	32.6	25.8	31.6	25.1	30.6	4.9	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.0	20.7	30.6	24.0	19.5	29.7	23.1	18.4	28.6	85.0	32.5	81.2	32.0	77.6	30.4	29.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.5	10.1	8.8	DB	-21.6	37.0	3.2	1.6	-24.0	38.1	-25.8	39.1	-27.6	40.0	-30.0	41.2	(4)
(5)			WB	-22.0	28.2	3.0	0.6	-24.2	28.6	-26.0	28.9	-27.7	29.2	-29.9	29.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	12.3	-2.2	0.0	6.4	12.5	18.5	23.6	25.4	24.2	20.2	13.2	6.0	-0.5	(6)	
	DBStd	11.06	6.48	6.60	6.35	5.50	4.67	3.41	3.09	3.20	4.29	5.33	5.62	6.16	(7)	
	HDD10.0	1350	380	286	148	36	2	0	0	0	1	28	143	328	(8)	
	HDD18.3	2933	638	514	373	187	58	3	1	1	29	175	370	584	(9)	
	CDD10.0	2199	1	4	36	111	264	407	479	440	306	126	23	3	(10)	
	CDD18.3	740	0	0	2	12	62	160	221	183	85	15	1	0	(11)	
	CDH23.3	7585	0	0	23	134	601	1623	2382	1807	849	160	5	0	(12)	
	CDH26.7	3038	0	0	2	32	195	645	1059	762	301	41	0	0	(13)	
(14) Wind	WSAvg	3.9	4.1	4.2	4.7	4.9	4.2	3.8	3.0	2.8	3.1	3.6	4.0	3.9	(14)	
(15) Precipitation	PrecAvg	895	24	25	58	77	121	119	94	110	114	74	44	35	(15)	
	PrecMax	1412	89	98	185	169	293	301	245	264	311	209	108	121	(16)	
	PrecMin	527	0	1	7	22	34	25	1	10	20	0	0	0	(17)	
	PrecStd	228	21	21	43	42	60	67	72	68	88	53	35	26	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.8	21.2	26.2	30.3	33.7	35.4	37.1	37.1	34.1	30.8	23.9	17.9	(19)	
		MCWB	9.6	12.3	16.6	19.6	22.2	25.1	25.5	24.7	23.3	21.0	15.6	14.0	(20)	
	2%	DB	13.3	16.8	22.8	27.1	31.0	33.5	34.9	34.0	32.2	27.4	21.0	14.1	(21)	
		MCWB	8.2	10.9	14.7	17.5	20.9	24.2	25.7	25.1	23.4	18.5	14.8	10.1	(22)	
	5%	DB	10.0	13.0	20.0	24.2	28.7	32.1	33.4	32.6	30.1	24.8	17.8	11.3	(23)	
		MCWB	6.1	8.1	13.6	16.2	20.1	23.8	25.5	24.7	22.5	17.6	12.2	7.8	(24)	
	10%	DB	7.0	9.9	17.3	22.2	27.0	30.5	32.1	31.0	27.9	22.4	15.4	8.3	(25)	
		MCWB	3.8	6.1	11.9	15.4	19.5	22.9	25.0	24.0	20.8	16.7	10.8	5.4	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.4	14.8	18.6	20.7	24.1	26.8	28.0	27.4	25.4	22.6	17.3	15.0	(27)	
		MCDB	15.2	18.0	24.0	27.1	31.1	32.6	33.5	33.0	31.8	27.6	21.6	17.5	(28)	
	2%	WB	8.4	11.4	16.7	19.0	22.7	25.6	27.0	26.3	24.2	20.8	15.2	11.3	(29)	
		MCDB	12.9	15.0	20.8	24.5	28.9	31.9	32.8	32.4	30.1	25.0	19.3	13.1	(30)	
	5%	WB	6.2	8.5	14.9	17.6	21.6	24.6	26.3	25.4	23.4	19.1	13.5	7.9	(31)	
		MCDB	10.1	13.8	19.2	23.0	27.1	30.6	32.2	31.2	28.6	23.3	17.2	10.6	(32)	
	10%	WB	3.8	6.0	11.9	15.8	20.3	23.7	25.4	24.5	22.4	17.2	11.3	5.6	(33)	
		MCDB	6.7	9.7	17.1	21.1	25.3	29.1	30.7	29.8	26.8	21.2	14.8	8.4	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	10.7	10.9	12.0	12.4	11.6	10.9	10.8	11.4	13.0	13.0	11.9	10.3	(35)	
		MCDBR	15.9	16.4	16.4	15.7	14.0	12.1	12.0	13.2	13.9	15.7	16.0	14.5	(36)	
	5% WB	MCWBR	11.2	10.9	9.6	8.6	6.3	5.3	5.2	6.0	6.4	8.2	10.0	10.8	(37)	
		MCWBR	15.0	15.0	13.4	13.4	11.7	10.9	10.7	11.5	12.0	12.3	13.7	13.2	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.292	0.306	0.336	0.386	0.419	0.432	0.434	0.433	0.386	0.340	0.302	0.288	(40)	
		taud	2.454	2.424	2.404	2.284	2.255	2.254	2.248	2.271	2.353	2.469	2.516	2.487	(41)	
	Edn at Noon	Edn at Noon	881	916	920	888	862	848	842	833	854	865	864	859	(42)	
		Edh at Noon	79	94	107	129	136	136	136	129	112	89	74	71	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	2.13	2.98	3.87	4.92	5.73	6.43	6.42	5.67	4.75	3.35	2.35	1.84	(44)	
	RadStd	RadStd	0.20	0.26	0.34	0.31	0.49	0.48	0.44	0.27	0.32	0.38	0.20	0.18	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (39 neighbors)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page