

TOPEKA FORBES, KS, USA

WMO: 724565

Lat: 38.950N

Lon: 95.664W

Elev: 325

StdP: 97.48

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 13920

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-15.8	-12.9	-20.6	0.6	-14.5	-18.2	0.8	-12.0	12.8	3.6	11.8	1.4	4.1	320	0.547

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.6	37.2	24.6	35.0	24.5	33.3	24.0	26.3	33.5	25.6	32.6	24.9	31.6	5.4	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
24.2	19.8	30.1	23.5	19.1	29.5	22.8	18.3	28.7	83.4	33.6	80.5	32.7	77.4	31.6	29.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
11.7	10.4	9.0		DB	-20.2	39.4	2.8	2.0	-22.3	40.8	-23.9	42.0	-25.5	43.2	-27.6	44.6
				WB	-20.6	27.7	2.7	0.9	-22.6	28.4	-24.2	28.9	-25.7	29.5	-27.7	30.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	13.2	-1.0	1.0	7.5	13.1	18.7	23.9	26.4	25.5	21.0	13.8	7.1	0.8	(6)
(7)		DBStd	10.90	6.26	6.57	6.18	5.24	4.50	3.59	3.32	3.36	4.42	5.30	5.64	6.05	(7)
(8)		HDD10.0	1186	343	260	122	27	2	0	0	0	0	23	119	290	(8)
(9)		HDD18.3	2712	601	486	338	168	53	4	0	1	22	158	337	544	(9)
(10)		CDD10.0	2359	1	8	44	122	270	416	510	480	331	141	32	4	(10)
(11)		CDD18.3	844	0	0	3	13	63	170	252	222	103	18	1	0	(11)
(12)		CDH23.3	9015	0	2	31	146	602	1769	2904	2373	1010	170	8	0	(12)
(13)		CDH26.7	4058	0	0	4	29	186	752	1473	1164	405	44	1	0	(13)
(14)	Wind	WSAvg	4.2	4.5	4.6	4.9	5.2	4.3	4.1	3.4	3.2	3.5	4.1	4.4	4.4	(14)
(15)	Precipitation	PrecAvg	996	24	40	57	102	134	138	110	114	97	78	57	36	(15)
(16)		PrecMax	1336	69	103	124	224	297	217	353	207	210	185	218	95	(16)
(17)		PrecMin	701	1	0	8	26	41	49	31	28	20	5	3	3	(17)
(18)		PrecStd	180	17	26	32	53	67	47	76	53	54	44	50	24	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.9	22.3	26.6	29.5	32.7	36.4	39.3	39.1	36.3	30.7	24.5	18.9	(19)
(20)		MCWB	10.1	12.8	17.1	18.9	22.4	24.9	23.9	23.9	23.2	20.9	16.2	14.2		(20)
(21)		2%	DB	14.1	17.8	23.4	27.2	30.7	34.2	37.4	37.0	32.9	27.5	21.7	15.6	(21)
(22)		MCWB	8.0	11.5	14.8	18.1	21.4	24.3	25.1	24.3	23.1	18.7	14.5	10.5		(22)
(23)		5%	DB	11.1	14.6	20.9	24.8	28.8	32.7	35.5	34.5	31.2	24.9	18.8	12.5	(23)
(24)		MCWB	6.4	9.4	13.9	16.5	20.6	23.9	24.9	24.1	22.6	17.7	13.1	8.6		(24)
(25)		10%	DB	8.1	11.6	17.9	22.5	27.0	31.0	33.5	32.6	28.8	22.6	16.3	10.0	(25)
(26)		MCWB	4.5	7.1	12.3	15.8	20.1	23.2	24.5	23.7	21.3	16.7	11.7	6.4		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.9	15.1	18.8	20.7	24.4	26.8	27.4	26.8	25.4	22.9	17.7	15.6	(27)
(28)		MADB	14.8	18.6	24.7	27.3	30.4	33.1	34.8	33.7	32.5	28.0	21.8	18.1		(28)
(29)		2%	WB	8.9	12.2	16.9	19.4	23.1	25.6	26.5	25.9	24.2	21.1	15.7	12.1	(29)
(30)		MADB	13.0	16.3	20.8	24.7	28.6	32.1	34.1	33.1	30.4	25.2	19.7	14.2		(30)
(31)		5%	WB	6.8	9.8	15.1	18.0	21.9	24.7	25.8	25.2	23.5	19.3	14.1	8.9	(31)
(32)		MADB	10.8	14.7	19.3	23.0	26.9	31.1	33.0	32.2	29.4	23.1	17.9	12.0		(32)
(33)		10%	WB	4.6	6.9	12.6	16.6	20.8	23.9	25.2	24.4	22.4	17.5	12.1	6.6	(33)
(34)		MADB	8.4	11.2	17.6	21.7	25.5	29.6	32.0	30.7	27.8	21.0	15.7	9.9		(34)
(35)	Mean Daily Temperature Range	MDBR	11.2	11.6	12.5	12.5	11.8	11.3	11.6	12.0	12.5	12.4	12.1	10.9	(35)	
(36)		5% DB	MADB	16.2	16.8	16.7	15.7	13.9	12.6	13.7	14.3	13.8	14.8	15.8	14.9	(36)
(37)		MCWBR	10.9	11.1	9.6	8.8	6.6	5.3	4.7	4.9	5.7	7.7	9.5	10.6	(37)	
(38)		5% WB	MADB	15.2	15.3	12.9	13.0	11.8	11.6	12.0	12.4	12.0	11.5	13.0	13.5	(38)
(39)		MCWBR	10.7	10.9	8.2	8.4	6.6	5.6	5.0	5.2	5.7	7.3	9.0	10.5	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.287	0.301	0.330	0.381	0.414	0.428	0.430	0.431	0.383	0.339	0.305	0.283	(40)	
(41)		taud	2.485	2.457	2.428	2.308	2.275	2.264	2.286	2.287	2.371	2.481	2.513	2.513	(41)	
(42)		Ebn at Noon	897	929	930	896	868	853	847	838	861	872	866	876	(42)	
(43)		Edh at Noon	78	92	105	126	133	135	131	128	110	89	76	71	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.28	3.06	3.97	5.05	5.77	6.55	6.49	5.79	4.81	3.49	2.49	1.96	(44)	
(45)		RadStd	0.22	0.34	0.32	0.33	0.50	0.44	0.43	0.30	0.33	0.39	0.22	0.18	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (25 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page