

ELKHART-MORTON COUNTY AP, KS, USA

WMO: 724604

Lat: 37.000N

Lon: 101.883W

Elev: 1104

StdP: 88.75

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 93076

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-13.8	-11.0	-19.1	0.8	-11.3	-17.3	0.9	-7.3	13.1	10.3	11.7	6.1	4.1	350	0.609

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.9	37.6	20.0	36.4	19.9	35.0	19.7	22.6	32.2	21.9	31.7	21.2	31.0	5.3	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.1	16.9	25.5	19.1	15.9	25.2	18.3	15.1	24.9	72.6	32.2	69.8	31.6	67.1	31.2	25.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
11.9	10.6	9.2	-17.9	40.0	2.0	1.1	-19.3	40.8	-20.5	41.4	-21.6	42.0	-23.0	42.8	
			DB												
			WB	-18.2	23.4	2.3	1.0	-19.8	24.1	-21.1	24.6	-22.4	25.2	-24.1	25.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	14.0	2.4	3.6	8.6	12.7	18.2	24.2	26.3	25.2	21.3	14.2	8.0	2.7
	DBStd	9.96	5.85	6.44	5.84	5.38	4.87	3.53	2.84	3.09	4.05	5.05	5.44	5.82
	HDD10.0	916	241	192	96	33	3	0	0	0	0	19	98	233
	HDD18.3	2417	494	412	304	178	63	3	1	1	19	144	309	486
	CDD10.0	2382	5	13	51	115	257	427	507	472	341	150	39	5
	CDD18.3	839	0	0	1	10	59	179	249	214	109	17	1	0
	CDH23.3	10278	2	11	73	281	873	2211	2958	2314	1223	299	33	1
	CDH26.7	5364	0	2	13	88	394	1213	1702	1264	582	104	3	0
Wind	WSAvg	4.7	4.4	4.7	5.0	5.6	5.2	5.1	4.4	4.2	4.7	4.6	4.6	4.4
Precipitation	PrecAvg	445	11	14	30	39	63	63	68	56	49	22	20	11
	PrecMax	741	49	46	101	138	212	138	158	192	135	94	94	34
	PrecMin	223	0	0	0	1	6	6	10	7	0	0	0	0
	PrecStd	121	11	15	28	38	41	38	44	44	35	24	22	9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.0	24.9	28.2	32.1	36.2	39.2	39.0	38.4	36.9	32.5	26.7	21.5
		MCWB	9.0	10.6	12.5	14.3	16.6	18.7	20.6	20.8	19.0	15.9	12.2	9.2
	2%	DB	18.1	21.2	25.5	29.0	33.3	37.2	37.6	37.0	34.4	29.8	23.6	17.6
		MCWB	7.2	9.0	11.5	13.1	16.4	19.2	20.4	20.4	18.8	15.2	10.8	7.5
	5%	DB	14.7	17.8	22.5	27.1	31.1	35.6	36.4	35.3	32.5	27.1	20.7	14.6
		MCWB	5.9	7.4	10.3	12.6	15.9	19.1	20.4	20.5	18.6	14.3	9.6	6.0
	10%	DB	11.6	14.1	19.2	23.8	28.5	33.5	34.9	33.6	30.3	23.8	17.3	11.8
		MCWB	4.3	5.8	8.9	11.6	15.6	18.9	20.4	20.1	18.2	13.1	8.2	4.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.8	10.8	14.6	16.1	20.6	22.9	23.8	23.3	22.1	19.9	13.3	9.7
		MCDB	20.5	23.2	24.6	25.8	28.2	32.6	33.6	32.3	30.8	24.5	24.6	20.3
	2%	WB	7.7	9.3	12.5	14.7	19.0	21.7	22.8	22.4	20.9	17.1	11.5	8.0
		MCDB	17.2	20.1	22.0	25.2	27.7	31.8	32.7	31.7	29.8	24.9	21.7	16.9
	5%	WB	6.2	7.7	10.9	13.5	17.7	20.8	22.0	21.7	20.0	15.4	10.2	6.4
		MCDB	14.6	17.1	21.1	23.7	26.8	30.9	32.1	31.3	29.1	24.4	19.2	14.2
	10%	WB	4.5	5.9	9.5	12.4	16.5	20.0	21.2	21.0	19.0	14.0	8.7	4.9
		MCDB	11.2	14.0	18.8	22.2	25.9	30.2	31.5	30.4	27.5	23.1	16.9	11.3
Mean Daily Temperature Range	5% DB	MDBR	13.8	14.7	15.4	15.2	15.2	15.5	14.9	14.2	14.7	14.8	14.5	12.9
		MCDBR	18.6	19.9	19.7	20.1	18.9	18.2	17.0	16.9	17.4	19.0	19.0	17.4
		MCWBR	10.8	11.0	9.8	9.1	7.6	6.2	5.7	5.5	6.3	8.5	9.9	10.0
	5% WB	MCDBR	17.7	19.1	18.3	17.5	16.7	16.1	15.5	14.9	15.1	16.3	17.7	16.8
		MCWBR	10.6	10.9	9.6	8.6	7.4	6.4	5.7	5.7	5.9	8.1	9.6	10.0
Clear-Sky Solar Irradiance	taub	0.254	0.261	0.286	0.313	0.335	0.367	0.369	0.356	0.331	0.296	0.268	0.252	
	taud	2.581	2.569	2.505	2.442	2.440	2.383	2.428	2.432	2.485	2.553	2.563	2.588	
	Ebn at Noon	962	991	986	968	945	910	906	913	923	934	933	942	
	Edh at Noon	73	84	98	111	114	120	114	111	100	84	74	68	
All-Sky Solar Radiation	RadAvg	2.84	3.67	4.97	6.15	7.06	7.59	7.41	6.53	5.54	4.15	3.12	2.50	
	RadStd	0.24	0.34	0.42	0.33	0.41	0.35	0.30	0.32	0.28	0.42	0.26	0.16	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (18 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page