

DURANGO-LA PLATA COUNTY AP, CO, USAWMO: **724625**Lat: **37.143N**Lon: **107.760W**Elev: **6670**StdP: **11.48**Time Zone: **-7.00 (NAM)**Period: **96-19**WBAN: **93005****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-0.3	4.5	-7.6	4.7	13.0	-2.6	6.1	19.6	23.1	34.2	19.9	35.5	3.3	60	0.589

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	31.5	90.2	57.0	88.0	56.6	85.4	56.2	61.6	77.2	60.6	76.5	59.7	75.9	11.3	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
57.5	90.7	62.9	56.5	87.4	63.0	54.8	82.0	63.5	30.7	76.7	29.9	76.8	29.1	75.9	66.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 23.4	19.6	17.0	-9.2	94.1	6.8	1.9	-14.1	95.5	-18.1	96.6	-21.9	97.7	-26.8	99.1		
(5)			-9.7	63.9	6.6	1.2	-14.5	64.8	-18.3	65.5	-22.0	66.2	-26.8	67.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	47.1	24.8	29.6	38.5	45.2	53.4	63.8	70.3	67.6	60.1	47.9	36.6	26.6
	DBStd	16.69	8.50	7.75	6.95	5.91	6.34	5.12	3.41	3.25	5.51	6.30	6.65	8.03
	HDD50	3154	780	572	357	161	39	0	0	0	5	111	403	726
	HDD65	6849	1245	992	821	595	362	81	4	14	161	531	852	1191
	CDD50	2103	0	0	1	17	144	414	629	545	307	46	0	0
	CDD65	321	0	0	0	0	2	44	168	94	13	0	0	0
	CDH74	6567	0	0	0	6	250	1777	2416	1586	516	16	0	0
	CDH80	2250	0	0	0	0	39	629	983	510	89	0	0	0
Wind	WSAvg	6.0	4.6	5.5	6.6	7.9	7.4	6.9	6.1	5.7	5.5	5.7	4.9	4.6
Precipitation	PrecAvg	19.2	1.7	1.5	1.4	1.2	1.1	0.7	2.0	2.6	2.3	1.8	1.5	1.5
	PrecMax	25.9	5.4	4.0	3.7	4.5	3.3	2.3	3.6	5.5	4.6	4.9	3.4	4.4
	PrecMin	12.1	0.0	0.0	0.0	0.1	0.0	0.0	0.1	0.9	0.4	0.0	0.0	0.1
	PrecStd	3.3	1.4	0.9	0.9	1.0	0.9	0.6	0.9	1.1	1.3	1.3	0.9	1.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.2	57.3	69.6	74.0	84.0	91.8	93.4	90.6	85.8	75.6	65.3	54.0
		MCWB	38.8	40.4	45.6	47.3	52.8	56.0	58.1	57.2	56.0	50.9	44.1	38.7
	2%	DB	46.5	52.3	64.2	70.4	80.3	89.3	90.7	88.2	82.3	72.3	61.1	48.2
		MCWB	35.3	37.8	42.9	45.6	51.6	55.3	57.8	56.8	54.7	49.5	42.8	35.8
	5%	DB	43.0	47.6	60.7	67.3	76.5	86.6	88.4	85.5	80.1	69.2	57.1	44.8
		MCWB	33.3	35.8	41.3	44.1	49.6	54.3	57.5	56.8	54.0	47.9	41.1	34.4
	10%	DB	38.7	43.9	56.0	63.7	73.0	83.7	85.9	82.4	76.8	65.0	52.5	40.0
		MCWB	31.7	34.2	39.4	42.8	48.3	53.4	57.6	57.1	53.1	46.6	38.9	32.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	39.9	41.8	46.3	49.7	55.7	60.3	62.9	63.2	60.0	55.7	46.4	41.1
		MCDB	48.6	53.2	65.0	69.1	78.4	78.4	79.1	75.6	74.3	68.8	58.7	49.7
	2%	WB	36.9	39.2	44.1	47.2	53.1	58.6	61.7	61.8	58.4	52.7	44.0	37.6
		MCDB	43.3	49.2	61.9	65.1	74.7	79.6	78.5	75.8	72.8	64.8	57.1	45.5
	5%	WB	34.7	37.0	42.1	45.4	51.4	57.1	60.9	60.6	57.1	50.4	42.0	35.3
		MCDB	40.3	45.7	58.5	63.5	71.9	78.6	77.8	75.1	72.1	62.6	54.7	42.4
	10%	WB	32.8	34.9	40.1	43.7	49.8	55.5	60.0	59.7	55.8	48.3	39.9	33.2
		MCDB	37.7	42.5	54.3	61.4	69.5	77.6	77.2	74.3	70.6	61.3	51.3	39.6
Mean Daily Temperature Range	5% DB	MDBR	25.6	24.5	28.5	30.6	33.0	37.3	31.5	30.4	31.0	30.0	27.7	24.1
		MCDBR	29.5	29.8	36.8	39.2	39.8	41.2	35.7	35.7	35.8	37.0	36.1	29.3
		MCWBR	19.2	17.6	18.9	19.2	17.2	16.6	12.1	12.4	14.1	17.9	20.3	18.8
		MCDDBR	24.4	26.0	33.8	34.2	35.1	34.9	28.0	26.5	27.5	28.5	31.7	25.3
	5% WB	MCWBR	16.4	16.2	17.8	17.3	15.5	14.6	9.1	9.3	11.3	14.7	18.4	16.7
Clear-Sky Solar Irradiance	taub		0.234	0.238	0.260	0.285	0.299	0.301	0.343	0.335	0.297	0.272	0.244	0.236
	taud		2.609	2.613	2.562	2.514	2.524	2.511	2.462	2.452	2.579	2.622	2.643	2.612
	Ebn at Noon		314	324	323	317	311	309	295	296	305	306	308	306
	Edh at Noon		22	25	29	33	33	34	35	35	29	25	21	21
All-Sky Solar Radiation	RadAvg		923	1198	1650	2014	2283	2540	2186	1971	1750	1358	1017	794
	RadStd		77	99	121	114	176	139	127	86	85	112	74	63