

DURANGO-LA PLATA COUNTY AP, CO, USAWMO: **724625**Lat: **37.143N**Lon: **107.760W**Elev: **2033**StdP: **79.17**Time Zone: **-7.00 (NAM)**Period: **96-19**WBAN: **93005****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-17.9	-15.3	-22.0	0.7	-10.6	-19.2	0.9	-6.9	10.3	1.2	8.9	1.9	1.5	60	0.589

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.5	32.3	13.9	31.1	13.7	29.7	13.4	16.4	25.1	15.9	24.7	15.4	24.4	5.0	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.2	13.0	17.2	13.6	12.5	17.2	12.6	11.7	17.5	53.5	24.9	51.6	24.9	49.9	24.4	19.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.5	8.8	7.6	DB	-22.9	34.5	3.8	1.1	-25.6	35.3	-27.8	35.9	-29.9	36.5	-32.7	37.3	(4)
(5)			WB	-23.2	17.7	3.7	0.7	-25.8	18.2	-28.0	18.6	-30.0	19.0	-32.7	19.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.4	-4.0	-1.3	3.6	7.3	11.9	17.7	21.3	19.8	15.6	8.8	2.5	-3.0	(6)	
	DBStd	9.27	4.72	4.30	3.86	3.28	3.52	2.84	1.90	1.81	3.06	3.50	3.70	4.46	(7)	
	HDD10.0	1752	433	318	198	89	22	0	0	0	3	62	224	403	(8)	
	HDD18.3	3805	692	551	456	331	201	45	2	8	89	295	473	662	(9)	
	CDD10.0	1168	0	0	1	9	80	230	349	303	171	26	0	0	(10)	
	CDD18.3	178	0	0	0	0	1	24	93	52	7	0	0	0	(11)	
	CDH23.3	3648	0	0	0	3	139	987	1342	881	287	9	0	0	(12)	
	CDH26.7	1250	0	0	0	0	22	349	546	283	49	0	0	0	(13)	
(14) Wind	WSAvg	2.7	2.1	2.5	2.9	3.5	3.3	3.1	2.7	2.5	2.5	2.5	2.2	2.1	(14)	
(15) Precipitation	PrecAvg	487	42	37	35	30	29	17	50	65	58	46	39	38	(15)	
	PrecMax	659	138	101	94	114	84	58	92	140	116	125	86	111	(16)	
	PrecMin	307	1	0	0	2	0	0	3	22	9	0	0	3	(17)	
	PrecStd	83	36	23	22	25	23	14	23	27	33	32	23	25	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.2	14.1	20.9	23.3	28.9	33.2	34.1	32.6	29.9	24.2	18.5	12.2	(19)	
		MCWB	3.8	4.7	7.5	8.5	11.6	13.3	14.5	14.0	13.3	10.5	6.7	3.7	(20)	
	2%	DB	8.0	11.3	17.9	21.3	26.8	31.8	32.6	31.2	28.0	22.4	16.2	9.0	(21)	
		MCWB	1.8	3.2	6.0	7.6	10.9	12.9	14.4	13.8	12.6	9.7	6.0	2.1	(22)	
	5%	DB	6.1	8.7	16.0	19.6	24.7	30.3	31.3	29.7	26.7	20.7	13.9	7.1	(23)	
		MCWB	0.7	2.1	5.1	6.7	9.8	12.4	14.2	13.8	12.2	8.8	5.0	1.3	(24)	
	10%	DB	3.7	6.6	13.3	17.6	22.8	28.7	30.0	28.0	24.9	18.4	11.4	4.5	(25)	
		MCWB	-0.2	1.2	4.1	6.0	9.0	11.9	14.2	13.9	11.7	8.1	3.9	0.3	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.4	5.4	7.9	9.8	13.2	15.7	17.2	17.3	15.5	13.1	8.0	5.0	(27)	
		MCDB	9.2	11.8	18.3	20.6	25.8	25.8	26.2	24.2	23.5	20.5	14.8	9.8	(28)	
	2%	WB	2.7	4.0	6.7	8.4	11.7	14.8	16.5	16.5	14.6	11.5	6.7	3.1	(29)	
		MCDB	6.3	9.6	16.6	18.4	23.7	26.5	25.8	24.3	22.7	18.2	13.9	7.5	(30)	
	5%	WB	1.5	2.8	5.6	7.4	10.8	13.9	16.0	15.9	14.0	10.2	5.5	1.8	(31)	
		MCDB	4.6	7.6	14.7	17.5	22.2	25.9	25.5	23.9	22.3	17.0	12.6	5.8	(32)	
	10%	WB	0.5	1.6	4.5	6.5	9.9	13.1	15.6	15.4	13.2	9.0	4.4	0.7	(33)	
		MCDB	3.2	5.9	12.4	16.3	20.8	25.4	25.1	23.5	21.4	16.3	10.7	4.2	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	14.2	13.6	15.9	17.0	18.3	20.7	17.5	16.9	17.2	16.7	15.4	13.4	(35)	
		MCDBR	16.4	16.5	20.5	21.8	22.1	22.9	19.8	19.8	19.9	20.5	20.1	16.3	(36)	
		MCWBR	10.7	9.8	10.5	10.7	9.5	9.2	6.7	6.9	7.9	10.0	11.3	10.4	(37)	
	5% WB	MCDBR	13.6	14.5	18.8	19.0	19.5	19.4	15.6	14.7	15.3	15.8	17.6	14.1	(38)	
		MCWBR	9.1	9.0	9.9	9.6	8.6	8.1	5.1	5.1	6.3	8.2	10.2	9.3	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.234	0.238	0.260	0.285	0.299	0.301	0.343	0.335	0.297	0.272	0.244	0.236	(40)	
	taud		2.609	2.613	2.562	2.514	2.524	2.511	2.462	2.452	2.579	2.622	2.643	2.612	(41)	
	Ebn at Noon		990	1021	1017	998	980	974	930	934	961	965	970	966	(42)	
	Edh at Noon		70	79	92	103	104	106	110	109	90	78	67	65	(43)	
(44) All-Sky Solar Radiation	RadAvg		2.91	3.78	5.20	6.35	7.20	8.01	6.89	6.21	5.52	4.28	3.21	2.50	(44)	
	RadStd		0.24	0.31	0.38	0.36	0.56	0.44	0.40	0.27	0.27	0.35	0.23	0.20	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (15 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page