

TELLURIDE, CO, USA

WMO: 724627

Lat: 37.950N

Lon: 107.900W

Elev: 9091

StdP: 10.47

Time Zone: -7.00 (NAM)

Period: 01-19

WBAN: 03011

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	1.4	6.7	-13.5	3.7	29.7	-8.9	4.8	24.9	21.7	32.7	18.7	30.6	4.3	130	0.602

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.1	79.1	49.8	76.9	49.5	74.0	48.9	56.5	65.3	55.0	65.4	53.8	65.0	7.5	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
54.0	87.7	59.4	52.0	81.4	58.3	50.0	75.5	57.9	28.3	65.6	27.2	65.4	26.4	63.7	61.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.3	16.7	14.4	DB	-5.0	82.8	4.8	2.6	-8.4	84.6	-11.2	86.1	-13.9	87.6	-17.4	89.4	(4)
(5)			WB	-5.9	58.2	4.6	1.6	-9.2	59.3	-11.9	60.2	-14.5	61.1	-17.9	62.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	43.1	26.6	26.3	32.9	39.7	47.4	59.2	63.3	60.7	54.6	43.9	35.2	26.3
	DBStd	15.18	8.65	8.13	8.15	7.30	7.50	5.99	3.65	3.86	5.94	7.52	8.69	8.66
	HDD50	3796	725	665	530	313	138	8	0	1	27	210	443	736
	HDD65	8035	1190	1085	995	760	546	185	74	139	314	653	893	1201
	CDD50	1274	0	0	0	3	57	284	413	331	164	22	0	0
	CDD65	39	0	0	0	0	0	11	23	4	1	0	0	0
	CDH74	573	0	0	0	0	3	168	299	87	16	0	0	0
	CDH80	34	0	0	0	0	0	7	27	0	0	0	0	0
Wind	WSAvg	5.6	5.2	5.5	6.1	6.7	6.3	6.3	4.6	4.6	5.3	5.7	5.6	5.1
Precipitation	PrecAvg	22.2	1.7	1.9	2.2	2.0	1.4	0.9	2.1	2.6	2.5	1.9	1.7	1.3
	PrecMax	26.0	3.1	4.5	4.8	4.6	3.9	2.0	4.5	4.2	4.4	3.7	3.2	2.1
	PrecMin	16.9	0.8	1.1	0.6	0.9	0.2	0.1	0.2	0.7	1.1	0.2	0.2	0.6
	PrecStd	2.8	0.7	0.8	1.0	1.0	1.1	0.5	1.1	0.9	1.0	1.0	0.7	0.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.9	50.0	58.6	62.8	72.7	81.2	82.4	79.1	76.7	66.9	58.7	50.0
		MCWB	36.9	34.2	37.9	40.6	46.2	49.4	50.5	49.7	49.2	44.0	38.8	33.5
	2%	DB	45.8	45.6	54.3	59.1	68.1	78.6	80.6	76.8	72.4	63.2	54.7	45.1
		MCWB	31.7	31.6	36.2	38.3	43.6	48.3	50.5	49.8	48.0	42.4	37.5	31.5
	5%	DB	42.5	42.4	50.2	55.4	64.3	75.4	77.3	73.4	70.1	60.6	52.0	41.4
		MCWB	30.2	30.6	34.4	36.8	42.1	47.4	50.7	49.5	47.0	41.2	36.2	30.4
	10%	DB	37.4	37.7	46.0	53.7	62.8	73.0	74.6	72.2	67.6	57.0	47.9	37.4
		MCWB	28.3	28.5	32.4	36.3	41.4	46.0	50.9	49.8	45.9	40.1	34.6	29.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	37.5	36.1	39.4	42.5	48.4	53.4	58.7	58.1	53.9	48.0	41.1	36.4
		MCDB	50.0	44.1	53.2	55.1	67.4	70.7	67.2	64.0	65.2	57.9	52.3	42.6
	2%	WB	34.2	33.8	37.3	40.4	45.9	51.6	56.9	56.5	51.9	46.0	39.0	34.2
		MCDB	42.0	41.3	50.8	54.2	64.5	70.0	66.2	64.1	62.5	56.4	51.5	40.7
	5%	WB	32.1	31.9	35.5	38.7	44.0	50.2	55.5	55.0	50.3	44.0	37.2	32.3
		MCDB	39.1	40.2	47.6	52.6	60.9	69.2	66.2	64.2	61.7	56.1	48.6	39.2
	10%	WB	30.0	30.0	33.7	37.1	42.2	48.6	54.4	53.7	48.9	42.0	35.3	30.3
		MCDB	36.8	37.2	44.4	49.7	58.6	68.4	65.9	63.5	61.0	54.2	46.2	37.0
Mean Daily Temperature Range	5% DB	MDBR	18.0	16.8	18.0	18.5	20.4	23.4	22.1	20.9	20.7	19.0	17.9	16.7
		MCDBR	21.2	18.7	21.4	22.3	24.2	25.9	26.0	24.1	24.2	22.9	21.4	18.2
		MCWBR	12.6	11.0	10.6	10.4	10.3	10.0	9.2	8.6	9.0	10.5	10.6	10.7
	5% WB	MCDBR	18.4	16.3	19.5	20.8	23.5	22.5	19.8	18.1	18.3	18.5	20.1	16.7
		MCWBR	12.1	10.6	10.6	10.1	10.6	9.3	8.0	7.8	7.6	9.1	10.6	10.8
Clear-Sky Solar Irradiance	taub	0.209	0.214	0.235	0.268	0.270	0.274	0.309	0.302	0.268	0.247	0.222	0.212	
	taud	2.554	2.533	2.537	2.521	2.598	2.586	2.527	2.534	2.653	2.680	2.658	2.575	
	Ebn at Noon	323	332	331	322	320	317	305	306	315	316	316	315	
	Edh at Noon	23	27	30	32	31	31	33	32	26	23	21	21	
All-Sky Solar Radiation	RadAvg	876	1136	1581	1932	2196	2502	2157	1922	1711	1304	961	750	
	RadStd	65	89	124	117	180	153	129	92	91	111	71	60	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (20 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page