

TELLURIDE, CO, USA

WMO: 724627

Lat: 37.950N

Lon: 107.900W

Elev: 2771

StdP: 72.18

Time Zone: -7.00 (NAM)

Period: 01-19

WBAN: 03011

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-17.0	-14.1	-25.3	0.5	-1.3	-22.7	0.7	-3.9	9.7	0.4	8.4	-0.8	1.9	130	0.602

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.3	26.2	9.9	24.9	9.7	23.3	9.4	13.6	18.5	12.8	18.6	12.1	18.4	3.4	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.2	12.5	15.2	11.1	11.6	14.6	10.0	10.8	14.4	47.9	18.6	45.4	18.6	43.4	17.6	16.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.6	7.5	6.4	DB	-20.5	28.2	2.7	1.4	-22.5	29.2	-24.0	30.1	-25.5	30.9	-27.4	31.9	(4)
(5)			WB	-21.1	14.5	2.6	0.9	-22.9	15.2	-24.4	15.7	-25.9	16.2	-27.7	16.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	6.2	-3.0	-3.2	0.5	4.3	8.6	15.1	17.4	15.9	12.5	6.6	1.8	-3.2	(6)	
	DBStd	8.43	4.81	4.52	4.53	4.06	4.17	3.33	2.03	2.14	3.30	4.18	4.83	4.81	(7)	
	HDD10.0	2109	403	369	294	174	77	4	0	1	15	117	246	409	(8)	
	HDD18.3	4464	661	603	553	422	303	103	41	77	174	363	496	667	(9)	
	CDD10.0	708	0	0	0	2	32	158	229	184	91	12	0	0	(10)	
	CDD18.3	22	0	0	0	0	0	6	13	2	1	0	0	0	(11)	
	CDH23.3	318	0	0	0	0	2	93	166	48	9	0	0	0	(12)	
	CDH26.7	19	0	0	0	0	0	4	15	0	0	0	0	0	(13)	
(14) Wind	WSAvg	2.5	2.3	2.5	2.7	3.0	2.8	2.8	2.1	2.1	2.4	2.6	2.5	2.3	(14)	
(15) Precipitation	PrecAvg	563	43	48	55	52	36	23	53	67	63	48	42	34	(15)	
	PrecMax	661	80	115	121	118	98	51	115	107	111	94	81	54	(16)	
	PrecMin	429	20	27	16	22	5	3	4	18	28	6	5	14	(17)	
	PrecStd	71	17	21	26	26	27	13	27	24	26	25	18	11	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.7	10.0	14.8	17.1	22.6	27.3	28.0	26.1	24.8	19.4	14.8	10.0	(19)	
		MCWB	2.7	1.2	3.3	4.8	7.9	9.7	10.3	9.8	9.5	6.7	3.8	0.8	(20)	
	2%	DB	7.7	7.5	12.4	15.1	20.1	25.9	27.0	24.9	22.4	17.3	12.6	7.3	(21)	
		MCWB	-0.2	-0.2	2.4	3.5	6.4	9.1	10.3	9.9	8.9	5.8	3.0	-0.3	(22)	
	5%	DB	5.8	5.8	10.1	13.0	17.9	24.1	25.2	23.0	21.2	15.9	11.1	5.2	(23)	
		MCWB	-1.0	-0.8	1.4	2.7	5.6	8.6	10.4	9.7	8.4	5.1	2.3	-0.9	(24)	
	10%	DB	3.0	3.2	7.8	12.1	17.1	22.8	23.7	22.3	19.8	13.9	8.9	3.0	(25)	
		MCWB	-2.1	-2.0	0.2	2.4	5.2	7.8	10.5	9.9	7.7	4.5	1.4	-1.6	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.0	2.3	4.1	5.8	9.1	11.9	14.9	14.5	12.2	8.9	5.0	2.5	(27)	
		MCDB	10.0	6.7	11.8	12.8	19.7	21.5	19.6	17.8	18.4	14.4	11.3	5.9	(28)	
	2%	WB	1.2	1.0	3.0	4.7	7.7	10.9	13.8	13.6	11.0	7.8	3.9	1.2	(29)	
		MCDB	5.5	5.2	10.5	12.3	18.0	21.1	19.0	17.8	16.9	13.6	10.8	4.8	(30)	
	5%	WB	0.0	-0.1	1.9	3.7	6.6	10.1	13.0	12.8	10.2	6.7	2.9	0.2	(31)	
		MCDB	3.9	4.5	8.7	11.5	16.0	20.6	19.0	17.9	16.5	13.4	9.2	4.0	(32)	
	10%	WB	-1.1	-1.1	0.9	2.8	5.7	9.2	12.4	12.1	9.4	5.6	1.8	-1.0	(33)	
		MCDB	2.7	2.9	6.9	9.9	14.8	20.2	18.8	17.5	16.1	12.3	7.9	2.8	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	10.0	9.3	10.0	10.3	11.3	13.0	12.3	11.6	11.5	10.6	10.0	9.3	(35)	
		MCDBR	11.8	10.4	11.9	12.4	13.5	14.4	14.4	13.4	13.5	12.7	11.9	10.1	(36)	
	5% WB	MCWBR	7.0	6.1	5.9	5.8	5.7	5.6	5.1	4.8	5.0	5.9	5.9	6.0	(37)	
		MCWBR	10.2	9.1	10.8	11.5	13.0	12.5	11.0	10.1	10.2	10.3	11.1	9.3	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.209	0.214	0.235	0.268	0.270	0.274	0.309	0.302	0.268	0.247	0.222	0.212	(40)	
		taud	2.554	2.533	2.537	2.521	2.598	2.586	2.527	2.534	2.653	2.680	2.658	2.575	(41)	
	Ebn at Noon	Ebn at Noon	1018	1048	1043	1014	1010	1000	962	966	992	995	997	993	(42)	
		Edh at Noon	71	84	94	102	97	98	103	100	83	73	65	65	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	2.76	3.58	4.99	6.09	6.92	7.89	6.80	6.06	5.39	4.11	3.03	2.36	(44)	
	RadStd	RadStd	0.20	0.28	0.39	0.37	0.57	0.48	0.41	0.29	0.29	0.35	0.22	0.19	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB		1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (20 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page