

LA JUNTA, CO, USA

WMO: 724635

Lat: 38.049N

Lon: 103.512W

Elev: 1278

StdP: 86.88

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 23067

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-15.9	-12.9	-20.5	0.7	-7.6	-18.0	0.9	-4.5	14.4	4.8	12.4	5.0	3.5	270	0.617

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.4	37.9	17.6	36.5	17.6	35.0	17.5	20.5	30.3	19.9	30.1	19.3	29.5	4.8	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.9	15.1	22.0	17.3	14.5	21.8	16.6	13.8	22.1	64.4	30.3	62.3	29.8	60.3	29.4	23.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.4	11.4	9.5	-20.4	40.5	3.9	1.6	-23.2	41.6	-25.5	42.6	-27.8	43.5	-30.6	44.6		
(5)			-20.8	21.7	3.8	0.6	-23.6	22.2	-25.8	22.5	-28.0	22.9	-30.8	23.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	12.8	0.3	2.2	7.5	11.7	17.3	23.4	26.1	24.9	20.4	12.7	5.9	0.2	(6)
(7)		DBStd	10.44	5.87	6.20	5.53	5.10	4.57	3.77	2.75	2.80	4.37	5.20	5.26	5.77	(7)
(8)		HDD10.0	1166	303	226	113	40	5	0	0	0	2	32	141	305	(8)
(9)		HDD18.3	2781	560	453	338	203	74	6	0	1	29	184	373	562	(9)
(10)		CDD10.0	2173	1	6	34	92	230	401	500	462	313	114	18	1	(10)
(11)		CDD18.3	747	0	0	1	4	41	157	242	204	90	8	0	0	(11)
(12)		CDH23.3	9977	0	5	49	188	732	2100	3038	2369	1239	241	16	0	(12)
(13)		CDH26.7	5214	0	1	7	44	306	1142	1764	1280	595	76	1	0	(13)
(14)	Wind	WSAvg	4.4	3.9	4.4	4.8	5.5	5.0	4.9	4.2	4.0	4.1	4.2	4.1	4.0	(14)
(15)	Precipitation	PrecAvg	285	8	8	18	30	39	34	58	34	19	17	12	8	(15)
(16)		PrecMax	442	22	36	88	118	107	85	141	108	52	59	45	23	(16)
(17)		PrecMin	152	0	0	0	0	0	0	1	2	3	0	0	0	(17)
(18)		PrecStd	76	7	9	19	26	25	23	34	25	12	16	13	6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	20.5	23.0	27.6	30.4	35.2	39.7	39.5	38.8	36.8	31.6	25.3	19.9	(19)
(20)			MCWB	7.7	8.7	10.6	12.0	15.1	16.3	18.2	17.9	16.9	13.8	10.2	7.6	(20)
(21)		2%	DB	17.0	19.6	24.4	27.8	32.5	37.3	38.0	36.8	34.5	28.9	22.5	16.2	(21)
(22)			MCWB	6.1	7.3	9.3	11.2	14.4	16.5	18.1	17.8	16.4	12.9	9.2	6.0	(22)
(23)		5%	DB	13.2	16.6	21.9	25.6	30.2	35.2	36.8	35.2	32.6	26.2	19.2	13.1	(23)
(24)			MCWB	4.6	6.0	8.6	10.8	13.9	16.5	18.1	17.9	16.1	12.4	8.0	4.5	(24)
(25)		10%	DB	9.8	12.8	18.6	22.8	27.8	33.1	35.2	33.4	30.5	23.0	16.0	9.9	(25)
(26)			MCWB	3.0	4.3	7.5	10.0	13.5	16.5	18.3	18.1	15.6	11.3	6.7	3.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.2	9.3	11.5	14.1	17.9	20.4	21.3	21.2	19.3	16.3	11.2	8.1	(27)
(28)			MCDB	19.2	22.2	23.3	24.4	28.4	30.6	31.2	29.9	28.7	24.8	22.4	19.2	(28)
(29)		2%	WB	6.4	7.7	10.2	12.7	16.6	19.3	20.6	20.4	18.4	14.7	9.8	6.3	(29)
(30)			MCDB	15.8	18.7	22.4	23.5	26.7	29.7	30.6	30.0	27.7	24.3	20.8	15.7	(30)
(31)		5%	WB	4.8	6.2	9.0	11.6	15.6	18.5	20.0	19.9	17.6	13.3	8.5	4.8	(31)
(32)			MCDB	12.8	16.1	20.3	22.6	25.7	29.2	30.3	29.9	27.8	23.1	18.5	12.7	(32)
(33)		10%	WB	3.3	4.6	7.9	10.6	14.7	17.8	19.5	19.2	16.8	12.1	7.0	3.1	(33)
(34)			MCDB	9.3	12.4	17.9	21.7	24.7	28.5	29.9	29.0	27.2	21.8	15.6	9.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	15.0	15.2	16.7	16.1	16.1	16.7	16.4	15.7	16.4	16.6	16.0	14.6	(35)
(36)			MCDBR	20.6	21.1	21.5	20.9	20.0	19.6	18.6	18.2	19.3	21.1	21.3	19.7	(36)
(37)			MCWBR	11.7	11.0	9.8	8.5	7.1	6.0	5.2	4.9	6.3	8.9	10.7	11.2	(37)
(38)		5% WB	MCDBR	19.6	20.2	20.2	19.0	17.4	17.1	15.7	15.6	16.6	18.1	20.0	18.9	(38)
(39)			MCWBR	11.3	10.8	9.7	8.1	6.9	6.1	4.9	4.9	5.7	8.1	10.3	11.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.245	0.253	0.278	0.308	0.328	0.345	0.372	0.355	0.319	0.278	0.256	0.246	(40)	
(41)		taud	2.601	2.598	2.519	2.430	2.435	2.410	2.395	2.421	2.492	2.597	2.578	2.588	(41)	
(42)		Ebn at Noon	969	998	993	971	951	930	901	912	933	953	942	942	(42)	
(43)		Edh at Noon	70	80	96	112	114	117	118	112	98	79	71	66	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.77	3.62	4.97	6.12	7.01	7.64	7.49	6.69	5.59	4.20	3.07	2.42	(44)	
(45)		RadStd	0.19	0.29	0.36	0.33	0.39	0.32	0.24	0.22	0.27	0.28	0.21	0.16	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	+0.38	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (15 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+80	+49

Nomenclature: See separate page