

HILL CITY, KS, USA

WMO: 724655

Lat: 39.376N

Lon: 99.830W

Elev: 667

StdP: 93.57

Time Zone: -6.00 (NAC)

Period: 96-19

WBAN: 93990

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-16.6	-13.8	-21.0	0.6	-15.1	-18.3	0.8	-12.1	13.6	2.2	12.0	3.5	3.4	0	0.601

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.4	38.6	21.7	37.0	21.7	35.0	21.5	24.3	32.6	23.6	32.1	22.8	31.4	6.0	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.2	18.3	27.9	21.3	17.3	26.9	20.5	16.5	26.3	76.8	32.3	73.6	32.1	70.9	31.4	27.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.4	11.0	9.4	-21.0	41.4	2.5	1.6	-22.7	42.5	-24.2	43.5	-25.6	44.4	-27.3	45.6		
(5)			-21.4	25.5	2.3	0.8	-23.0	26.1	-24.3	26.6	-25.6	27.0	-27.3	27.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	12.4	-0.7	0.6	6.3	11.4	17.3	23.5	26.8	25.0	20.5	12.7	5.5	-0.4
	DBStd	11.03	6.10	6.42	6.08	5.36	4.82	4.16	3.54	3.29	4.82	5.47	5.45	5.77
	HDD10.0	1304	332	267	145	46	4	0	0	0	1	34	153	323
	HDD18.3	2944	590	496	374	215	78	7	1	1	32	186	385	580
	CDD10.0	2196	1	4	29	87	229	406	520	464	317	118	18	1
	CDD18.3	794	0	0	1	7	46	163	262	206	98	12	0	0
	CDH23.3	9852	1	6	38	158	637	2017	3278	2300	1184	219	14	0
	CDH26.7	5104	0	1	6	47	258	1054	1888	1217	563	70	1	0
Wind	WSAvg	4.3	4.0	4.4	4.8	5.3	4.7	4.5	4.0	3.7	4.2	4.3	4.1	4.0
Precipitation	PrecAvg	555	13	15	33	51	96	77	89	77	55	38	19	15
	PrecMax	825	35	41	92	147	319	181	322	179	167	172	67	118
	PrecMin	305	0	1	0	2	26	24	13	11	18	0	0	0
	PrecStd	118	9	12	25	31	60	38	61	45	34	39	16	23
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	20.0	23.1	27.2	31.2	35.5	40.4	41.1	39.1	37.7	32.4	25.4	18.0
		MCWB	8.8	10.0	13.6	15.6	18.3	21.0	22.0	21.4	20.4	18.3	12.4	8.8
	2%	DB	15.9	18.2	23.8	27.6	32.2	37.1	39.1	37.3	34.9	28.2	22.0	14.7
		MCWB	6.8	8.6	12.2	15.2	18.8	21.4	21.9	21.7	20.4	16.5	11.6	7.0
	5%	DB	12.2	14.3	20.9	24.6	29.5	34.9	37.5	35.2	32.5	25.8	18.2	11.9
		MCWB	5.3	6.8	11.3	14.4	18.3	21.3	22.3	21.8	20.0	15.5	10.0	5.7
	10%	DB	8.8	11.2	17.4	21.6	27.1	32.6	35.5	33.0	30.0	22.6	15.2	8.7
		MCWB	3.5	5.3	10.1	13.1	17.5	20.9	22.2	21.6	19.3	14.4	8.2	3.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.5	11.4	16.7	18.0	22.1	24.7	25.4	25.1	23.6	20.5	14.6	10.4
		MCDB	18.2	18.4	22.2	25.2	29.2	33.6	34.2	33.0	31.1	27.7	20.5	16.2
	2%	WB	7.3	9.3	14.4	16.6	20.7	23.4	24.5	24.0	22.2	18.8	12.6	7.5
		MCDB	14.9	17.7	20.5	24.1	28.2	32.2	33.2	31.8	30.3	24.6	18.9	13.9
	5%	WB	5.6	7.4	12.3	15.2	19.6	22.5	23.8	23.1	21.1	17.0	10.8	5.7
		MCDB	11.7	13.9	18.4	22.8	26.8	31.4	32.6	31.2	29.1	23.1	17.6	11.3
	10%	WB	3.8	5.5	10.2	13.7	18.5	21.6	23.1	22.4	20.2	15.2	8.9	4.0
		MCDB	8.5	10.9	17.7	20.8	25.2	30.3	32.1	30.3	27.6	21.1	15.2	8.6
Mean Daily Temperature Range	5% DB	MDBR	13.6	13.8	15.3	14.8	14.3	14.6	14.4	13.9	14.8	15.0	14.7	13.2
		MCDBR	19.6	20.4	20.9	19.7	18.2	17.6	17.0	16.8	17.3	19.4	20.0	18.1
		MCWBR	12.1	12.0	11.4	9.7	7.7	5.8	5.0	5.5	6.5	9.2	11.1	11.5
	5% WB	MCDBR	18.7	19.2	18.0	16.8	15.2	15.4	14.8	14.5	14.9	15.8	18.3	17.3
		MCWBR	11.8	11.7	10.7	9.1	7.6	6.2	5.4	5.6	6.4	8.4	10.6	11.3
Clear-Sky Solar Irradiance	taub		0.270	0.276	0.306	0.339	0.364	0.380	0.404	0.386	0.350	0.306	0.276	0.264
	taud		2.521	2.518	2.449	2.384	2.394	2.382	2.354	2.393	2.433	2.545	2.548	2.534
	Ebn at Noon		919	960	955	936	914	896	879	879	894	910	904	900
	Edh at Noon		74	85	102	117	118	120	122	115	103	83	71	68
All-Sky Solar Radiation	RadAvg		2.45	3.27	4.49	5.53	6.36	7.15	7.02	6.12	5.04	3.68	2.71	2.13
	RadStd		0.18	0.30	0.37	0.29	0.41	0.38	0.29	0.37	0.29	0.38	0.19	0.17

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB		1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (15 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page