

LEADVILLE LAKE COUNTY AP, CO, USA

WMO: 724673

Lat: 39.229N

Lon: 106.317W

Elev: 3027

StdP: 69.87

Time Zone: -7.00 (NAM)

Period: 98-19

WBAN: 93009

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-22.1	-19.4	-27.3	0.4	-16.7	-25.1	0.6	-14.4	10.9	-5.8	9.3	-6.5	3.0	50	0.751

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.2	23.4	8.8	22.4	8.6	21.2	8.3	11.3	17.9	10.6	17.5	10.1	16.8	4.9	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.3	10.6	11.9	8.5	10.1	11.5	7.7	9.5	11.2	40.8	17.9	39.0	17.4	37.3	16.5	15.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.3	8.3	7.5	DB	-27.1	26.0	2.6	0.7	-29.0	26.5	-30.5	27.0	-32.0	27.4	-33.9	27.9	(4)
(5)			WB	-27.4	12.9	2.5	1.0	-29.2	13.6	-30.7	14.2	-32.1	14.7	-33.9	15.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	1.8	-7.9	-7.7	-4.0	-0.2	4.9	10.6	13.4	12.0	8.6	2.8	-3.3	-8.1	(6)
(7)		DBStd	8.67	4.60	4.69	4.51	4.07	3.94	2.78	1.62	1.79	2.81	4.15	5.17	4.95	(7)
(8)		HDD10.0	3218	554	495	433	306	161	26	1	4	54	224	400	560	(8)
(9)		HDD18.3	6026	812	728	691	556	416	231	152	197	291	483	650	818	(9)
(10)		CDD10.0	234	0	0	0	0	3	44	107	66	14	0	0	0	(10)
(11)		CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)
(12)		CDH23.3	34	0	0	0	0	0	9	22	3	1	0	0	0	(12)
(13)		CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	3.2	3.5	3.6	3.5	3.6	3.4	3.3	2.7	2.5	2.8	3.3	3.3	3.5	(14)
(15)	Precipitation	PrecAvg	419	31	30	37	46	35	22	49	51	35	27	28	27	(15)
(16)		PrecMax	549	79	73	66	79	95	41	88	84	84	74	50	68	(16)
(17)		PrecMin	307	12	14	14	20	7	7	9	19	8	8	11	10	(17)
(18)		PrecStd	52	16	14	12	17	19	11	19	19	15	13	9	14	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.6	7.0	10.9	14.1	21.0	24.6	25.2	23.6	22.2	17.3	12.4	6.6	(19)
(20)			MCWB	-0.9	-1.0	1.5	2.9	7.1	8.5	9.6	8.9	7.9	4.9	1.6	-1.3	(20)
(21)		2%	DB	3.4	4.1	8.3	11.7	17.7	22.8	23.8	22.3	20.0	15.1	9.8	3.8	(21)
(22)			MCWB	-2.7	-2.4	0.1	1.8	5.4	8.0	9.1	8.7	7.4	3.9	0.8	-2.6	(22)
(23)		5%	DB	1.7	2.1	6.2	9.8	15.9	21.5	22.7	21.1	18.5	13.1	7.5	1.7	(23)
(24)			MCWB	-3.3	-3.1	-0.9	1.2	4.5	7.4	8.9	8.6	6.7	3.2	-0.3	-3.5	(24)
(25)		10%	DB	-0.4	0.0	4.0	7.9	13.9	20.1	21.6	19.6	17.2	11.2	5.1	-0.4	(25)
(26)			MCWB	-4.3	-4.2	-2.0	0.3	3.8	6.9	9.0	8.5	6.2	2.5	-1.5	-4.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-0.3	-0.3	1.8	3.8	7.9	10.8	12.8	11.9	10.3	6.7	2.4	-0.6	(27)
(28)			MCDWB	4.0	4.6	9.4	12.3	17.8	20.2	18.8	17.3	17.1	12.8	10.1	4.8	(28)
(29)		2%	WB	-1.7	-1.8	0.5	2.5	6.3	9.5	11.6	11.0	9.1	5.1	1.2	-1.9	(29)
(30)			MCDWB	2.2	2.9	7.3	9.7	15.1	18.7	18.3	17.2	15.5	12.3	8.5	2.3	(30)
(31)		5%	WB	-2.8	-2.8	-0.5	1.6	5.2	8.6	11.0	10.4	8.2	4.0	0.1	-2.9	(31)
(32)			MCDWB	0.7	1.4	5.3	8.4	13.8	17.7	17.9	16.7	14.7	11.4	6.6	0.9	(32)
(33)		10%	WB	-4.0	-3.9	-1.5	0.7	4.4	7.8	10.4	9.8	7.4	3.0	-1.0	-4.1	(33)
(34)			MCDWB	-0.5	-0.4	3.5	7.0	12.7	17.5	17.3	16.0	14.3	9.6	4.6	-0.6	(34)
(35)	Mean Daily Temperature Range			MDBR	11.7	11.3	11.9	11.8	13.7	16.7	16.2	15.2	13.0	12.4	11.4	(35)
(36)		5% DB	MCDBR	14.3	13.3	14.2	15.2	17.4	19.1	18.4	17.8	18.2	16.7	15.3	13.5	(36)
(37)			MCWBR	9.8	8.8	8.2	7.6	7.5	7.8	6.8	6.9	7.8	8.2	8.5	8.9	(37)
(38)		5% WB	MCDBR	12.5	11.7	13.1	13.6	15.8	17.1	14.9	14.0	14.9	14.7	13.9	12.0	(38)
(39)			MCWBR	8.8	8.0	7.7	7.2	7.2	7.3	6.1	6.0	7.0	7.5	7.9	8.3	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.203	0.212	0.234	0.263	0.274	0.279	0.305	0.302	0.266	0.245	0.217	0.205	(40)
(41)		taud		2.461	2.424	2.398	2.452	2.562	2.566	2.543	2.519	2.640	2.655	2.618	2.501	(41)
(42)		Ebn at Noon		1014	1041	1038	1017	1004	994	964	963	990	991	993	989	(42)
(43)		Edh at Noon		76	92	106	108	100	99	101	101	83	73	65	68	(43)
(44)	All-Sky Solar Radiation	RadAvg		2.73	3.69	5.09	5.83	6.25	7.29	6.45	5.71	5.18	3.87	2.78	2.27	(44)
(45)		RadStd		0.13	0.20	0.38	0.39	0.48	0.45	0.35	0.28	0.34	0.30	0.22	0.17	(45)

Historical Trends

		DBAvg		Heating		Cooling			Degree-Days					
				99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)			
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)		
(47)	Regional (34 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+66	+21	(47)	

Nomenclature: See separate page