

MEEKER, CO, USA

WMO: 724674

Lat: 40.044N

Lon: 107.889W

Elev: 6366

StdP: 11.62

Time Zone: -7.00 (NAM)

Period: 99-19

WBAN: 94050

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-9.8	-3.6	-15.0	3.1	-9.1	-8.7	4.4	-2.9	22.0	37.5	19.3	37.7	1.8	50	0.613

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	34.6	90.6	57.3	88.3	56.7	85.7	56.1	61.4	79.5	60.2	78.6	59.1	77.6	9.5	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
56.5	86.6	64.2	54.7	80.7	64.0	52.8	75.2	64.3	30.3	79.3	29.4	78.9	28.5	77.2	66.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.7	19.0	16.5	-21.7	94.5	6.4	1.9	-26.2	95.9	-30.0	97.0	-33.5	98.1	-38.1	99.5		
(5)			-21.7	64.2	6.2	1.6	-26.2	65.3	-29.8	66.2	-33.3	67.1	-37.9	68.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	44.7	20.4	26.2	36.1	43.6	51.9	62.1	69.0	66.4	58.1	45.5	33.7	22.1		
	DBStd	18.26	10.75	9.87	8.67	7.25	7.12	5.81	3.53	3.69	6.01	7.93	9.94	10.72		
	HDD50	3836	917	666	434	208	64	3	0	0	12	176	490	866		
	HDD65	7654	1382	1085	897	642	406	118	7	27	215	605	939	1331		
	CDD50	1893	0	0	2	16	124	364	589	507	254	36	1	0		
	CDD65	239	0	0	0	0	1	30	131	70	7	0	0	0		
	CDH74	6304	0	0	0	5	175	1392	2544	1631	535	22	0	0		
	CDH80	2326	0	0	0	0	29	486	1122	580	108	1	0	0		
(14) Wind	WSAvg	5.3	3.3	4.5	5.7	7.0	6.7	6.7	5.7	5.6	5.7	5.1	4.4	3.6		
(15) Precipitation	PrecAvg	15.0	0.9	1.0	1.3	1.5	1.4	1.3	1.3	1.5	1.4	1.4	1.0	1.1		
	PrecMax	21.2	2.1	3.1	2.2	3.2	3.0	4.2	2.9	3.6	6.0	4.1	2.0	2.8		
	PrecMin	9.9	0.2	0.1	0.4	0.6	0.0	0.0	0.1	0.2	0.4	0.1	0.1	0.1		
	PrecStd	3.3	0.5	0.8	0.6	0.7	0.8	1.1	0.8	0.8	1.2	1.0	0.5	0.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.1	54.3	69.6	73.7	83.6	91.9	94.3	91.5	86.9	77.1	65.8	52.0		
		MCWB	37.0	40.3	45.1	47.7	53.5	56.3	58.9	57.8	55.3	50.3	44.7	38.0		
	2%	DB	44.1	49.1	63.1	69.8	78.8	88.5	91.4	88.7	82.9	72.0	61.0	46.3		
		MCWB	34.8	37.4	42.8	45.6	51.0	55.5	57.8	56.7	53.7	48.8	42.8	36.1		
	5%	DB	40.4	45.3	57.4	66.0	74.9	85.7	89.7	86.2	80.5	68.0	56.1	42.3		
		MCWB	33.1	35.2	40.7	43.9	49.6	54.5	57.5	56.0	52.8	47.3	40.9	34.0		
	10%	DB	37.1	41.8	53.1	62.5	71.7	82.2	86.9	83.3	76.9	63.8	51.3	37.6		
		MCWB	31.5	33.9	38.7	42.9	48.7	53.7	57.4	56.2	52.1	45.7	38.8	31.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	38.8	41.6	46.2	49.2	55.4	60.2	63.7	62.4	59.4	53.3	46.3	39.5		
		MCDB	44.8	51.6	66.3	70.1	78.5	81.8	79.1	78.6	77.7	67.2	61.9	48.2		
	2%	WB	36.2	38.2	43.7	46.7	53.0	58.4	62.0	61.0	57.3	50.9	43.4	37.0		
		MCDB	42.1	47.2	61.3	64.9	72.9	80.5	80.0	77.7	73.1	67.2	58.6	44.7		
	5%	WB	33.9	36.1	41.4	45.2	51.2	56.7	60.8	59.8	55.7	48.9	41.5	34.4		
		MCDB	39.0	43.9	56.1	62.7	70.2	79.1	79.7	76.5	70.9	64.5	55.1	41.2		
	10%	WB	31.9	34.3	39.2	43.6	49.8	55.1	59.7	58.7	54.1	46.9	39.2	32.1		
		MCDB	37.0	41.0	51.4	60.2	68.0	77.5	79.0	75.4	69.9	61.3	49.6	37.6		
(35) Mean Daily Temperature Range	MDBR		24.5	23.4	25.5	27.4	30.1	35.7	34.6	32.9	33.2	29.5	26.4	23.2		
	5% DB	MCDBR	24.5	24.6	33.0	37.3	37.9	41.6	40.1	39.3	39.9	38.0	34.4	25.1		
		MCWBR	17.2	15.3	16.6	17.1	15.8	16.2	14.6	14.7	16.5	18.5	18.9	16.5		
	5% WB	MCDBR	20.9	22.3	31.1	32.4	33.7	36.0	31.0	29.4	30.2	32.1	32.2	22.2		
		MCWBR	15.0	14.1	16.1	15.5	14.7	14.6	11.7	11.5	13.0	16.3	17.8	14.8		
(40) Clear-Sky Solar Irradiance	taub		0.237	0.247	0.269	0.296	0.304	0.307	0.339	0.337	0.294	0.271	0.248	0.240		
	taud		2.537	2.524	2.522	2.485	2.523	2.515	2.464	2.464	2.588	2.623	2.609	2.534		
	Ebn at Noon		305	315	316	311	308	306	295	293	303	302	299	295		
	Edh at Noon		23	26	30	33	33	33	35	34	28	24	21	21		
(44) All-Sky Solar Radiation	RadAvg		740	1000	1436	1783	2066	2454	2251	1966	1681	1194	814	621		
	RadStd		48	73	124	118	144	146	103	85	99	96	78	53		

Historical Trends

		DBAvg		Heating		Cooling			Degree-Days			
				99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (17 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page