

EAGLE COUNTY REGIONAL, CO, USA

WMO: 724675

Lat: 39.650N

Lon: 106.917W

Elev: 6497

StdP: 11.56

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 23063

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-4.3	0.6	-9.1	4.3	-1.8	-4.6	5.5	4.1	24.4	37.6	20.4	35.7	1.4	100	0.638

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	34.5	89.9	56.9	87.7	56.0	84.2	55.1	59.6	79.2	58.6	78.0	57.4	76.6	11.0	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
54.4	80.5	62.3	52.7	75.5	62.3	50.8	70.1	62.8	29.2	79.5	28.3	77.8	27.5	76.4	64.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 24.8	21.0	18.5	DB	-13.0	92.7	6.0	2.6	-17.3	94.5	-20.8	96.0	-24.2	97.4	-28.6	99.3	(4)
(5)			WB	-13.4	61.5	5.8	1.7	-17.6	62.7	-21.0	63.7	-24.3	64.6	-28.5	65.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	44.6	23.2	27.2	36.3	43.4	52.5	60.9	67.9	65.6	57.5	44.9	32.5	22.1		
	DBStd	17.14	8.14	8.01	6.91	6.28	6.62	5.36	4.01	3.30	6.04	7.11	8.47	8.92		
	HDD50	3744	832	637	426	208	52	3	0	0	13	182	526	865		
	HDD65	7633	1297	1057	890	649	388	140	18	33	231	624	976	1330		
	CDD50	1767	0	0	0	9	131	330	554	482	238	23	0	0		
	CDD65	183	0	0	0	0	2	17	107	50	7	0	0	0		
	CDH74	5318	0	0	0	0	200	1079	2233	1363	434	9	0	0		
	CDH80	1823	0	0	0	0	39	313	943	427	101	0	0	0		
	WSAvg	5.5	4.1	4.9	5.9	7.3	7.1	7.1	5.7	5.4	5.5	5.1	4.3	3.8		
	PrecAvg	10.4	0.8	0.6	0.9	0.7	0.8	0.9	1.2	1.0	1.2	0.9	0.6	0.9		
(15) Precipitation	PrecMax	16.1	2.9	1.5	2.0	1.9	2.7	2.4	3.3	3.0	4.7	2.9	2.0	2.4		
	PrecMin	6.9	0.0	0.1	0.1	0.1	0.0	0.0	0.2	0.2	0.1	0.0	0.2	0.1		
	PrecStd	2.3	0.7	0.4	0.5	0.6	0.6	0.7	0.8	0.7	1.1	0.8	0.4	0.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.1	52.3	64.3	71.9	84.2	90.3	92.9	90.2	87.8	75.0	61.3	51.6		
		MCWB	36.4	38.3	43.5	46.6	53.1	55.1	58.2	56.7	56.6	49.2	41.9	37.0		
	2%	DB	43.2	46.8	60.5	67.8	79.2	86.4	90.7	87.8	82.5	71.7	56.6	43.9		
		MCWB	34.3	35.7	41.3	45.1	50.9	53.9	57.5	56.2	54.0	48.0	40.4	34.6		
	5%	DB	38.9	43.5	55.4	64.3	75.0	83.6	88.5	84.4	79.2	66.2	52.4	39.0		
		MCWB	31.9	33.8	39.4	43.2	48.9	53.3	56.7	55.6	52.5	45.6	38.9	32.0		
	10%	DB	36.2	39.5	51.9	61.3	72.2	81.1	86.0	81.9	75.2	62.8	46.4	35.9		
		MCWB	30.7	32.2	37.8	42.1	48.1	52.4	56.2	55.4	51.4	44.2	36.5	30.2		
	0.4%	WB	38.2	39.1	45.2	47.6	55.1	57.9	61.4	60.6	57.8	52.6	43.8	38.0		
		MCDB	44.3	49.6	62.8	66.4	80.9	77.9	82.0	78.7	79.6	65.0	57.8	47.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	35.2	36.5	42.2	45.8	52.1	56.0	60.2	59.3	56.4	49.4	41.3	35.1		
		MCDB	41.2	45.3	57.5	64.2	74.7	78.2	80.4	77.8	76.2	66.9	54.0	43.1		
	5%	WB	33.0	34.9	40.2	44.3	50.4	54.8	59.2	58.3	54.9	47.3	39.3	32.5		
		MCDB	38.5	42.4	54.2	61.7	71.7	77.8	79.1	76.6	73.0	62.9	50.5	38.4		
	10%	WB	31.0	33.1	38.2	42.7	48.9	53.4	58.1	57.2	53.2	45.3	37.2	30.4		
		MCDB	35.4	39.2	50.3	58.9	69.3	76.2	77.8	75.4	70.2	60.7	46.0	35.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	22.8	22.4	24.7	26.5	30.7	34.3	34.5	32.3	32.6	30.8	24.7	23.4		
		MCDBR	24.0	25.2	33.5	36.1	38.8	40.0	38.9	38.1	39.0	40.3	33.4	24.9		
		MCWBR	16.4	15.8	17.7	17.3	17.0	16.5	14.9	15.0	16.8	20.7	19.0	16.8		
		MCDBR	21.4	22.1	30.9	32.6	34.9	34.8	31.2	29.4	32.0	34.2	30.2	23.0		
	5% WB	MCWBR	15.1	14.0	16.7	15.8	15.4	14.2	11.3	11.4	13.6	17.8	17.5	15.7		
(40) Clear-Sky Solar Irradiance	taub		0.234	0.246	0.275	0.306	0.319	0.321	0.354	0.352	0.300	0.278	0.249	0.237		
	taud		2.434	2.389	2.429	2.431	2.478	2.473	2.428	2.416	2.572	2.602	2.577	2.473		
	Ebn at Noon		305	314	314	308	304	302	291	289	301	300	298	296		
	Edh at Noon		25	30	33	35	34	35	36	36	28	24	22	22		
(44) All-Sky Solar Radiation	RadAvg		802	1082	1538	1799	1975	2374	2137	1851	1636	1183	828	658		
	RadStd		42	70	124	129	151	151	110	92	108	102	81	56		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (28 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page