

EAGLE COUNTY REGIONAL, CO, USA

WMO: 724675

Lat: 39.650N

Lon: 106.917W

Elev: 1980

StdP: 79.69

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 23063

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-20.2	-17.5	-22.8	0.6	-18.8	-20.3	0.8	-15.5	10.9	3.1	9.1	2.1	0.6	100	0.638

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.2	32.2	13.8	30.9	13.3	29.0	12.8	15.4	26.2	14.8	25.5	14.1	24.8	4.9	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.5	11.5	16.8	11.5	10.8	16.8	10.4	10.0	17.1	50.0	26.4	48.0	25.4	46.1	24.7	18.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.1	9.4	8.3	DB	-25.0	33.7	3.3	1.4	-27.4	34.7	-29.4	35.5	-31.2	36.3	-33.6	37.4	(4)
(5)			WB	-25.2	16.4	3.2	0.9	-27.5	17.1	-29.4	17.6	-31.3	18.1	-33.6	18.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.0	-4.9	-2.6	2.4	6.3	11.4	16.1	19.9	18.6	14.2	7.1	0.3	-5.5	(6)	
	DBStd	9.52	4.52	4.45	3.84	3.49	3.68	2.98	2.23	1.83	3.36	3.95	4.70	4.95	(7)	
	HDD10.0	2080	462	354	237	116	29	2	0	0	7	101	292	481	(8)	
	HDD18.3	4241	721	587	494	361	216	78	10	18	128	347	542	739	(9)	
	CDD10.0	982	0	0	0	5	73	183	308	268	132	13	0	0	(10)	
	CDD18.3	102	0	0	0	0	1	9	59	28	4	0	0	0	(11)	
	CDH23.3	2954	0	0	0	0	111	599	1241	757	241	5	0	0	(12)	
	CDH26.7	1013	0	0	0	0	22	174	524	237	56	0	0	0	(13)	
(14) Wind	WSAvg	2.5	1.8	2.2	2.7	3.2	3.2	3.2	2.5	2.4	2.5	2.3	1.9	1.7	(14)	
(15) Precipitation	PrecAvg	265	20	14	22	19	21	22	30	25	30	24	16	24	(15)	
	PrecMax	409	73	37	52	47	69	60	83	77	119	74	51	62	(16)	
	PrecMin	175	0	2	2	2	0	0	4	5	2	0	4	2	(17)	
	PrecStd	58	17	10	13	14	15	17	20	18	28	20	10	17	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.0	11.3	18.0	22.1	29.0	32.4	33.8	32.3	31.0	23.9	16.3	10.9	(19)	
		MCWB	2.4	3.5	6.4	8.1	11.7	12.9	14.5	13.7	13.7	9.6	5.5	2.8	(20)	
	2%	DB	6.2	8.2	15.9	19.9	26.2	30.2	32.6	31.0	28.0	22.1	13.7	6.6	(21)	
		MCWB	1.3	2.0	5.2	7.3	10.5	12.2	14.2	13.4	12.2	8.9	4.7	1.4	(22)	
	5%	DB	3.8	6.4	13.0	18.0	23.9	28.6	31.4	29.1	26.2	19.0	11.3	3.9	(23)	
		MCWB	-0.1	1.0	4.1	6.2	9.4	11.8	13.7	13.1	11.4	7.6	3.8	0.0	(24)	
	10%	DB	2.3	4.1	11.1	16.3	22.3	27.3	30.0	27.7	24.0	17.1	8.0	2.1	(25)	
		MCWB	-0.7	0.1	3.2	5.6	8.9	11.4	13.4	13.0	10.8	6.8	2.5	-1.0	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.4	4.0	7.3	8.7	12.8	14.4	16.3	15.9	14.3	11.5	6.5	3.3	(27)	
		MCDB	6.8	9.8	17.1	19.1	27.2	25.5	27.8	25.9	26.4	18.3	14.3	8.7	(28)	
	2%	WB	1.8	2.5	5.7	7.7	11.2	13.4	15.6	15.2	13.5	9.7	5.2	1.7	(29)	
		MCDB	5.1	7.4	14.2	17.9	23.7	25.7	26.9	25.4	24.5	19.4	12.2	6.2	(30)	
	5%	WB	0.6	1.6	4.5	6.8	10.2	12.7	15.1	14.6	12.7	8.5	4.0	0.3	(31)	
		MCDB	3.6	5.8	12.3	16.5	22.0	25.5	26.2	24.8	22.8	17.2	10.3	3.6	(32)	
	10%	WB	-0.6	0.6	3.4	6.0	9.4	11.9	14.5	14.0	11.8	7.4	2.9	-0.9	(33)	
		MCDB	1.9	4.0	10.2	15.0	20.7	24.5	25.4	24.1	21.2	15.9	7.8	1.7	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	12.7	12.4	13.7	14.7	17.0	19.1	19.2	17.9	18.1	17.1	13.7	13.0	(35)	
		MCDBR	13.3	14.0	18.6	20.0	21.5	22.2	21.6	21.1	21.7	22.4	18.6	13.8	(36)	
	5% WB	MCWBR	9.1	8.8	9.8	9.6	9.4	9.2	8.3	8.3	9.3	11.5	10.6	9.3	(37)	
		MCWBR	11.9	12.3	17.2	18.1	19.4	19.3	17.3	16.3	17.8	19.0	16.8	12.8	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.234	0.246	0.275	0.306	0.319	0.321	0.354	0.352	0.300	0.278	0.249	0.237	(40)	
		taud	2.434	2.389	2.429	2.431	2.478	2.473	2.428	2.416	2.572	2.602	2.577	2.473	(41)	
	Ebn at Noon		961	991	989	971	958	951	916	911	949	945	941	932	(42)	
		Edh at Noon	78	95	103	111	108	109	113	112	89	77	68	70	(43)	
(44) All-Sky Solar Radiation	RadAvg		2.53	3.41	4.85	5.67	6.23	7.49	6.74	5.83	5.16	3.73	2.61	2.07	(44)	
	RadStd		0.13	0.22	0.39	0.41	0.48	0.47	0.35	0.29	0.34	0.32	0.26	0.18	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (28 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page