

ASPEN PITKIN COUNTY AP, CO, USA

WMO: 724676

Lat: 39.230N

Lon: 106.871W

Elev: 7720

StdP: 11.03

Time Zone: -7.00 (NAM)

Period: 98-19

WBAN: 93073

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.2	0.6	-10.0	4.3	-2.1	-6.3	5.2	4.7	18.1	30.2	15.4	30.6	4.9	200	0.635

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	30.6	84.2	54.1	82.0	53.7	79.9	53.2	58.2	73.9	57.1	72.8	56.0	71.5	8.9	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
54.3	83.8	60.0	52.4	78.3	59.5	50.6	73.1	59.6	28.5	74.1	27.7	72.7	26.9	71.5	64.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	18.3	16.0	12.9	DB	-12.1	87.8	4.9	2.2	-15.6	89.4	-18.5	90.7	-21.2	91.9	-24.8	93.6
(5)				WB	-12.7	60.9	4.8	1.6	-16.1	62.1	-18.9	63.0	-21.6	63.9	-25.1	65.1

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	42.2	21.0	24.1	33.0	40.6	48.8	58.9	65.0	62.2	55.5	43.5	31.9	21.1	(6)
(7)		DBStd	16.98	8.10	8.30	8.14	7.30	7.25	6.04	3.59	3.62	6.01	7.50	9.24	8.79	(7)
(8)		HDD50	4237	898	725	528	287	108	9	0	0	22	220	544	896	(8)
(9)		HDD65	8383	1363	1145	993	732	503	193	45	100	287	667	994	1361	(9)
(10)		CDD50	1400	0	0	0	5	71	277	464	378	187	18	0	0	(10)
(11)		CDD65	69	0	0	0	0	0	10	44	13	2	0	0	0	(11)
(12)		CDH74	2339	0	0	0	0	35	544	1079	540	140	1	0	0	(12)
(13)		CDH80	453	0	0	0	0	3	94	265	77	14	0	0	0	(13)
(14)	Wind	WSAvg	6.0	4.8	5.3	6.1	6.9	7.0	7.1	6.4	6.3	6.5	5.9	5.3	4.7	(14)
(15)	Precipitation	PrecAvg	23.6	2.1	2.2	2.1	2.5	1.9	1.0	2.1	2.0	2.1	1.9	1.9	2.3	(15)
(16)		PrecMax	28.9	4.4	4.6	4.5	4.7	5.1	2.0	3.7	3.4	4.1	3.7	2.8	4.6	(16)
(17)		PrecMin	18.2	1.0	1.0	0.7	1.4	0.6	0.2	0.5	0.7	0.9	0.8	0.4	0.4	(17)
(18)		PrecStd	2.5	0.9	1.0	0.8	0.8	1.0	0.6	0.8	0.7	0.7	0.8	0.6	1.1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	45.9	49.8	63.1	67.9	79.0	86.2	88.3	84.5	82.0	72.0	62.5	48.8	(19)
(20)		MCWB	33.7	35.9	41.3	44.0	51.0	53.6	55.9	54.2	53.6	46.8	41.2	34.6	(20)	
(21)		2%	DB	40.9	45.2	57.2	63.6	72.8	82.4	85.2	82.0	77.9	67.9	57.2	42.7	(21)
(22)		MCWB	31.5	33.1	38.7	41.5	47.7	52.3	54.8	53.7	51.5	45.3	39.2	31.9	(22)	
(23)		5%	DB	37.1	41.8	52.4	61.1	69.9	80.2	82.9	80.2	74.8	64.0	52.5	37.8	(23)
(24)		MCWB	29.9	31.9	36.9	40.4	46.5	51.5	54.4	53.5	49.7	43.5	37.5	30.0	(24)	
(25)		10%	DB	34.2	37.5	47.8	57.2	66.2	77.2	80.8	77.1	72.0	60.6	47.3	34.4	(25)
(26)		MCWB	28.8	30.0	34.8	39.1	45.0	50.2	54.5	53.2	49.0	42.5	35.3	29.0	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	35.9	37.1	42.0	45.4	52.9	57.0	60.3	59.2	56.3	49.9	42.4	36.1	(27)
(28)		MADB	41.5	46.5	60.4	63.8	75.3	78.1	75.3	73.3	72.6	62.6	58.3	45.0	(28)	
(29)		2%	WB	33.2	34.5	39.6	43.0	49.6	54.9	58.8	57.6	54.3	47.3	40.1	33.4	(29)
(30)		MADB	38.6	42.9	54.6	59.9	68.7	75.6	74.7	71.9	69.3	62.5	54.2	39.1	(30)	
(31)		5%	WB	31.2	32.6	37.4	41.5	47.7	53.3	57.6	56.6	52.8	45.4	38.2	31.3	(31)
(32)		MADB	36.2	39.9	50.0	57.3	66.1	74.3	73.9	70.8	67.4	60.4	50.7	37.2	(32)	
(33)		10%	WB	29.1	31.0	35.5	40.1	46.1	51.8	56.7	55.4	51.2	43.6	36.0	29.2	(33)
(34)		MADB	33.8	37.4	46.1	55.1	63.5	72.7	72.8	69.4	65.7	57.6	46.2	34.5	(34)	
(35)	Mean Daily Temperature Range	MDBR	22.5	22.4	23.2	24.1	26.7	31.5	30.6	28.9	29.3	27.0	24.3	21.8	(35)	
(36)		5% DB	MCDDBR	25.1	25.8	29.2	31.2	32.4	35.0	34.4	33.4	33.8	33.9	31.6	24.5	(36)
(37)		MCWBR	17.6	16.4	14.9	14.5	13.8	13.9	12.4	12.3	13.5	16.3	16.9	16.3	(37)	
(38)		5% WB	MCDDBR	21.5	22.7	26.6	28.2	30.2	32.2	29.0	26.6	27.2	29.3	29.2	21.6	(38)
(39)		MCWBR	15.2	14.6	14.1	13.8	13.5	13.2	11.1	10.6	11.4	14.3	16.0	14.5	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.222	0.229	0.257	0.290	0.299	0.300	0.331	0.333	0.287	0.267	0.236	0.223	(40)	
(41)		taud	2.438	2.404	2.393	2.422	2.512	2.522	2.484	2.451	2.603	2.617	2.585	2.475	(41)	
(42)		Ebn at Noon	312	323	320	313	310	309	298	295	306	305	305	304	(42)	
(43)		Edh at Noon	25	30	34	36	33	33	34	34	28	24	22	22	(43)	
(44)	All-Sky Solar Radiation	RadAvg	830	1111	1569	1834	2006	2374	2108	1845	1649	1217	865	690	(44)	
(45)		RadStd	44	69	123	124	154	151	115	91	106	102	75	56	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (29 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page