

ASPEN PITKIN COUNTY AP, CO, USA

WMO: 724676

Lat: 39.230N

Lon: 106.871W

Elev: 2353

StdP: 76.07

Time Zone: -7.00 (NAM)

Period: 98-19

WBAN: 93073

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-20.1	-17.4	-23.3	0.6	-18.9	-21.3	0.7	-15.1	8.1	-1.0	6.9	-0.8	2.2	200	0.635

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.0	29.0	12.3	27.8	12.0	26.6	11.8	14.6	23.3	13.9	22.7	13.3	22.0	4.0	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.4	12.0	15.6	11.4	11.2	15.3	10.3	10.4	15.3	48.4	23.4	46.5	22.6	44.6	21.9	18.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.2	7.1	5.8	DB	-24.5	31.0	2.7	1.2	-26.5	31.9	-28.1	32.6	-29.6	33.3	-31.6	34.2	(4)
(5)			WB	-24.8	16.1	2.7	0.9	-26.7	16.7	-28.3	17.2	-29.8	17.7	-31.7	18.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	5.7	-6.1	-4.4	0.5	4.8	9.3	15.0	18.3	16.8	13.1	6.4	-0.1	-6.1	(6)	
	DBStd	9.43	4.50	4.61	4.52	4.05	4.03	3.36	2.00	2.01	3.34	4.16	5.13	4.88	(7)	
	HDD10.0	2354	499	403	293	159	60	5	0	0	12	122	302	498	(8)	
	HDD18.3	4657	757	636	552	407	279	107	25	56	159	371	552	756	(9)	
	CDD10.0	778	0	0	0	3	39	154	258	210	104	10	0	0	(10)	
	CDD18.3	38	0	0	0	0	6	24	7	1	0	0	0	0	(11)	
	CDH23.3	1299	0	0	0	0	19	302	599	300	78	1	0	0	(12)	
	CDH26.7	252	0	0	0	0	2	52	147	43	8	0	0	0	(13)	
(14) Wind	WSAvg	2.7	2.1	2.4	2.7	3.1	3.1	3.2	2.9	2.8	2.9	2.6	2.3	2.1	(14)	
(15) Precipitation	PrecAvg	600	54	57	53	64	49	26	53	52	54	47	48	58	(15)	
	PrecMax	733	111	118	115	120	130	51	93	86	105	93	70	117	(16)	
	PrecMin	462	25	26	19	35	14	4	13	19	22	20	10	10	(17)	
	PrecStd	63	24	25	20	20	26	14	20	17	19	20	15	27	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.7	9.9	17.3	20.0	26.1	30.1	31.3	29.2	27.8	22.2	16.9	9.3	(19)	
		MCWB	1.0	2.1	5.2	6.6	10.5	12.0	13.3	12.3	12.0	8.2	5.1	1.5	(20)	
	2%	DB	5.0	7.4	14.0	17.6	22.7	28.0	29.6	27.8	25.5	20.0	14.0	5.9	(21)	
		MCWB	-0.3	0.6	3.7	5.3	8.7	11.3	12.7	12.0	10.8	7.4	4.0	-0.1	(22)	
	5%	DB	2.8	5.4	11.3	16.2	21.1	26.8	28.3	26.8	23.8	17.8	11.4	3.2	(23)	
		MCWB	-1.2	0.0	2.7	4.7	8.0	10.8	12.4	11.9	9.8	6.4	3.1	-1.1	(24)	
	10%	DB	1.2	3.1	8.8	14.0	19.0	25.1	27.1	25.1	22.2	15.9	8.5	1.3	(25)	
		MCWB	-1.8	-1.1	1.6	4.0	7.2	10.1	12.5	11.8	9.5	5.8	1.8	-1.7	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.2	2.9	5.6	7.4	11.6	13.9	15.7	15.1	13.5	10.0	5.8	2.3	(27)	
		MCDB	5.3	8.0	15.8	17.7	24.1	25.6	24.0	22.9	22.6	17.0	14.6	7.2	(28)	
	2%	WB	0.7	1.4	4.2	6.1	9.8	12.7	14.9	14.2	12.4	8.5	4.5	0.8	(29)	
		MCDB	3.7	6.0	12.5	15.5	20.4	24.2	23.7	22.2	20.7	17.0	12.4	4.0	(30)	
	5%	WB	-0.5	0.3	3.0	5.3	8.7	11.8	14.2	13.7	11.5	7.4	3.4	-0.4	(31)	
		MCDB	2.3	4.4	10.0	14.0	19.0	23.5	23.3	21.5	19.7	15.8	10.4	2.9	(32)	
	10%	WB	-1.6	-0.6	1.9	4.5	7.8	11.0	13.7	13.0	10.6	6.4	2.2	-1.6	(33)	
		MCDB	1.0	3.0	7.8	12.9	17.5	22.6	22.7	20.8	18.7	14.2	7.9	1.4	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	12.5	12.4	12.9	13.4	14.8	17.5	17.0	16.1	16.3	15.0	13.5	12.1	(35)	
		MCDBR	14.0	14.3	16.2	17.4	18.0	19.4	19.1	18.6	18.8	18.8	17.5	13.6	(36)	
	5% WB	MCWBR	9.8	9.1	8.3	8.1	7.7	7.7	6.9	6.8	7.5	9.1	9.4	9.0	(37)	
		MCWBR	12.0	12.6	14.8	15.7	16.8	17.9	16.1	14.8	15.1	16.3	16.2	12.0	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.222	0.229	0.257	0.290	0.299	0.300	0.331	0.333	0.287	0.267	0.236	0.223	(40)	
		taud	2.438	2.404	2.393	2.422	2.512	2.522	2.484	2.451	2.603	2.617	2.585	2.475	(41)	
	Ebn at Noon		983	1017	1010	988	978	973	940	931	966	961	963	958	(42)	
		Edh at Noon	78	94	107	112	105	104	107	108	87	76	68	70	(43)	
(44) All-Sky Solar Radiation	RadAvg		2.62	3.50	4.95	5.78	6.33	7.48	6.64	5.82	5.20	3.84	2.73	2.18	(44)	
	RadStd		0.14	0.22	0.39	0.39	0.49	0.47	0.36	0.29	0.34	0.32	0.24	0.18	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (29 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page