

CARBON COUNTY REGIONAL, UT, USA

WMO: 724700

Lat: 39.609N

Lon: 110.755W

Elev: 1805

StdP: 81.44

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 93141

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.9	-12.5	-21.4	0.7	-8.5	-19.2	0.9	-6.4	10.2	0.1	9.0	-1.0	1.7	10	0.562

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.5	34.2	14.6	33.0	14.2	31.8	14.0	17.0	27.7	16.4	27.3	15.7	26.7	4.6	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
14.1	12.5	19.1	12.8	11.5	19.4	11.7	10.7	19.9	54.6	27.7	52.4	27.3	50.2	26.6	24.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)		
9.9	8.5	7.5	-17.9	37.0	2.5	2.2	-19.7	38.6	-21.2	39.9	-22.5	41.1	-24.3	42.7		
			-18.5	18.9	2.4	2.0	-20.2	20.3	-21.6	21.5	-22.9	22.6	-24.7	24.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	9.9	-3.2	-0.4	5.1	8.8	13.9	20.2	24.1	22.3	17.6	10.0	2.9	-3.0
	DBStd	10.16	4.27	4.23	4.02	4.02	4.40	3.93	2.48	2.40	3.67	4.02	4.31	4.21
	HDD10.0	1613	408	291	159	70	16	1	0	0	2	48	215	404
	HDD18.3	3503	666	524	411	287	147	26	1	2	53	258	464	663
	CDD10.0	1583	0	0	6	33	137	308	438	381	231	49	1	0
	CDD18.3	432	0	0	0	0	10	83	181	125	32	1	0	0
	CDH23.3	5668	0	0	0	11	224	1272	2201	1449	493	18	0	0
	CDH26.7	2436	0	0	0	1	52	552	1083	611	134	2	0	0
Wind	WSAvg	3.0	2.2	2.6	3.4	3.8	3.6	3.5	3.1	2.9	3.0	2.9	2.7	2.3
Precipitation	PrecAvg	315	26	27	26	26	29	18	22	36	37	32	19	26
	PrecMax	396	66	68	61	64	76	47	47	84	95	93	47	63
	PrecMin	221	0	0	0	4	3	3	4	8	4	0	0	3
	PrecStd	47	20	18	15	16	18	13	11	17	25	23	11	16
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.4	14.1	21.2	24.8	30.9	35.2	36.3	34.6	31.8	25.9	17.1	10.1
		MCWB	2.8	4.8	7.7	9.4	13.9	14.2	15.7	14.8	13.6	10.9	6.9	3.4
	2%	DB	7.2	11.1	17.9	22.2	27.9	33.5	34.9	33.0	29.8	22.4	14.9	7.4
		MCWB	1.9	3.6	6.4	8.4	11.7	13.7	14.9	14.3	12.8	9.7	5.9	1.8
	5%	DB	5.2	8.5	15.7	20.1	26.0	32.0	33.6	32.0	28.1	20.0	12.7	5.3
		MCWB	0.1	2.5	5.5	7.6	10.5	13.3	14.7	14.1	12.2	8.5	4.8	0.7
	10%	DB	3.1	6.2	12.9	17.7	23.6	30.1	32.3	30.4	26.6	17.8	10.2	3.3
		MCWB	-0.6	1.3	4.4	6.6	9.8	12.5	14.4	13.9	11.7	7.7	3.6	-0.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.0	5.6	8.4	10.3	14.9	16.6	18.5	17.8	15.9	12.8	8.2	4.5
		MCDB	7.8	12.2	19.0	22.3	29.6	32.0	30.0	27.9	23.6	19.8	15.5	8.1
	2%	WB	2.4	4.2	7.0	9.1	12.6	15.2	17.4	16.9	14.8	11.0	6.6	2.8
		MCDB	5.6	9.6	16.5	20.2	25.1	29.2	28.2	26.7	23.7	18.7	13.0	5.9
	5%	WB	1.1	3.0	5.9	8.0	11.3	14.2	16.6	16.3	13.9	10.0	5.3	1.3
		MCDB	4.2	7.2	14.3	18.2	23.4	28.0	27.9	26.2	23.7	17.5	11.8	4.8
	10%	WB	0.0	1.9	4.8	7.1	10.4	13.3	16.0	15.6	13.0	8.8	4.1	0.0
		MCDB	2.8	5.5	12.3	16.6	22.0	27.2	27.5	25.5	22.9	16.3	9.6	3.2
Mean Daily Temperature Range	5% DB	MDBR	10.3	10.5	12.5	13.8	14.4	16.2	15.5	15.0	14.9	12.9	11.6	10.0
		MCDBR	12.0	13.2	16.0	17.3	17.7	18.5	17.2	17.2	17.2	15.6	14.2	12.0
		MCWBR	7.8	7.6	8.0	8.2	7.7	7.9	6.8	6.8	7.3	7.5	7.8	7.7
	5% WB	MCDBR	10.4	11.3	14.7	15.8	16.0	16.4	14.3	13.8	13.7	12.9	12.9	10.7
		MCWBR	7.0	6.9	7.6	7.8	7.2	7.6	5.9	5.7	6.2	6.3	7.5	7.2
Clear-Sky Solar Irradiance	taub	0.241	0.253	0.267	0.300	0.304	0.307	0.347	0.345	0.299	0.279	0.250	0.244	
	taud	2.512	2.525	2.534	2.440	2.492	2.503	2.421	2.428	2.552	2.572	2.593	2.541	
	Ebn at Noon	956	988	1001	976	973	965	923	918	951	943	940	928	
	Edh at Noon	73	84	93	110	107	106	114	110	91	79	67	66	
All-Sky Solar Radiation	RadAvg	2.48	3.35	4.80	5.97	6.86	7.85	7.10	6.26	5.48	4.00	2.80	2.12	
	RadStd	0.20	0.31	0.32	0.32	0.47	0.55	0.38	0.32	0.33	0.33	0.20	0.18	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+89
(47)	Regional (11 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page