

BLANDING, UT, USA

WMO: 724723

Lat: 37.583N

Lon: 109.483W

Elev: 1789

StdP: 81.60

Time Zone: -7.00 (NAM)

Period: 83-19

WBAN: 93025

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.8	-9.6	-19.0	0.9	0.7	-17.1	1.0	0.0	9.4	-0.7	8.2	0.5	2.4	350	0.527

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.9	33.8	14.6	32.7	14.3	31.5	14.1	17.3	27.0	16.6	26.6	16.0	26.1	4.0	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.9	13.2	18.8	13.8	12.3	18.8	12.8	11.5	19.5	55.4	26.8	53.4	26.7	51.6	25.9	20.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
10.0	8.3	7.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	11.3	-1.3	2.1	6.4	10.1	14.4	21.9	23.6	23.1	18.0	11.7	4.8	-0.1
	DBStd	9.42	3.85	4.44	4.14	3.87	4.13	3.24	2.44	2.15	4.02	3.81	4.10	3.62
	HDD10.0	1253	349	222	125	46	12	0	0	0	2	25	158	314
	HDD18.3	3055	607	455	369	246	131	9	1	1	53	207	404	572
	CDD10.0	1721	0	1	14	50	148	358	421	405	243	77	4	0
	CDD18.3	482	0	0	0	0	9	117	163	148	44	1	0	0
	CDH23.3	5484	0	0	0	6	163	1531	1853	1444	466	22	0	0
	CDH26.7	2290	0	0	0	0	29	676	865	586	133	1	0	0
Wind	WSAvg	2.9	2.2	2.8	3.3	3.7	3.6	3.4	2.8	2.9	3.0	2.8	2.7	2.1
Precipitation	PrecAvg	349	37	30	28	22	19	11	32	37	35	39	29	30
	PrecMax	556	135	95	92	74	59	48	88	138	105	184	76	121
	PrecMin	172	0	0	0	0	0	0	0	1	1	0	0	0
	PrecStd	90	36	26	23	18	15	12	24	31	26	34	19	28
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.1	15.6	21.8	24.3	29.7	35.4	35.3	34.1	32.5	25.7	18.0	11.4
		MCWB	3.9	6.4	8.4	9.5	11.2	14.4	15.3	14.3	14.1	11.3	7.9	4.1
	2%	DB	8.4	13.0	18.9	22.3	27.2	33.5	34.0	32.9	30.0	22.9	16.3	9.1
		MCWB	2.7	5.1	7.2	8.8	10.8	13.8	15.2	14.4	13.3	10.3	7.1	3.1
	5%	DB	6.3	10.8	16.6	20.4	25.3	32.3	32.9	31.8	27.9	21.1	14.0	7.4
		MCWB	1.7	4.1	5.9	7.9	10.2	13.4	14.8	14.3	13.0	9.4	5.7	2.4
	10%	DB	4.4	8.6	14.3	18.4	23.2	30.6	31.6	30.2	26.1	19.0	12.0	5.6
		MCWB	0.8	3.0	5.1	6.9	9.6	13.0	14.8	14.2	12.7	8.6	4.8	1.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.0	7.5	8.9	11.2	13.7	17.0	18.4	17.9	15.8	13.4	9.0	6.1
		MCDB	9.4	13.4	19.6	21.5	21.6	28.3	25.1	25.8	23.3	17.8	15.5	8.6
	2%	WB	3.5	5.8	7.7	9.6	12.3	15.6	17.5	17.0	15.1	12.0	7.8	4.7
		MCDB	6.8	11.2	17.5	19.7	21.7	28.6	27.9	25.7	23.9	20.1	14.6	7.7
	5%	WB	2.3	4.6	6.6	8.6	11.4	14.7	16.9	16.5	14.5	10.8	6.4	3.4
		MCDB	5.2	9.5	15.1	18.6	21.8	27.9	27.3	25.8	23.9	17.9	13.2	6.1
	10%	WB	1.2	3.6	5.5	7.6	10.4	13.9	16.3	15.8	13.8	9.9	5.2	2.1
		MCDB	3.9	8.0	13.2	16.5	21.4	27.3	26.7	25.2	23.4	16.8	11.3	5.0
Mean Daily Temperature Range	5% DB	MDBR	8.9	10.2	12.0	13.3	13.9	15.9	14.9	14.0	13.3	13.0	11.4	9.1
		MCDBR	10.3	12.7	14.7	15.6	16.3	17.4	16.6	15.9	15.3	15.0	13.3	10.9
		MCWBR	6.3	6.8	7.2	7.1	6.7	6.8	5.6	5.9	6.1	6.9	7.2	6.8
	5% WB	MCDBR	8.7	11.5	13.6	14.7	14.3	15.2	13.8	12.8	13.2	12.4	12.7	9.0
		MCWBR	5.9	6.4	7.0	6.9	6.3	6.2	4.5	4.4	5.4	6.0	7.2	6.0
Clear-Sky Solar Irradiance	taub	0.244	0.257	0.267	0.288	0.299	0.303	0.344	0.343	0.300	0.282	0.251	0.246	
	taud	2.597	2.565	2.552	2.485	2.494	2.470	2.412	2.418	2.544	2.554	2.604	2.593	
	Ebn at Noon	972	993	1007	993	980	971	928	924	955	948	955	946	
	Edh at Noon	70	83	93	106	107	110	116	112	93	83	69	66	
All-Sky Solar Radiation	RadAvg	2.78	3.66	5.25	6.59	7.54	8.36	7.52	6.64	5.76	4.33	3.18	2.38	
	RadStd	0.25	0.29	0.39	0.33	0.45	0.36	0.33	0.25	0.21	0.30	0.20	0.18	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (12 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page