

HANKSVILLE, UT, USAWMO: **724733**Lat: **38.417N**Lon: **110.700W**Elev: **1355**StdP: **86.07**Time Zone: **-7.00 (NAM)**Period: **98-19**WBAN: **23170****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-13.0	-11.2	-18.8	0.8	-3.7	-17.1	1.0	-2.3	11.0	10.7	8.5	7.3	0.1	140	0.491

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.0	39.0	16.7	37.6	16.2	36.3	15.9	19.5	30.0	18.7	30.2	17.9	29.8	3.1	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.0	14.3	22.5	15.9	13.3	22.4	14.0	11.7	22.4	61.7	29.6	58.7	29.9	56.0	29.7	25.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.7	8.8	7.8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	13.0	-0.6	2.9	8.5	12.4	17.3	24.6	27.9	25.5	20.8	12.6	5.1	-1.3
	DBStd	10.54	3.75	4.14	3.90	3.63	3.93	3.57	2.51	2.37	3.75	4.09	4.34	4.01
	HDD10.0	1148	329	199	75	17	2	0	0	0	0	19	157	349
	HDD18.3	2777	587	431	304	178	67	2	0	0	19	182	398	607
	CDD10.0	2253	0	1	28	91	227	439	553	481	324	100	9	0
	CDD18.3	842	0	0	0	2	34	192	295	222	93	4	0	0
	CDH23.3	12451	0	0	19	92	706	3188	4171	2811	1362	101	1	0
	CDH26.7	6867	0	0	1	12	251	1898	2528	1532	628	18	0	0
Wind	WSAvg	2.0	1.2	2.0	2.4	3.1	2.7	2.8	2.0	1.9	2.0	1.7	1.5	1.0
Precipitation	PrecAvg	144	11	7	12	12	12	7	12	18	21	17	11	8
	PrecMax	246	45	22	47	41	79	32	47	60	69	91	68	39
	PrecMin	56	0	0	0	0	0	0	0	0	0	0	0	0
	PrecStd	42	13	5	11	12	13	9	10	15	17	17	12	9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.0	17.9	26.3	28.8	35.0	40.2	41.8	38.9	36.2	28.7	21.4	13.1
		MCWB	6.1	7.4	10.4	11.7	14.8	16.1	18.2	17.0	15.9	13.3	9.6	7.5
	2%	DB	11.0	16.0	22.8	26.2	32.0	38.5	39.9	37.3	33.9	26.2	18.6	11.1
		MCWB	5.3	6.6	9.1	10.4	13.2	15.7	17.6	16.3	15.2	11.8	8.3	5.7
	5%	DB	8.9	13.0	20.5	24.1	29.8	37.3	38.0	35.7	32.4	23.7	17.0	7.9
		MCWB	3.7	5.5	8.3	9.7	12.5	15.4	16.9	16.1	14.6	10.9	7.4	3.1
	10%	DB	7.1	11.2	17.8	22.3	27.6	36.0	37.0	33.9	30.8	21.9	13.9	6.2
		MCWB	2.4	4.8	7.1	9.0	11.7	14.8	16.7	15.8	14.2	10.6	6.0	1.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.2	9.3	11.4	12.7	16.0	17.9	21.4	20.6	18.4	15.2	10.7	8.5
		MCDB	12.0	15.5	22.6	24.1	29.9	34.9	33.3	30.1	26.0	23.6	18.6	12.9
	2%	WB	5.7	7.5	10.0	11.3	14.4	16.7	20.1	19.1	17.3	13.8	9.0	6.0
		MCDB	10.1	14.0	20.9	23.7	27.9	34.6	31.2	28.8	26.3	21.1	16.9	10.3
	5%	WB	4.1	6.5	8.9	10.5	13.1	15.9	19.1	18.4	16.3	12.5	7.9	3.8
		MCDB	8.0	12.4	18.8	22.4	27.3	34.0	30.9	28.3	26.5	19.5	15.0	7.6
	10%	WB	2.7	5.2	7.8	9.6	12.2	15.3	18.4	17.7	15.4	11.5	6.7	1.9
		MCDB	6.1	10.5	16.8	20.6	25.8	32.7	31.2	27.7	26.7	19.2	13.1	5.7
Mean Daily Temperature Range	5% DB	MDBR	13.0	13.7	15.9	15.8	16.4	18.8	17.0	16.7	17.5	15.8	15.0	12.6
		MCDBR	16.6	17.0	20.8	19.7	21.5	22.0	19.8	19.4	20.8	19.2	17.7	14.5
		MCWBR	11.0	9.7	10.2	9.2	8.7	8.8	6.4	6.8	8.0	8.9	10.0	9.9
	5% WB	MCDBR	13.8	15.4	17.8	18.0	19.0	19.6	14.7	14.6	15.4	14.7	14.8	13.5
		MCWBR	9.8	9.5	9.8	8.7	8.0	7.8	5.0	5.2	6.2	7.1	8.6	9.6
Clear-Sky Solar Irradiance	taub	0.254	0.267	0.278	0.317	0.320	0.321	0.369	0.363	0.320	0.293	0.261	0.256	
	taud	2.535	2.505	2.486	2.355	2.399	2.400	2.322	2.347	2.453	2.497	2.544	2.541	
	Ebn at Noon	948	976	991	960	958	953	904	902	929	929	931	921	
	Edh at Noon	74	87	99	120	118	118	126	120	101	87	73	69	
All-Sky Solar Radiation	RadAvg	2.67	3.63	5.16	6.43	7.31	8.18	7.27	6.43	5.70	4.26	3.08	2.33	
	RadStd	0.21	0.29	0.30	0.30	0.41	0.43	0.34	0.31	0.27	0.29	0.20	0.17	