

INVERNESS, FL, USA

WMO: 724737

Lat: 28.804N

Lon: 82.318W

Elev: 50

StdP: 14.67

Time Zone: -5.00 (NAE)

Period: 09-19

WBAN: 00377

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	31.6	35.5	18.9	14.2	42.3	25.4	19.4	44.8	17.6	57.9	16.1	62.2	1.3	0	0.307

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	17.0	95.5	78.0	93.4	77.4	91.3	76.6	82.4	88.4	81.5	87.0	80.8	86.5	4.9	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
81.3	163.1	84.5	80.7	159.7	84.1	79.2	151.8	83.2	46.3	88.7	45.0	88.2	44.2	87.3	86.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
13.4	11.7	10.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			26.1	82.5	3.9	2.9	23.2	84.6	20.9	86.3	18.7	87.9	15.9	90.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	71.2	56.0	61.2	63.9	70.4	75.9	80.5	82.0	82.4	80.6	73.3	65.6	61.6
	DBStd	10.83	9.02	8.78	7.50	4.75	4.40	2.85	3.05	3.06	2.98	6.26	7.12	8.41
	HDD50	79	46	15	4	0	0	0	0	0	0	0	1	13
	HDD65	844	299	161	113	11	2	0	0	0	0	17	79	162
	CDD50	7808	232	327	434	613	804	916	992	1005	919	723	470	373
	CDD65	3098	21	53	78	174	341	466	527	540	469	274	98	57
	CDH74	28934	188	427	732	1803	3398	4446	5109	5250	4199	2241	736	405
	CDH80	11821	14	69	138	582	1485	2010	2368	2369	1817	768	151	50
(14) Wind	WSAvg	3.2	3.6	3.4	3.7	3.8	3.3	2.7	2.0	2.5	2.8	3.5	3.7	3.4
(15) Precipitation	PrecAvg	53.5	3.3	3.3	4.2	2.2	3.2	7.9	7.8	8.3	6.4	2.5	2.0	2.6
	PrecMax	87.3	9.6	6.6	16.0	5.9	12.0	21.9	14.7	16.2	16.3	9.1	7.7	10.5
	PrecMin	35.7	0.3	0.5	0.0	0.0	0.2	1.7	3.7	1.8	0.7	0.0	0.0	0.1
	PrecStd	9.3	1.8	1.7	3.2	1.6	2.5	4.0	2.7	3.3	3.9	2.0	1.7	2.1
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	81.7	85.7	86.1	91.0	94.9	99.0	99.0	98.6	95.3	91.3	88.0	83.7
		MCWB	68.6	70.6	66.3	71.6	73.2	76.9	78.8	79.9	77.1	76.1	75.0	71.9
	2%	DB	79.2	81.9	83.7	88.3	91.3	94.7	95.4	95.1	93.2	89.6	83.9	81.4
		MCWB	67.5	69.2	66.9	70.3	72.3	76.7	78.9	80.1	77.1	74.5	71.5	70.8
	5%	DB	75.4	79.4	81.4	86.1	90.2	91.1	93.0	91.5	91.0	87.5	81.3	79.1
		MCWB	65.9	67.8	66.5	69.2	71.9	76.2	78.7	78.5	76.5	73.0	69.3	69.2
	10%	DB	71.9	76.7	78.9	82.4	88.1	90.0	90.4	90.4	89.9	84.3	78.9	75.2
		MCWB	64.2	65.9	65.3	67.6	71.4	76.3	78.2	78.4	76.1	71.7	68.1	67.8
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	72.3	73.9	73.2	75.9	79.1	82.2	83.2	84.4	82.2	79.8	77.3	75.0
		MCDB	78.6	80.4	78.8	83.6	83.9	87.0	89.2	90.5	87.4	84.9	83.2	81.1
	2%	WB	69.5	72.0	71.4	74.2	77.3	81.0	82.1	83.0	81.0	78.0	74.8	73.2
		MCDB	74.9	78.4	77.7	82.5	83.9	86.0	87.8	89.6	86.7	84.0	80.9	78.2
	5%	WB	67.7	70.2	69.5	72.6	76.0	79.9	81.2	81.8	79.7	76.6	72.4	71.7
		MCDB	72.9	76.3	76.1	80.7	83.7	86.0	87.0	87.8	85.7	83.1	77.7	76.4
	10%	WB	65.4	68.4	67.8	70.7	74.6	78.8	80.4	81.0	78.4	75.1	70.4	69.9
		MCDB	71.9	74.0	74.5	78.5	82.4	85.3	86.6	86.5	84.5	81.5	75.2	73.9
(35) Mean Daily Temperature Range	5% DB	MDBR	24.1	23.8	25.1	25.1	23.0	18.5	17.9	17.0	17.9	21.5	23.0	23.1
		MCDBR	26.0	24.7	26.4	27.7	26.2	21.3	20.3	18.6	19.9	21.7	23.3	23.8
		MCWBR	15.0	13.1	12.1	10.8	8.8	7.5	6.8	6.9	6.7	8.7	11.7	13.5
	5% WB	MCDBR	22.1	21.2	21.8	23.0	19.5	17.9	17.7	16.6	16.8	17.1	18.8	21.2
		MCWBR	14.6	12.3	11.9	11.5	8.7	8.3	8.2	7.6	7.1	7.8	11.1	14.1
(40) Clear-Sky Solar Irradiance	taub		0.340	0.352	0.367	0.389	0.426	0.457	0.486	0.467	0.421	0.391	0.353	0.340
	taud		2.511	2.483	2.434	2.351	2.300	2.288	2.208	2.275	2.385	2.440	2.492	2.533
	Ebn at Noon		286	291	292	288	276	266	258	262	272	274	278	280
	Edh at Noon		29	32	36	40	42	43	46	43	37	33	29	27
(44) All-Sky Solar Radiation	RadAvg		1081	1290	1651	1983	2096	1874	1784	1721	1570	1438	1176	992
	RadStd		75	98	140	115	130	145	117	112	108	99	65	83

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (42 neighbors)	+0.77	N/A	N/A	N/A	N/A	N/A	N/A	-11	-94	+286	+207

Nomenclature: See separate page