

MILFORD, UT, USA

WMO: 724750

Lat: 38.417N

Lon: 113.017W

Elev: 5040

StdP: 12.21

Time Zone: -7.00 (NAM)

Period: 97-19

WBAN: 23176

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-1.3	4.7	-7.8	4.4	6.5	-1.5	6.1	14.8	30.8	41.6	27.1	38.9	4.5	190	0.686

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	33.2	97.6	60.4	95.2	59.4	92.8	58.8	64.6	84.4	63.4	83.8	62.2	83.5	13.6	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
59.7	92.4	69.3	57.1	83.9	68.8	54.8	77.2	69.5	32.2	84.2	31.2	83.1	30.3	82.8	76.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 31.0	26.5	23.6	-9.4	101.9	7.7	1.8	-15.0	103.2	-19.5	104.3	-23.8	105.4	-29.4	106.7		
(5)			-9.9	67.0	7.6	2.4	-15.4	68.8	-19.8	70.2	-24.1	71.5	-29.6	73.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	51.3	28.8	33.6	42.2	48.3	57.7	69.1	77.0	74.5	65.0	51.0	38.9	28.4	
	DBStd	18.45	10.31	9.33	7.49	7.34	7.85	6.90	4.21	4.08	6.83	8.01	8.85	10.33	
	HDD50	2615	658	461	257	117	24	1	0	0	4	84	339	670	
	HDD65	5934	1123	880	706	501	246	41	0	1	81	437	783	1135	
	CDD50	3089	0	1	16	66	263	575	836	758	452	115	7	0	
	CDD65	933	0	0	0	0	21	165	371	294	79	3	0	0	
	CDH74	15319	0	0	8	57	787	3316	5310	4085	1602	154	0	0	
	CDH80	7830	0	0	0	5	254	1719	3052	2151	624	25	0	0	
Wind	WSAvg	10.5	9.2	10.0	11.0	11.8	11.1	11.9	11.1	11.0	10.1	9.8	9.6	9.6	
Precipitation	PrecAvg	9.7	0.6	0.7	1.1	1.0	0.7	0.5	0.7	0.9	1.0	0.8	0.8	0.7	
	PrecMax	13.9	1.9	1.7	2.0	2.3	2.2	2.4	1.8	3.7	3.6	2.6	2.2	2.4	
	PrecMin	6.4	0.0	0.0	0.0	0.2	0.0	0.0	0.0	0.1	0.0	0.0	0.1	0.0	
	PrecStd	2.2	0.5	0.4	0.5	0.6	0.6	0.6	0.6	0.8	0.9	0.6	0.5	0.6	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	56.8	63.8	74.4	79.5	91.0	99.5	101.7	98.0	92.8	82.8	71.1	57.4	
		MCWB	41.5	43.4	48.7	50.7	57.0	59.7	62.0	61.1	58.9	53.9	47.7	42.7	
	2%	DB	51.7	57.9	68.9	74.9	86.2	95.4	98.9	95.3	89.6	78.7	65.6	52.3	
		MCWB	40.3	42.3	46.3	49.0	54.1	57.5	61.2	60.0	56.8	52.5	45.6	40.9	
	5%	DB	46.4	52.6	64.2	71.7	82.2	92.8	96.7	93.0	87.0	74.0	60.9	47.7	
		MCWB	38.0	40.6	44.3	48.1	52.9	56.5	60.4	59.8	56.3	50.5	43.8	38.4	
	10%	DB	43.0	47.8	60.6	67.0	78.7	90.2	93.5	90.9	83.7	70.0	55.3	43.5	
		MCWB	36.1	38.6	42.8	46.4	51.3	55.6	59.6	59.3	55.7	49.2	41.7	36.0	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	44.5	46.4	50.0	53.3	58.8	62.0	67.1	68.3	63.7	57.4	49.8	45.0
			MCDB	51.8	58.4	71.5	75.0	87.7	93.0	87.0	88.0	77.6	75.9	65.3	54.2
2%		WB	41.6	43.7	47.3	50.8	55.7	59.8	65.1	64.4	61.4	54.5	47.0	42.2	
		MCDB	48.4	54.6	66.4	70.8	81.3	90.0	85.5	84.1	79.4	72.9	62.6	50.3	
5%		WB	39.1	41.4	45.2	49.0	54.0	58.1	64.0	63.1	59.7	52.3	44.7	39.1	
		MCDB	45.7	51.2	62.4	68.0	78.3	87.3	84.4	83.8	76.8	70.3	58.6	46.6	
10%		WB	36.6	39.1	43.3	47.2	52.4	56.7	62.8	62.0	57.9	50.1	42.3	36.3	
		MCDB	42.3	47.2	58.8	65.5	75.3	85.3	83.9	82.9	76.5	66.5	54.4	42.9	
Mean Daily Temperature Range		5% DB	MDBR	21.5	22.4	28.2	29.1	32.2	35.6	33.2	32.3	33.2	31.1	27.6	22.3
			MCDBR	25.6	29.3	36.4	37.5	39.2	40.2	37.1	35.4	37.4	38.1	35.8	26.6
	MCWBR		16.4	16.6	18.7	17.9	16.5	16.5	13.5	12.9	15.2	18.6	20.0	16.6	
	5% WB	MCDBR	22.2	25.1	33.6	34.0	35.9	36.5	29.7	29.8	28.8	32.5	32.4	24.5	
		MCWBR	14.6	14.8	17.6	16.6	15.3	15.0	9.9	10.5	11.6	15.8	18.7	15.8	
Clear-Sky Solar Irradiance	taub	0.246	0.259	0.271	0.299	0.312	0.306	0.345	0.339	0.299	0.277	0.253	0.246		
	taud	2.611	2.573	2.563	2.463	2.472	2.503	2.439	2.448	2.555	2.588	2.618	2.608		
	Ebn at Noon	306	313	317	311	307	307	294	294	303	302	300	298		
	Edh at Noon	22	26	29	34	35	34	36	35	29	25	21	20		
All-Sky Solar Radiation	RadAvg	838	1109	1555	1957	2243	2563	2213	2039	1801	1321	933	714		
	RadStd	69	97	95	104	180	177	130	132	110	106	59	57		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+113
Regional (7 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page