

MILFORD, UT, USA

WMO: 724750

Lat: 38.417N

Lon: 113.017W

Elev: 1536

StdP: 84.18

Time Zone: -7.00 (NAM)

Period: 97-19

WBAN: 23176

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-18.5	-15.2	-22.1	0.6	-14.2	-18.6	0.9	-9.6	13.8	5.3	12.1	3.9	2.0	190	0.686

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.4	36.4	15.8	35.1	15.2	33.8	14.9	18.1	29.1	17.4	28.8	16.8	28.6	6.1	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
15.4	13.2	20.7	13.9	12.0	20.4	12.7	11.0	20.8	57.1	29.0	54.7	28.4	52.5	28.2	24.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.9	11.8	10.5	-23.0	38.8	4.3	1.0	-26.1	39.6	-28.6	40.2	-31.0	40.8	-34.1	41.5		
(5)			-23.3	19.5	4.2	1.3	-26.3	20.4	-28.8	21.2	-31.2	22.0	-34.2	22.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.7	-1.8	0.9	5.7	9.1	14.3	20.6	25.0	23.6	18.3	10.6	3.8	-2.0		
	DBStd	10.25	5.73	5.18	4.16	4.08	4.36	3.83	2.34	2.27	3.80	4.45	4.92	5.74		
	HDD10.0	1453	366	256	143	65	13	1	0	0	2	47	188	372		
	HDD18.3	3297	624	489	392	278	137	23	0	1	45	243	435	631		
	CDD10.0	1716	0	1	9	37	146	319	464	421	251	64	4	0		
	CDD18.3	518	0	0	0	0	12	92	206	163	44	2	0	0		
	CDH23.3	8511	0	0	4	32	437	1842	2950	2269	890	86	0	0		
	CDH26.7	4350	0	0	0	3	141	955	1696	1195	347	14	0	0		
(14) Wind	WSAvg	4.7	4.1	4.5	4.9	5.3	5.0	5.3	5.0	4.9	4.5	4.4	4.3	4.3		
(15) Precipitation	PrecAvg	247	16	17	29	26	19	12	19	24	25	21	20	17		
	PrecMax	354	47	42	51	58	57	62	45	95	92	66	56	62		
	PrecMin	163	1	0	0	4	0	0	1	2	0	1	3	0		
	PrecStd	56	12	11	12	14	15	14	15	20	22	16	13	15		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.8	17.7	23.5	26.4	32.8	37.5	38.7	36.7	33.8	28.2	21.7	14.1		
		MCWB	5.3	6.3	9.3	10.4	13.9	15.4	16.7	16.2	15.0	12.2	8.7	6.0		
	2%	DB	11.0	14.4	20.5	23.8	30.1	35.2	37.2	35.2	32.0	26.0	18.7	11.3		
		MCWB	4.6	5.7	7.9	9.5	12.3	14.2	16.2	15.5	13.8	11.4	7.6	5.0		
	5%	DB	8.0	11.5	17.9	22.1	27.9	33.8	36.0	33.9	30.5	23.4	16.1	8.7		
		MCWB	3.4	4.8	6.9	8.9	11.6	13.6	15.8	15.4	13.5	10.3	6.6	3.6		
	10%	DB	6.1	8.8	15.9	19.5	25.9	32.3	34.2	32.7	28.7	21.1	12.9	6.4		
		MCWB	2.3	3.7	6.0	8.0	10.7	13.1	15.4	15.1	13.2	9.6	5.4	2.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.9	8.0	10.0	11.8	14.9	16.7	19.5	20.2	17.6	14.1	9.9	7.2		
		MCDB	11.0	14.7	21.9	23.9	31.0	33.9	30.5	31.1	25.3	24.4	18.5	12.3		
	2%	WB	5.3	6.5	8.5	10.4	13.2	15.4	18.4	18.0	16.3	12.5	8.3	5.7		
		MCDB	9.1	12.5	19.1	21.6	27.4	32.2	29.7	28.9	26.4	22.7	17.0	10.1		
	5%	WB	3.9	5.2	7.3	9.5	12.2	14.5	17.8	17.3	15.4	11.3	7.0	4.0		
		MCDB	7.6	10.7	16.9	20.0	25.7	30.7	29.1	28.8	24.9	21.3	14.8	8.1		
	10%	WB	2.5	3.9	6.3	8.4	11.3	13.7	17.1	16.6	14.4	10.1	5.7	2.4		
		MCDB	5.7	8.5	14.9	18.6	24.1	29.6	28.8	28.3	24.7	19.2	12.5	6.0		
(35) Mean Daily Temperature Range	5% DB	MDBR	11.9	12.5	15.6	16.2	17.9	19.8	18.4	18.0	18.5	17.3	15.3	12.4		
		MCDBR	14.2	16.3	20.2	20.8	21.8	22.3	20.6	19.7	20.8	21.2	19.9	14.8		
	5% WB	MCWBR	9.1	9.2	10.4	10.0	9.1	9.2	7.5	7.1	8.5	10.3	11.1	9.2		
		MCWBR	12.3	13.9	18.6	18.9	19.9	20.3	16.5	16.5	16.0	18.0	18.0	13.6		
(40) Clear-Sky Solar Irradiance	taub		0.246	0.259	0.271	0.299	0.312	0.306	0.345	0.339	0.299	0.277	0.253	0.246		
	taud		2.611	2.573	2.563	2.463	2.472	2.503	2.439	2.448	2.555	2.588	2.618	2.608		
	Ebn at Noon		965	988	1000	980	967	967	926	927	955	952	947	941		
	Edh at Noon		69	82	92	108	109	106	112	109	92	79	67	64		
(44) All-Sky Solar Radiation	RadAvg		2.64	3.50	4.90	6.17	7.07	8.08	6.98	6.43	5.68	4.16	2.94	2.25		
	RadStd		0.22	0.31	0.30	0.33	0.57	0.56	0.41	0.42	0.35	0.33	0.18	0.18		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+63
(47) Regional (7 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page