

ST GEORGE, UT, USA

WMO: 724754

Lat: 37.091N

Lon: 113.593W

Elev: 895

StdP: 91.03

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 23186

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-3.7	-2.3	-16.3	1.0	3.0	-14.0	1.2	5.7	11.7	9.1	9.4	7.5	1.2	70	0.488

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.1	41.2	18.9	39.8	18.5	38.3	18.0	20.8	33.9	20.2	33.6	19.7	33.3	6.1	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.5	13.9	24.4	16.3	12.9	25.5	14.8	11.7	26.9	64.1	33.6	61.8	33.5	59.9	33.1	23.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.9	10.2	8.5	DB	-6.7	43.6	2.5	1.2	-8.5	44.5	-10.0	45.1	-11.4	45.8	-13.3	46.7	(4)
(5)			WB	-8.6	21.8	2.2	0.8	-10.2	22.3	-11.5	22.8	-12.7	23.2	-14.3	23.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	18.0	5.9	8.4	13.0	16.7	22.3	28.2	31.5	30.2	25.8	18.0	10.4	5.1	(6)	
	DBStd	9.79	2.94	3.25	3.80	4.14	4.31	3.67	2.50	2.37	3.24	3.99	3.69	3.19	(7)	
	HDD10.0	403	129	63	15	3	0	0	0	0	0	2	38	154	(8)	
	HDD18.3	1628	385	278	168	78	15	1	0	0	1	54	237	411	(9)	
	CDD10.0	3330	2	18	108	204	382	547	667	627	473	249	51	2	(10)	
	CDD18.3	1513	0	0	3	29	139	298	408	368	224	43	0	0	(11)	
	CDH23.3	20859	0	0	71	406	1742	4325	6134	5153	2567	457	6	0	(12)	
	CDH26.7	12291	0	0	12	122	852	2684	3981	3160	1342	137	0	0	(13)	
(14) Wind	WSAvg	2.7	1.6	2.0	2.7	3.5	3.8	3.8	3.6	3.3	2.9	2.3	1.7	1.6	(14)	
(15) Precipitation	PrecAvg	210	29	28	26	15	9	5	13	17	15	16	21	17	(15)	
	PrecMax	401	120	79	111	73	50	34	39	59	69	62	62	63	(16)	
	PrecMin	107	0	0	0	0	0	0	0	0	0	0	0	0	(17)	
	PrecStd	72	30	23	25	16	11	7	12	16	17	17	17	16	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.2	22.0	27.9	32.4	37.9	42.3	43.6	41.4	38.0	32.7	23.9	16.4	(19)	
		MCWB	8.2	10.0	12.3	14.1	17.0	18.7	19.8	18.9	18.1	15.1	11.2	7.6	(20)	
	2%	DB	14.8	18.9	25.2	29.9	36.0	40.1	42.1	40.1	37.0	30.0	22.0	13.9	(21)	
		MCWB	6.6	8.5	11.0	13.1	15.6	17.8	19.4	18.7	17.3	14.3	10.6	6.7	(22)	
	5%	DB	12.9	17.3	22.9	27.7	33.6	38.7	40.4	38.7	35.1	27.8	19.6	12.4	(23)	
		MCWB	5.8	7.8	10.1	12.1	14.8	17.4	18.9	18.6	16.8	13.1	9.3	5.9	(24)	
	10%	DB	12.1	15.1	21.2	25.9	32.0	37.4	38.8	37.5	33.4	26.1	17.5	11.1	(25)	
		MCWB	5.5	6.8	9.4	11.1	14.3	16.7	18.5	18.3	16.3	12.3	8.3	5.1	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.8	10.8	12.8	14.5	17.3	19.4	22.0	21.3	20.5	16.9	12.7	9.6	(27)	
		MCDB	13.5	18.0	26.6	30.8	37.3	39.7	35.3	33.9	31.4	27.5	21.0	13.9	(28)	
	2%	WB	8.4	9.6	11.6	13.3	16.0	18.4	21.2	20.6	19.4	15.3	11.0	8.0	(29)	
		MCDB	12.8	16.4	23.8	28.4	34.6	38.6	34.3	33.8	30.6	27.9	19.5	12.4	(30)	
	5%	WB	7.1	8.6	10.6	12.4	15.1	17.5	20.6	20.1	18.5	14.1	9.9	6.8	(31)	
		MCDB	11.5	15.8	21.7	26.6	32.5	37.1	33.8	33.4	29.8	25.4	18.5	11.1	(32)	
	10%	WB	6.0	7.5	9.7	11.5	14.2	16.9	20.0	19.5	17.6	13.1	8.8	5.6	(33)	
		MCDB	10.6	14.1	19.8	24.6	30.5	36.0	33.7	33.0	29.4	23.4	16.9	9.9	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	10.7	11.4	13.4	13.8	14.2	15.2	14.1	14.0	14.2	13.5	12.2	10.1	(35)	
		MCDBR	12.9	14.7	16.1	16.8	16.6	16.9	15.8	15.7	15.9	15.8	14.9	11.9	(36)	
	5% WB	MCWBR	7.3	7.7	7.5	7.3	7.0	7.4	5.9	5.6	6.1	7.1	7.6	6.9	(37)	
		MCWBR	10.4	12.9	15.3	16.0	16.0	16.2	13.0	13.2	12.8	13.8	13.3	10.2	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.268	0.277	0.291	0.319	0.337	0.331	0.381	0.375	0.326	0.307	0.275	0.269	(40)	
		taud	2.570	2.553	2.512	2.419	2.405	2.421	2.370	2.377	2.502	2.518	2.570	2.575	(41)	
	Ebn at Noon		941	970	980	961	943	944	894	894	929	920	923	917	(42)	
		Edh at Noon	74	85	98	114	118	116	121	118	98	87	73	69	(43)	
(44) All-Sky Solar Radiation	RadAvg		2.86	3.73	5.26	6.63	7.59	8.44	7.37	6.80	5.96	4.42	3.25	2.49	(44)	
	RadStd		0.26	0.37	0.35	0.36	0.50	0.43	0.38	0.36	0.27	0.33	0.17	0.21	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (13 neighbors)	N/A	N/A	-0.98	N/A	N/A	N/A	N/A	N/A	N/A	+99	+42

Nomenclature: See separate page