

CEDAR CITY, UT, USA

WMO: 724755

Lat: 37.709N

Lon: 113.094W

Elev: 5586

StdP: 11.96

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 93129

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	2.6	7.9	-3.6	5.6	13.5	0.7	7.0	20.4	27.5	44.0	24.8	42.8	2.2	60	0.585

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	30.2	94.0	59.1	91.6	58.6	89.4	57.8	63.6	82.3	62.4	81.6	61.2	80.9	10.8	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
58.3	89.7	67.6	56.4	83.4	68.1	54.2	77.0	68.9	31.7	81.8	30.7	81.1	29.7	80.7	72.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 26.0	23.0	19.4	-6.4	98.3	5.8	1.7	-10.6	99.5	-14.0	100.6	-17.2	101.5	-21.4	102.8		
(5)			-7.0	66.3	5.7	1.7	-11.1	67.5	-14.4	68.5	-17.6	69.5	-21.7	70.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	50.9	30.7	34.4	42.0	47.5	56.8	67.8	74.6	72.5	63.7	50.7	39.3	30.0		
	DBStd	17.17	9.31	8.39	7.62	7.48	7.75	6.90	4.01	3.77	6.33	7.71	8.96	9.35		
	HDD50	2498	597	438	263	134	29	1	0	0	4	84	327	621		
	HDD65	5874	1062	858	714	525	269	51	0	2	94	443	770	1086		
	CDD50	2835	0	1	14	59	239	536	762	697	413	107	7	0		
	CDD65	736	0	0	0	0	14	136	297	234	54	1	0	0		
	CDH74	11224	0	0	3	31	495	2525	3946	3043	1080	101	0	0		
	CDH80	4888	0	0	0	2	117	1126	1971	1355	307	10	0	0		
(14) Wind	WSAvg	7.3	6.0	6.7	7.9	8.8	8.5	8.7	7.5	7.3	7.1	6.5	6.2	5.9		
(15) Precipitation	PrecAvg	11.3	0.7	0.9	1.2	1.0	0.8	0.5	1.0	1.3	0.9	1.1	1.0	0.7		
	PrecMax	16.9	3.0	2.4	3.0	3.1	2.2	1.7	4.4	4.4	4.6	3.3	2.6	1.7		
	PrecMin	6.2	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
	PrecStd	2.7	0.7	0.6	0.7	0.6	0.6	0.4	0.9	1.1	0.9	0.9	0.7	0.4		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	58.7	63.8	72.7	78.0	87.8	95.8	97.8	94.6	89.4	81.3	70.2	57.6		
		MCWB	41.7	44.3	47.4	50.6	56.1	57.7	60.6	59.9	57.1	53.1	46.7	42.5		
	2%	DB	52.6	58.4	67.5	73.4	83.3	92.4	95.1	92.1	86.2	76.9	65.3	53.1		
		MCWB	39.4	42.1	45.3	48.3	53.4	56.7	60.1	59.3	56.0	51.6	45.2	40.1		
	5%	DB	48.7	53.3	63.4	69.6	79.6	89.7	92.7	89.9	83.6	72.8	61.0	49.0		
		MCWB	37.9	39.7	43.6	46.9	51.8	55.7	59.5	59.0	55.6	49.6	43.3	38.0		
	10%	DB	44.8	49.0	59.4	65.7	75.8	86.9	90.2	87.6	81.0	68.9	56.2	44.9		
		MCWB	36.2	37.9	42.0	45.4	50.2	54.7	58.7	58.5	55.2	48.0	41.3	36.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	43.9	45.9	48.8	52.1	57.2	60.4	65.5	65.1	63.3	56.6	49.1	44.3		
		MCDB	54.1	59.8	68.9	74.3	83.9	88.0	84.0	82.4	78.4	70.2	63.3	54.2		
	2%	WB	41.1	43.0	46.4	49.8	54.7	58.8	64.0	63.4	60.4	53.4	46.4	41.6		
		MCDB	49.4	55.8	64.9	69.9	78.7	87.1	82.9	82.4	77.5	72.3	62.0	50.0		
	5%	WB	39.0	40.9	44.5	47.9	52.9	57.2	62.8	62.2	58.8	51.2	44.3	39.2		
		MCDB	46.8	51.3	61.3	67.0	76.0	84.8	82.1	81.4	75.2	68.9	58.7	47.1		
	10%	WB	36.8	38.6	42.6	46.1	51.2	55.7	61.6	61.1	57.0	49.3	42.1	36.7		
		MCDB	44.0	48.0	57.8	64.2	73.5	82.7	81.4	80.5	74.0	65.8	55.3	44.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	23.1	23.5	27.1	27.8	30.0	32.4	30.2	29.5	31.0	30.0	27.1	22.9		
		MCDBR	27.5	29.8	34.1	35.1	35.6	36.3	33.9	33.2	34.5	35.9	33.8	27.0		
		MCWBR	16.7	16.6	17.2	16.6	15.5	14.7	12.6	12.6	14.3	17.4	18.2	16.3		
	5% WB	MCDBR	24.0	26.0	31.4	32.5	32.9	33.1	27.7	27.2	27.0	30.6	31.1	23.8		
		MCWBR	15.1	15.1	16.4	15.9	14.4	13.9	10.0	10.2	11.7	15.1	17.4	14.8		
(40) Clear-Sky Solar Irradiance	taub		0.244	0.259	0.270	0.296	0.305	0.303	0.343	0.345	0.298	0.287	0.253	0.248		
	taud		2.607	2.555	2.555	2.477	2.500	2.510	2.457	2.435	2.575	2.564	2.628	2.592		
	Ebn at Noon		308	314	318	312	309	308	295	292	304	299	302	299		
	Edh at Noon		22	27	30	34	34	34	35	35	29	26	22	21		
(44) All-Sky Solar Radiation	RadAvg		878	1146	1616	2034	2323	2631	2262	2085	1836	1361	987	758		
	RadStd		76	109	106	114	175	161	131	126	98	112	57	62		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page