

EUREKA AP, NV, USA

WMO: 724770

Lat: 39.601N

Lon: 116.006W

Elev: 1809

StdP: 81.40

Time Zone: -8.00 (NAP)

Period: 96-19

WBAN: 03170

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-19.7	-17.2	-23.6	0.6	-14.1	-21.1	0.7	-10.4	11.2	1.8	9.8	1.9	2.4	220	0.619

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.4	34.2	13.5	33.0	13.2	32.0	12.9	15.7	27.5	15.1	27.4	14.4	26.9	4.9	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.3	11.2	18.4	11.0	10.2	18.3	9.1	9.0	18.6	50.0	27.6	47.9	27.0	45.8	26.5	18.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.8	9.0	7.9	DB	-25.2	37.1	3.3	1.0	-27.5	37.9	-29.5	38.5	-31.3	39.1	-33.7	39.8	(4)
(5)			WB	-25.5	17.5	3.2	0.7	-27.8	18.0	-29.6	18.4	-31.4	18.7	-33.8	19.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.4	-3.3	-1.3	3.5	6.7	11.0	17.2	22.1	20.7	15.7	8.6	2.8	-3.2	(6)	
	DBStd	9.76	5.68	5.50	4.77	4.09	4.11	4.19	2.25	2.34	4.11	4.48	4.99	5.57	(7)	
	HDD10.0	1805	413	316	204	114	38	4	0	0	9	77	219	411	(8)	
	HDD18.3	3866	672	549	459	350	227	66	3	8	93	302	467	669	(9)	
	CDD10.0	1230	0	0	4	14	69	221	374	332	180	33	2	0	(10)	
	CDD18.3	249	0	0	0	0	1	33	118	82	14	1	0	0	(11)	
	CDH23.3	5656	0	0	0	9	138	1051	2146	1692	589	32	0	0	(12)	
	CDH26.7	2560	0	0	0	1	26	447	1112	794	177	3	0	0	(13)	
(14) Wind	WSAvg	3.1	2.5	2.8	3.3	3.6	3.3	3.3	3.3	3.2	3.1	3.0	2.7	2.6	(14)	
(15) Precipitation	PrecAvg	234	19	21	24	27	28	16	13	15	16	18	15	18	(15)	
	PrecMax	331	45	44	73	61	73	59	43	44	42	67	43	37	(16)	
	PrecMin	144	1	1	2	0	0	0	0	0	1	0	1	0	(17)	
	PrecStd	48	14	10	17	17	23	17	10	13	11	17	11	11	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.9	15.6	21.4	24.4	29.4	35.0	36.6	34.7	32.0	26.5	20.4	12.5	(19)	
		MCWB	4.7	5.3	7.6	9.0	11.1	13.6	14.2	13.5	12.3	10.6	7.9	4.3	(20)	
	2%	DB	9.8	12.5	18.3	21.9	27.0	32.9	35.0	33.1	30.1	23.8	17.7	9.9	(21)	
		MCWB	3.7	4.4	6.4	8.1	10.5	12.7	13.8	13.0	12.0	9.3	6.7	3.6	(22)	
	5%	DB	7.3	9.9	15.9	19.4	24.6	31.3	33.7	32.3	28.8	21.5	15.1	7.7	(23)	
		MCWB	2.3	3.3	5.6	7.3	9.8	12.2	13.5	12.8	11.6	8.3	5.5	2.5	(24)	
	10%	DB	4.8	7.4	13.1	17.2	22.2	29.3	32.5	31.2	27.3	19.1	12.3	5.5	(25)	
		MCWB	1.1	2.4	4.5	6.1	9.0	11.6	13.4	12.6	11.1	7.4	4.2	1.3	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.8	6.6	8.2	10.2	12.4	15.2	16.8	16.3	15.9	11.7	9.0	6.1	(27)	
		MCDB	10.3	13.0	19.4	21.0	23.7	30.7	27.5	25.4	25.7	22.8	17.9	10.4	(28)	
	2%	WB	4.0	5.1	6.9	8.9	11.4	14.0	16.0	15.3	14.3	10.4	7.2	4.4	(29)	
		MCDB	8.8	11.2	17.1	19.7	23.5	28.7	28.0	26.8	24.1	20.4	16.5	8.6	(30)	
	5%	WB	2.7	3.8	5.9	7.8	10.6	13.0	15.3	14.6	13.1	9.2	5.9	2.9	(31)	
		MCDB	6.5	9.1	14.9	17.8	22.4	28.3	27.9	26.6	24.0	18.7	13.9	7.0	(32)	
	10%	WB	1.5	2.6	4.8	6.7	9.7	12.2	14.8	13.9	11.8	8.2	4.7	1.4	(33)	
		MCDB	4.8	7.0	12.7	15.8	20.6	27.2	27.5	26.5	24.7	17.6	11.5	5.1	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	13.8	13.6	14.7	15.9	17.2	20.5	20.4	20.5	20.1	18.3	16.4	13.6	(35)	
		MCDBR	15.2	16.1	18.7	20.4	21.7	23.1	22.6	22.2	22.1	21.3	19.7	15.5	(36)	
	5% WB	MCWBR	9.9	9.4	9.4	9.9	9.3	9.0	8.6	8.8	9.5	10.4	10.8	10.0	(37)	
		MCWBR	13.3	14.2	17.6	18.0	19.2	21.2	18.0	18.0	17.9	17.9	18.0	12.9	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.236	0.245	0.256	0.284	0.293	0.294	0.314	0.307	0.278	0.260	0.242	0.236	(40)	
		taud	2.619	2.612	2.602	2.507	2.527	2.555	2.524	2.518	2.605	2.637	2.646	2.621	(41)	
	Ebn at Noon		971	1002	1015	994	984	979	956	957	975	969	956	947	(42)	
		Edh at Noon	66	77	87	103	103	101	103	100	86	74	64	61	(43)	
(44) All-Sky Solar Radiation	RadAvg		2.31	3.24	4.61	5.82	6.74	7.92	7.23	6.72	5.70	4.09	2.74	1.97	(44)	
	RadStd		0.28	0.36	0.31	0.38	0.69	0.59	0.47	0.46	0.29	0.29	0.14	0.27	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)		+0.40	N/A	N/A	+0.52	N/A	N/A	N/A	N/A	+125	+61

Nomenclature: See separate page