

CANYONLANDS FIELD, UT, USA

WMO: 724776

Lat: 38.750N

Lon: 109.763W

Elev: 1390

StdP: 85.70

Time Zone: -7.00 (NAM)

Period: 98-19

WBAN: 93075

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-17.0	-13.0	-21.3	0.7	-7.7	-18.9	0.8	-2.9	9.8	7.2	8.3	3.2	0.6	260	0.542

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.4	37.6	16.8	36.5	16.1	35.3	15.5	19.0	30.1	18.3	29.6	17.7	29.2	4.3	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.7	14.1	21.1	15.2	12.8	21.3	13.5	11.5	21.9	59.5	29.4	57.1	29.4	54.9	28.9	29.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.4	9.4	8.2	DB	-18.4	39.9	4.9	1.2	-21.9	40.8	-24.8	41.5	-27.5	42.1	-31.0	43.0	
			WB	-18.8	21.1	4.6	2.7	-22.1	23.1	-24.8	24.7	-27.4	26.2	-30.8	28.2	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	12.6	-2.6	2.0	7.9	12.0	17.5	24.1	27.8	25.6	20.7	12.6	4.7	-2.2
	DBStd	11.08	5.54	4.56	4.02	4.11	4.42	3.69	2.39	2.28	3.70	4.19	4.19	5.01
	HDD10.0	1298	391	224	90	27	3	0	0	0	0	22	164	378
	HDD18.3	2943	649	457	325	192	69	5	0	0	19	183	408	637
	CDD10.0	2231	0	1	23	87	235	422	551	483	321	102	6	0
	CDD18.3	834	0	0	0	2	43	177	293	225	90	4	0	0
	CDH23.3	11681	0	0	9	81	728	2674	4098	2826	1173	92	0	0
	CDH26.7	6186	0	0	0	11	266	1481	2427	1496	490	16	0	0
Wind	WSAvg	2.8	1.7	2.3	3.0	3.9	3.7	3.7	3.1	2.9	2.8	2.4	2.0	1.7
Precipitation	PrecAvg	188	13	12	13	14	16	9	15	22	23	24	12	12
	PrecMax	260	44	31	34	43	40	40	39	44	74	119	33	40
	PrecMin	125	4	1	2	3	2	1	2	3	7	1	1	2
	PrecStd	43	9	10	8	9	12	10	12	13	16	25	8	9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.4	17.2	24.6	28.0	34.1	38.6	39.7	37.4	35.1	28.5	20.4	12.5
		MCWB	5.7	6.9	9.5	11.1	15.1	15.9	17.1	17.3	15.7	12.2	9.1	6.1
	2%	DB	9.0	14.1	21.5	25.8	31.9	37.0	38.0	36.3	32.9	26.1	17.7	9.5
		MCWB	4.2	5.8	8.2	9.9	13.3	15.4	17.1	16.1	14.8	11.4	7.5	4.5
	5%	DB	7.2	12.0	19.1	23.6	29.6	35.7	37.2	35.0	31.5	23.6	15.9	7.4
		MCWB	2.8	4.9	7.1	9.1	12.2	14.5	16.9	15.6	14.2	10.6	6.7	2.6
	10%	DB	5.0	9.5	17.0	21.9	27.6	34.0	36.1	33.6	29.7	21.3	12.9	5.1
		MCWB	1.4	3.7	6.2	8.5	11.6	13.9	16.3	15.7	13.8	9.8	5.5	1.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.8	8.0	10.1	11.9	16.4	17.8	22.5	19.9	17.7	14.6	10.2	7.2
		MCDB	9.6	14.5	22.4	25.0	33.4	34.7	35.4	30.4	26.3	22.7	17.9	11.4
	2%	WB	4.9	6.7	8.8	10.6	14.2	16.7	19.3	19.0	16.7	13.1	8.5	5.1
		MCDB	8.4	12.4	19.5	22.8	28.0	33.0	30.9	29.1	26.1	20.9	15.7	8.7
	5%	WB	3.4	5.5	7.8	9.9	13.1	15.8	18.5	18.3	15.9	12.0	7.2	3.1
		MCDB	6.3	10.8	17.5	21.6	26.3	31.5	30.4	28.3	25.8	19.8	14.3	6.6
	10%	WB	1.7	4.3	6.7	9.0	12.1	15.1	17.9	17.6	15.1	10.9	6.0	1.6
		MCDB	4.6	8.8	15.6	19.9	25.2	30.5	30.1	27.6	25.5	19.4	12.2	4.8
Mean Daily Temperature Range	5% DB	MDBR	11.0	11.8	14.4	14.9	15.4	16.8	15.4	15.2	15.5	14.4	13.4	11.0
		MCDBR	13.0	14.9	18.3	18.0	18.5	18.6	17.0	17.5	17.6	17.5	16.5	13.0
		MCWBR	8.5	8.2	9.1	8.5	8.0	7.9	6.9	6.9	7.5	8.3	9.2	8.6
	5% WB	MCDBR	11.3	13.1	16.5	16.5	16.7	16.7	14.3	13.7	13.4	13.6	14.5	11.7
		MCWBR	7.7	7.4	8.3	7.8	7.0	7.4	5.5	5.5	5.6	6.5	8.2	7.9
Clear-Sky Solar Irradiance	taub	0.254	0.265	0.284	0.308	0.317	0.316	0.364	0.368	0.324	0.292	0.264	0.253	
	taud	2.561	2.534	2.483	2.417	2.442	2.445	2.357	2.355	2.465	2.523	2.556	2.571	
	Ebn at Noon	948	977	983	969	961	957	908	897	924	928	926	925	
	Edh at Noon	72	85	99	113	113	112	122	119	100	85	71	66	
All-Sky Solar Radiation	RadAvg	2.65	3.55	5.07	6.37	7.31	8.18	7.41	6.52	5.67	4.20	3.01	2.28	
	RadStd	0.19	0.28	0.33	0.31	0.38	0.41	0.34	0.29	0.26	0.28	0.20	0.16	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	-0.57	N/A	N/A	N/A	N/A	N/A
(47)	Regional (13 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page