

VACAVILLE NUT TREE, CA, USA

WMO: 724828

Lat: 38.378N

Lon: 121.958W

Elev: 109

StdP: 14.64

Time Zone: -8.00 (NAP)

Period: 01-19

WBAN: 93241

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	30.5	33.8	13.6	11.0	57.7	17.9	13.6	57.2	22.0	51.0	18.9	52.3	0.5	350	0.455

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	33.1	101.9	68.7	99.1	67.8	95.8	67.0	71.2	97.0	69.7	94.3	68.4	92.2	8.3	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
61.3	81.4	80.6	59.8	76.9	79.0	58.3	73.0	77.1	34.9	97.3	33.6	94.5	32.5	92.3	77.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
19.9	17.3	15.3	DB	26.3	107.7	3.3	2.9	23.9	109.8	22.0	111.5	20.2	113.1	17.8	115.2
			WB	24.8	73.8	3.2	2.2	22.5	75.4	20.6	76.7	18.8	77.9	16.5	79.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	62.6	48.3	51.7	56.0	59.8	66.1	73.4	77.8	76.0	73.1	65.0	54.8	48.2	(6)
(7)		DBStd	11.73	4.60	4.92	5.54	6.13	5.94	6.18	5.06	4.57	5.41	5.53	5.61	5.03	(7)
(8)		HDD50	246	86	36	11	1	0	0	0	0	0	0	18	94	(8)
(9)		HDD65	2319	517	374	283	180	56	7	0	0	4	68	308	522	(9)
(10)		CDD50	4835	35	82	197	295	500	702	861	807	692	464	163	37	(10)
(11)		CDD65	1430	0	0	4	23	90	259	396	342	247	67	2	0	(11)
(12)		CDH74	19751	2	9	121	461	1427	3639	5265	4368	3295	1094	70	0	(12)
(13)		CDH80	10493	0	1	14	149	587	1976	3128	2465	1768	399	6	0	(13)
(14)	Wind	WSAvg	5.8	3.9	5.3	6.0	6.6	7.3	7.2	6.9	6.4	5.5	5.1	4.2	4.7	(14)
(15)	Precipitation	PrecAvg	26.3	5.7	4.6	3.5	1.3	0.6	0.1	0.0	0.1	0.3	1.2	3.5	4.9	(15)
(16)		PrecMax	48.9	16.7	15.2	10.7	6.4	3.4	1.6	1.2	1.4	1.7	8.2	8.9	18.4	(16)
(17)		PrecMin	8.1	0.1	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.3	(17)
(18)		PrecStd	8.7	4.2	3.9	2.7	1.5	0.8	0.3	0.2	0.4	1.5	2.7	4.1		(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	70.5	75.1	81.8	90.1	96.7	104.1	107.7	104.4	102.0	94.1	80.0	66.2	(19)
(20)		MCWB	51.4	57.6	60.8	63.5	67.1	70.3	71.2	68.4	66.2	63.3	58.9	52.1		(20)
(21)		2%	DB	65.6	71.2	77.4	84.2	90.7	99.8	102.1	99.7	98.6	88.5	75.4	63.1	(21)
(22)		MCWB	51.7	55.2	59.5	61.3	65.2	68.6	69.6	67.6	65.9	61.6	57.7	52.2		(22)
(23)		5%	DB	61.6	66.3	73.1	79.5	86.9	95.3	98.9	96.7	94.5	84.1	71.1	60.5	(23)
(24)		MCWB	51.1	53.2	57.5	60.0	63.1	67.3	68.7	67.2	64.9	60.0	55.7	51.9		(24)
(25)		10%	DB	58.0	62.9	69.6	74.4	82.0	91.0	94.9	92.6	90.5	80.7	66.3	57.4	(25)
(26)		MCWB	50.1	52.0	55.5	57.8	61.6	65.4	67.5	66.2	63.8	59.0	54.0	51.1		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	58.0	60.4	63.3	66.9	70.3	73.4	73.4	71.4	70.2	66.5	62.5	59.4	(27)
(28)		MCDB	62.5	69.2	77.4	84.6	90.7	97.7	102.5	97.5	94.5	85.7	74.6	62.3		(28)
(29)		2%	WB	55.4	58.0	61.0	63.7	67.3	70.8	71.3	69.7	67.9	64.4	60.2	57.0	(29)
(30)		MCDB	60.7	66.2	74.5	80.5	88.3	95.6	98.4	94.4	92.0	83.0	69.2	59.4		(30)
(31)		5%	WB	53.6	55.9	58.9	61.2	64.9	68.6	69.8	68.4	66.4	62.5	58.5	54.7	(31)
(32)		MCDB	57.2	63.1	70.8	76.1	83.8	91.9	95.7	92.4	90.0	79.0	66.3	57.2		(32)
(33)		10%	WB	51.8	54.0	56.9	59.1	62.7	66.8	68.4	67.2	65.0	60.8	56.7	52.9	(33)
(34)		MCDB	56.4	60.2	66.5	72.7	79.7	88.7	92.9	90.4	87.7	75.7	64.1	55.5		(34)
(35)	Mean Daily Temperature Range		MDBR	18.3	20.2	21.5	23.4	26.4	30.1	33.1	32.7	32.0	27.5	22.3	17.3	(35)
(36)		5% DB	MCDBR	26.3	28.2	30.0	32.4	34.4	37.2	37.9	37.5	38.5	35.2	29.3	22.6	(36)
(37)		MCWBR	15.2	15.2	15.5	15.3	14.5	13.9	13.5	13.2	14.0	14.4	14.5	13.4	(37)	
(38)		5% WB	MCDBR	17.9	22.0	27.4	29.9	32.2	34.8	35.8	34.6	34.4	29.7	22.2	13.0	(38)
(39)		MCWBR	12.0	13.1	14.9	15.2	14.9	14.2	13.6	13.0	13.5	13.5	12.5	9.4		(39)
(40)	Clear-Sky Solar Irradiance	taub	0.319	0.321	0.332	0.353	0.358	0.356	0.358	0.343	0.343	0.328	0.321	0.324	(40)	
(41)		taud	2.525	2.524	2.480	2.402	2.414	2.425	2.411	2.444	2.452	2.519	2.524	2.513	(41)	
(42)		Ebn at Noon	274	289	295	293	292	292	290	293	287	282	271	263	(42)	
(43)		Edh at Noon	24	28	32	36	37	36	37	35	32	27	24	23	(43)	
(44)	All-Sky Solar Radiation	RadAvg	709	1029	1462	1934	2324	2583	2550	2277	1865	1323	866	628	(44)	
(45)		RadStd	123	133	149	163	138	106	73	70	62	88	61	103	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (51 neighbors)	+0.72	N/A	-2.03	N/A	N/A	N/A	N/A	-216	+245	+54	(47)

Nomenclature: See separate page