

ELY, NV, USA

WMO: 724860

Lat: 39.295N

Lon: 114.847W

Elev: 6262

StdP: 11.66

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 23154

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-3.8	1.4	-10.0	4.0	6.7	-5.4	5.2	11.2	28.1	36.4	25.4	34.3	10.7	170	0.679

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	37.2	91.6	56.6	89.4	55.7	87.3	55.0	60.3	80.2	59.1	79.7	57.7	78.8	11.7	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
55.1	81.6	62.7	52.5	74.1	63.3	49.9	67.2	63.5	29.4	79.4	28.4	78.7	27.4	78.8	68.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.9	22.3	19.2	DB	-13.3	95.9	5.6	2.0	-17.4	97.4	-20.6	98.5	-23.8	99.7	-27.9	101.1	(4)
(5)			WB	-13.8	63.1	5.5	1.8	-17.8	64.4	-21.0	65.5	-24.1	66.5	-28.1	67.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	45.8	26.5	29.2	37.3	42.5	50.6	61.0	68.9	67.0	57.9	45.8	35.0	26.3		
	DBStd	16.69	9.64	9.21	8.07	7.52	7.50	7.01	3.99	4.17	6.84	7.77	9.30	9.63		
	HDD50	3421	730	582	397	242	86	10	0	0	18	172	451	733		
	HDD65	7282	1195	1001	859	676	448	149	12	26	221	597	900	1198		
	CDD50	1875	0	0	3	16	105	341	587	527	255	40	1	0		
	CDD65	261	0	0	0	0	1	29	134	88	9	0	0	0		
	CDH74	8203	0	0	0	11	218	1573	3194	2459	708	40	0	0		
	CDH80	3263	0	0	0	1	41	580	1496	998	145	2	0	0		
(14) Wind	WSAvg	9.3	8.9	9.3	9.7	10.0	9.4	9.7	9.2	9.5	9.3	9.2	9.0	8.9		
(15) Precipitation	PrecAvg	9.8	0.7	0.7	0.9	1.0	1.1	0.7	0.7	0.8	0.8	0.8	0.7	0.7		
	PrecMax	15.5	2.1	2.7	2.2	3.4	3.3	3.5	2.3	2.9	5.0	2.3	1.8	3.3		
	PrecMin	4.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
	PrecStd	2.6	0.5	0.6	0.6	0.7	0.9	0.8	0.6	0.7	0.9	0.6	0.5	0.6		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	56.0	59.9	68.8	75.1	85.0	92.5	95.7	92.3	87.3	78.6	67.6	55.4		
		MCWB	39.5	41.7	44.7	48.4	53.5	56.8	58.5	56.7	54.0	50.5	44.8	39.0		
	2%	DB	50.5	53.7	63.6	69.9	79.7	89.0	92.8	90.1	83.8	74.0	63.2	50.5		
		MCWB	37.6	39.1	42.5	45.7	50.6	54.5	57.1	56.1	53.0	48.1	43.2	37.8		
	5%	DB	46.0	48.9	59.3	66.0	75.5	86.4	90.6	88.2	81.3	70.1	58.1	46.1		
		MCWB	35.9	37.3	41.2	44.0	49.1	53.4	56.3	55.5	52.2	46.5	40.9	35.7		
	10%	DB	41.3	44.1	55.1	61.6	71.7	83.5	88.3	85.9	78.5	66.0	52.4	41.8		
		MCWB	33.9	35.0	39.5	42.4	47.7	52.6	55.7	54.7	51.4	44.8	38.5	33.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	42.1	42.7	45.8	49.4	55.1	58.7	62.1	63.0	59.4	52.4	46.8	42.2		
		MCDB	51.1	54.9	64.9	72.5	79.3	86.3	81.8	81.0	75.3	71.1	62.0	51.4		
	2%	WB	39.0	40.4	43.7	46.9	52.3	56.7	60.5	60.1	57.0	50.0	44.0	39.2		
		MCDB	47.3	51.8	61.4	66.8	74.8	83.4	81.2	79.0	73.8	69.1	60.5	47.4		
	5%	WB	36.6	38.0	41.9	45.0	50.4	55.0	59.5	58.7	55.0	48.0	41.6	36.6		
		MCDB	44.5	47.3	57.8	62.7	71.8	81.2	80.5	78.7	73.1	65.6	56.2	44.7		
	10%	WB	34.3	35.6	39.9	43.2	48.7	53.4	58.4	57.3	53.1	46.1	39.3	34.1		
		MCDB	40.9	42.8	53.8	59.5	68.7	79.3	79.8	77.5	71.9	63.1	51.2	41.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	25.8	24.7	27.2	28.2	32.1	37.0	37.2	36.5	35.9	33.1	29.2	25.9		
		MCDBR	30.4	29.6	34.5	37.8	40.1	42.7	41.7	40.4	40.2	40.2	37.1	30.0		
	5% WB	MCWBR	19.3	17.2	17.6	18.4	18.2	18.8	17.1	17.1	18.0	20.4	20.6	19.0		
		MCWBR	26.6	26.0	32.0	33.7	36.6	38.9	34.0	32.7	32.3	34.9	33.6	26.7		
(40) Clear-Sky Solar Irradiance	taub		0.234	0.243	0.252	0.279	0.294	0.292	0.317	0.314	0.276	0.264	0.239	0.234		
	taud		2.610	2.602	2.619	2.523	2.520	2.567	2.520	2.508	2.617	2.622	2.657	2.616		
	Ebn at Noon		309	319	324	317	312	311	302	302	311	306	305	302		
	Edh at Noon		21	25	27	32	33	31	33	32	27	24	20	20		
(44) All-Sky Solar Radiation	RadAvg		787	1064	1502	1870	2141	2513	2253	2094	1794	1294	896	668		
	RadStd		73	110	89	125	216	194	146	150	106	96	48	69		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)		N/A	N/A	N/A	+1.12	N/A	N/A	N/A	N/A	+227	+115

Nomenclature: See separate page