

CALIENTE, NV, USA

WMO: 724870

Lat: 37.612N

Lon: 114.526W

Elev: 4373

StdP: 12.52

Time Zone: -8.00 (NAP)

Period: 90-02

WBAN: 03163

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	8.3	12.9	-9.9	3.8	15.3	-6.1	4.6	19.1	16.2	38.9	13.9	41.7	1.8	10	0.512

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	35.5	98.9	62.9	96.6	61.8	93.9	60.7	64.9	88.6	63.6	88.8	62.3	89.1	8.7	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
57.6	83.3	71.3	54.3	73.9	73.6	50.8	64.8	74.7	32.1	89.2	31.0	89.1	30.0	89.6	72.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.1	14.8	12.6	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	53.2	32.9	38.9	44.9	51.2	60.0	68.4	75.2	73.8	66.0	53.9	39.9	31.7
	DBStd	16.16	5.95	6.40	5.80	6.95	6.01	6.74	4.19	4.31	5.06	5.90	7.54	7.17
	HDD50	1997	529	311	174	68	5	4	0	0	0	30	307	569
	HDD65	5156	994	730	623	414	174	43	0	0	46	345	753	1034
	CDD50	3147	0	1	16	105	314	556	782	738	481	150	4	0
	CDD65	832	0	0	0	0	19	145	317	273	77	1	0	0
	CDH74	17217	0	0	4	180	925	3510	5487	4683	2070	358	0	0
	CDH80	8991	0	0	0	30	259	1873	3182	2638	924	85	0	0
(14) Wind	WSAvg	3.9	2.8	3.4	4.1	4.8	4.9	5.1	4.9	4.5	3.6	3.1	2.8	2.5
(15) Precipitation	PrecAvg	9.4	0.8	0.9	1.1	0.8	0.6	0.3	1.0	1.1	0.8	0.8	0.9	0.6
	PrecMax	18.5	2.6	2.9	3.9	3.1	2.3	1.5	5.4	3.3	2.8	3.7	3.4	1.9
	PrecMin	4.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	2.9	0.7	0.8	1.1	0.9	0.6	0.3	1.1	0.8	0.8	0.9	0.9	0.5
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	60.7	69.2	73.9	83.8	92.7	99.9	102.1	100.2	94.9	86.6	71.5	58.1
		MCWB	42.0	46.4	49.0	54.3	59.3	62.2	64.9	63.5	60.8	55.7	49.6	40.3
	2%	DB	54.0	64.2	69.4	79.4	85.6	97.0	99.2	98.6	91.5	82.2	66.4	52.5
		MCWB	38.8	44.4	47.0	52.1	55.5	61.1	63.4	63.0	59.6	54.0	46.3	38.0
	5%	DB	50.3	59.2	65.5	74.5	82.0	93.6	96.6	96.1	89.1	77.9	62.0	48.3
		MCWB	37.2	42.1	45.2	50.0	53.9	59.5	62.2	61.7	58.4	52.0	44.2	36.0
	10%	DB	46.4	53.8	61.4	70.0	79.2	90.8	93.9	92.6	86.0	73.4	56.4	44.3
		MCWB	34.8	39.3	43.5	48.2	53.0	58.2	61.1	60.9	57.3	49.8	41.1	33.9
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	43.3	47.3	50.1	54.5	59.8	63.2	67.3	66.2	63.1	56.7	51.6	41.3
		MCDB	57.3	66.7	70.5	82.1	90.7	97.6	93.8	87.3	85.8	81.7	67.2	55.1
	2%	WB	40.4	45.1	47.9	52.6	57.0	61.5	65.5	64.6	61.1	54.9	47.7	39.0
		MCDB	52.5	63.5	67.5	77.3	81.7	96.6	89.3	88.8	86.2	80.4	64.9	50.3
	5%	WB	37.5	42.4	46.0	50.7	55.1	60.0	64.1	63.5	59.5	52.6	44.6	36.7
		MCDB	49.2	57.1	63.6	73.3	79.1	92.5	87.7	90.5	85.2	76.3	61.1	47.3
	10%	WB	35.2	39.8	44.1	48.8	53.3	58.5	62.7	62.2	58.0	50.3	41.6	34.5
		MCDB	45.2	52.3	59.8	69.2	77.6	89.3	87.5	89.2	83.5	72.2	55.2	43.4
(35) Mean Daily Temperature Range	5% DB	MDBR	27.2	26.6	27.9	30.1	32.5	37.3	35.5	35.8	36.8	35.5	30.6	26.3
		MCDBR	34.8	38.4	36.9	39.0	39.3	44.9	40.3	41.5	42.0	44.4	39.3	32.3
	5% WB	MCWBR	23.0	23.1	20.6	19.9	19.6	21.9	18.2	19.3	20.5	24.2	24.0	21.2
		MCWBR	32.2	35.9	34.0	37.2	36.7	43.3	33.3	35.3	37.5	42.0	38.0	29.8
(40) Clear-Sky Solar Irradiance	taub		0.249	0.255	0.266	0.294	0.313	0.307	0.345	0.333	0.297	0.278	0.254	0.248
		taud	2.650	2.646	2.620	2.513	2.488	2.519	2.474	2.501	2.590	2.624	2.655	2.654
	Ebn at Noon		307	317	320	313	306	307	294	297	305	303	302	301
		Edh at Noon	21	24	28	33	34	33	35	33	28	25	21	20
(44) All-Sky Solar Radiation	RadAvg		895	1172	1649	2074	2379	2675	2387	2212	1915	1392	1014	780
	RadStd		82	128	108	115	162	152	126	123	86	106	49	66

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (13 neighbors)		N/A	N/A	-1.76	N/A	N/A	N/A	N/A	N/A	+189	+86

Nomenclature: See separate page