

CALIENTE, NV, USA

WMO: 724870

Lat: 37.612N

Lon: 114.526W

Elev: 1333

StdP: 86.30

Time Zone: -8.00 (NAP)

Period: 90-02

WBAN: 03163

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-13.1	-10.6	-23.3	0.5	-9.3	-21.2	0.7	-7.1	7.3	3.8	6.2	5.4	0.8	10	0.512

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.7	37.2	17.2	35.9	16.6	34.4	15.9	18.3	31.5	17.6	31.6	16.8	31.7	3.9	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
14.2	11.9	21.8	12.4	10.6	23.1	10.5	9.3	23.7	56.7	31.8	54.3	31.7	51.9	32.0	22.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.6	6.6	5.6	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.8	0.5	3.8	7.2	10.7	15.6	20.2	24.0	23.2	18.9	12.2	4.4	-0.2		
	DBStd	8.98	3.31	3.56	3.22	3.86	3.34	3.75	2.33	2.39	2.81	3.28	4.19	3.99		
	HDD10.0	1109	294	173	97	38	3	2	0	0	0	17	171	316		
	HDD18.3	2864	552	406	346	230	97	24	0	0	26	192	418	574		
	CDD10.0	1748	0	1	9	58	174	309	434	410	267	83	2	0		
	CDD18.3	462	0	0	0	0	11	81	176	152	43	1	0	0		
	CDH23.3	9565	0	0	2	100	514	1950	3048	2602	1150	199	0	0		
	CDH26.7	4995	0	0	0	17	144	1041	1768	1466	513	47	0	0		
(14) Wind	WSAvg	1.7	1.3	1.5	1.8	2.2	2.2	2.3	2.2	2.0	1.6	1.4	1.3	1.1		
(15) Precipitation	PrecAvg	240	20	22	29	20	16	7	25	28	20	21	23	14		
	PrecMax	469	67	74	98	78	58	39	136	85	72	93	86	48		
	PrecMin	121	0	0	0	0	0	0	0	0	0	0	0	0		
	PrecStd	74	19	20	27	22	15	8	28	21	20	22	23	13		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.0	20.7	23.3	28.8	33.7	37.7	38.9	37.9	34.9	30.3	22.0	14.5		
		MCWB	5.5	8.0	9.4	12.4	15.2	16.8	18.3	17.5	16.0	13.2	9.8	4.6		
	2%	DB	12.2	17.9	20.8	26.4	29.8	36.1	37.3	37.0	33.1	27.9	19.1	11.4		
		MCWB	3.8	6.9	8.3	11.1	13.1	16.2	17.4	17.2	15.3	12.2	8.0	3.3		
	5%	DB	10.2	15.1	18.6	23.6	27.8	34.2	35.9	35.6	31.7	25.5	16.7	9.0		
		MCWB	2.9	5.6	7.3	10.0	12.1	15.3	16.8	16.5	14.6	11.1	6.8	2.2		
	10%	DB	8.0	12.1	16.4	21.1	26.2	32.7	34.4	33.7	30.0	23.0	13.6	6.8		
		MCWB	1.6	4.1	6.4	9.0	11.6	14.5	16.2	16.0	14.0	9.9	5.0	1.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.3	8.5	10.1	12.5	15.4	17.3	19.6	19.0	17.3	13.7	10.9	5.2		
		MCDB	14.1	19.3	21.4	27.8	32.6	36.4	34.3	30.7	29.9	27.6	19.6	12.9		
	2%	WB	4.7	7.3	8.8	11.4	13.9	16.4	18.6	18.1	16.2	12.7	8.7	3.9		
		MCDB	11.4	17.5	19.7	25.2	27.6	35.9	31.9	31.5	30.1	26.9	18.3	10.2		
	5%	WB	3.1	5.8	7.8	10.4	12.8	15.5	17.8	17.5	15.3	11.5	7.0	2.6		
		MCDB	9.5	13.9	17.6	22.9	26.1	33.6	30.9	32.5	29.6	24.6	16.2	8.5		
	10%	WB	1.8	4.3	6.7	9.3	11.8	14.7	17.1	16.8	14.4	10.2	5.3	1.4		
		MCDB	7.3	11.3	15.4	20.7	25.3	31.8	30.9	31.8	28.6	22.3	12.9	6.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	15.1	14.8	15.5	16.7	18.0	20.7	19.7	19.9	20.4	19.7	17.0	14.6		
		MCDBR	19.3	21.3	20.5	21.7	21.8	25.0	22.4	23.1	23.3	24.7	21.8	17.9		
		MCWBR	12.8	12.8	11.4	11.1	10.9	12.2	10.1	10.7	11.4	13.4	13.3	11.8		
		MCDBR	17.9	20.0	18.9	20.7	20.4	24.1	18.5	19.6	20.8	23.3	21.1	16.6		
	5% WB	MCWBR	11.9	12.2	10.7	10.4	10.0	11.7	7.5	8.4	9.9	12.8	13.0	11.1		
(40) Clear-Sky Solar Irradiance	taub		0.249	0.255	0.266	0.294	0.313	0.307	0.345	0.333	0.297	0.278	0.254	0.248		
	taud		2.650	2.646	2.620	2.513	2.488	2.519	2.474	2.501	2.590	2.624	2.655	2.654		
	Ebn at Noon		968	999	1010	988	966	967	927	935	960	956	953	948		
	Edh at Noon		67	77	87	103	108	105	109	103	89	78	66	63		
(44) All-Sky Solar Radiation	RadAvg		2.82	3.69	5.20	6.54	7.50	8.43	7.52	6.97	6.04	4.39	3.20	2.46		
	RadStd		0.26	0.41	0.34	0.36	0.51	0.48	0.40	0.39	0.27	0.33	0.16	0.21		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (13 neighbors)		N/A	N/A	-0.98	N/A	N/A	N/A	N/A	N/A	+105	+48

Nomenclature: See separate page