

RENO-TAHOE, NV, USA

WMO: 724880

Lat: 39.484N

Lon: 119.771W

Elev: 4410

StdP: 12.50

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 23185

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	15.9	19.5	2.6	7.4	39.9	6.3	8.9	39.3	33.6	51.9	28.6	50.7	1.9	290	0.541

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	31.7	96.9	61.3	94.4	60.4	91.9	59.3	64.0	90.0	62.4	88.4	61.0	86.9	10.1	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
54.7	75.2	71.5	51.7	67.0	72.2	49.2	61.1	71.9	31.2	90.1	30.1	88.3	29.0	87.0	69.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 26.1	21.9	18.9	DB	8.2	101.5	5.1	2.5	4.5	103.3	1.5	104.7	-1.4	106.1	-5.1	107.9	(4)
(5)			WB	7.0	66.2	4.8	1.9	3.6	67.6	0.7	68.7	-1.9	69.7	-5.4	71.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	54.5	36.7	39.8	46.0	50.8	59.5	68.9	76.9	74.5	66.2	54.2	43.4	35.7		
	DBStd	15.66	6.87	6.71	6.94	7.59	7.75	7.46	5.06	4.67	6.62	7.14	7.37	7.75		
	HDD50	1663	414	290	160	83	12	1	0	0	1	40	217	445		
	HDD65	4817	877	707	589	428	205	48	1	3	65	338	648	908		
	CDD50	3293	1	3	36	106	306	567	833	761	487	171	19	3		
	CDD65	973	0	0	0	2	34	164	369	298	101	5	0	0		
	CDH74	14075	0	0	6	79	626	2364	5008	4071	1722	199	0	0		
	CDH80	6814	0	0	0	8	186	1074	2728	2089	691	38	0	0		
(14) Wind	WSAvg	6.0	4.3	5.6	7.1	8.0	7.7	7.5	6.8	6.2	5.2	4.6	4.6	4.8		
(15) Precipitation	PrecAvg	7.4	1.1	1.0	0.8	0.4	0.6	0.5	0.2	0.3	0.4	0.4	0.8	1.1		
	PrecMax	13.2	4.1	4.8	2.9	1.3	2.9	1.5	1.1	1.7	2.3	1.7	3.1	3.9		
	PrecMin	4.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
	PrecStd	2.4	1.0	1.0	0.6	0.4	0.7	0.5	0.3	0.4	0.5	0.4	0.7	1.0		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	61.4	66.6	74.1	80.9	89.8	97.1	101.4	98.3	93.6	84.6	71.2	60.9		
		MCWB	45.4	46.1	49.6	53.0	57.5	60.2	63.2	62.2	59.3	55.9	49.7	45.1		
	2%	DB	56.6	61.2	69.3	76.0	85.1	93.0	98.1	95.8	90.1	79.3	66.6	56.3		
		MCWB	43.4	44.1	47.1	50.9	55.6	59.2	61.7	61.1	57.6	53.6	47.3	43.5		
	5%	DB	52.6	57.1	65.3	71.8	81.1	89.9	95.5	93.3	87.4	75.2	62.0	52.6		
		MCWB	41.0	42.2	45.5	49.0	54.3	58.0	61.0	59.6	57.0	51.3	45.4	42.0		
	10%	DB	49.0	52.9	61.2	67.4	76.8	86.7	92.8	90.8	84.4	71.0	57.6	49.0		
		MCWB	39.6	40.8	44.2	47.0	52.1	56.8	60.2	58.6	55.9	49.5	43.5	40.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.2	48.3	50.9	54.5	59.7	63.3	66.4	65.4	63.5	57.3	51.3	48.5		
		MCDB	58.2	61.9	70.8	77.4	85.7	91.7	93.3	93.9	84.3	80.3	68.4	57.3		
	2%	WB	44.6	45.7	48.5	51.7	57.0	61.0	64.5	63.4	60.7	55.0	48.5	45.4		
		MCDB	53.3	58.7	66.4	72.9	80.6	88.3	90.2	89.6	83.6	75.4	63.4	53.5		
	5%	WB	42.2	43.4	46.6	49.9	55.3	59.4	63.1	61.6	58.7	52.7	46.4	42.8		
		MCDB	50.6	54.8	62.9	69.6	78.1	85.9	89.3	87.7	82.2	72.1	60.0	51.1		
	10%	WB	40.3	41.4	44.8	48.0	53.4	57.8	61.8	60.1	56.8	50.6	44.4	40.5		
		MCDB	48.0	51.7	59.8	65.6	74.2	83.6	87.8	86.0	81.0	68.3	56.3	48.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	20.4	21.7	24.3	24.7	26.0	29.3	31.7	32.2	31.7	29.0	24.4	19.6		
		MCDBR	26.8	29.7	32.4	32.7	32.6	33.6	33.4	34.5	35.8	36.0	31.7	24.2		
	5% WB	MCWBR	15.3	15.5	15.0	14.1	12.5	11.7	10.8	11.8	13.2	15.4	16.1	13.7		
		MCWBR	23.2	26.3	29.5	30.4	30.8	32.7	31.3	32.5	33.4	32.8	29.3	21.3		
(40) Clear-Sky Solar Irradiance	taub		0.267	0.282	0.291	0.305	0.320	0.322	0.324	0.321	0.305	0.293	0.269	0.265		
		taud	2.548	2.514	2.512	2.478	2.467	2.476	2.497	2.478	2.533	2.562	2.590	2.555		
	Ebn at Noon		293	302	309	308	304	301	300	299	299	293	290	285		
		Edh at Noon	23	27	30	34	35	35	34	33	30	26	22	21		
(44) All-Sky Solar Radiation	RadAvg		742	1031	1478	1932	2280	2615	2560	2312	1888	1334	867	630		
	RadStd		102	116	120	149	183	144	121	101	73	91	57	87		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+1.21	N/A	N/A	+1.15	N/A	N/A	N/A	-243	+369	+221
(47) Regional (17 neighbors)		+0.65	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+169	+77

Nomenclature: See separate page