

FALLON NAS, NV, USA

WMO: 724885

Lat: 39.417N

Lon: 118.717W

Elev: 1199

StdP: 87.73

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 93102

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-12.3	-9.7	-18.1	0.9	-0.6	-16.1	1.1	0.0	11.9	11.1	10.4	9.3	1.3	160	0.536

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.8	37.4	16.1	36.1	15.6	34.8	15.2	17.6	32.3	16.9	31.9	16.2	31.5	3.3	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.9	10.8	20.8	11.4	9.7	20.4	9.8	8.7	20.7	53.5	32.1	51.3	31.7	49.2	31.2	20.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.2	9.0	7.6	DB	-16.6	39.6	3.2	1.3	-18.9	40.6	-20.8	41.4	-22.6	42.2	-24.9	43.1	(4)
(5)			WB	-17.2	18.9	3.2	0.7	-19.5	19.4	-21.4	19.8	-23.2	20.2	-25.5	20.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	12.3	1.6	4.3	8.0	10.9	15.5	20.7	25.3	24.0	19.2	11.8	5.6	0.7		
	DBStd	9.16	4.44	3.97	3.84	4.11	4.03	3.99	2.62	2.52	3.94	4.31	4.24	4.98		
	HDD10.0	1016	261	163	85	38	5	1	0	0	1	30	141	291		
	HDD18.3	2761	518	393	320	224	106	23	1	1	38	207	382	548		
	CDD10.0	1872	1	3	23	65	175	322	475	435	277	86	9	2		
	CDD18.3	575	0	0	0	1	18	94	217	178	63	4	0	0		
	CDH23.3	9845	0	0	8	86	460	1704	3443	2829	1191	124	1	0		
	CDH26.7	5266	0	0	0	14	153	874	2047	1603	543	32	0	0		
(14) Wind	WSAvg	2.7	2.3	2.8	3.2	3.4	3.3	3.1	2.8	2.6	2.4	2.3	2.3	2.4		
(15) Precipitation	PrecAvg	128	12	13	11	13	15	15	6	8	6	8	12	10		
	PrecMax	194	42	60	37	69	44	77	32	42	22	57	40	32		
	PrecMin	52	1	0	0	0	0	0	0	0	0	0	0	0		
	PrecStd	35	11	12	10	13	15	17	7	11	7	12	10	8		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.1	19.6	24.3	28.6	32.7	37.9	39.7	38.1	35.2	30.3	22.0	16.9		
		MCWB	8.0	8.2	9.6	12.1	13.4	15.8	16.6	16.1	15.3	13.6	9.7	7.8		
	2%	DB	13.4	17.3	21.8	25.8	30.4	35.5	37.9	36.6	33.4	26.6	19.5	14.0		
		MCWB	6.2	7.6	8.5	10.8	12.9	15.1	16.2	15.8	14.4	12.0	8.8	6.7		
	5%	DB	11.3	15.0	19.6	23.4	28.3	33.7	36.7	35.4	32.0	24.0	17.2	11.3		
		MCWB	4.9	6.6	7.8	9.6	12.3	14.5	15.9	15.3	14.1	10.7	7.8	5.5		
	10%	DB	9.1	12.5	17.4	20.9	25.9	32.1	35.4	34.1	30.2	21.7	14.5	8.7		
		MCWB	4.0	5.5	7.0	8.9	11.4	13.9	15.6	14.9	13.6	9.7	6.8	3.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.2	9.6	10.3	12.9	15.0	17.2	18.8	18.1	17.4	14.6	11.0	9.0		
		MCDB	14.7	17.4	22.0	27.0	28.6	33.3	32.4	32.7	28.9	26.5	19.9	15.5		
	2%	WB	7.0	8.3	9.1	11.4	13.8	16.2	17.9	17.1	16.0	13.1	9.6	7.3		
		MCDB	12.0	15.7	20.0	23.4	26.6	32.9	32.4	32.0	28.7	23.3	18.1	13.1		
	5%	WB	5.5	7.1	8.3	10.4	12.9	15.3	17.3	16.5	15.1	11.8	8.3	5.8		
		MCDB	10.2	13.9	18.5	21.6	25.4	30.7	32.4	31.9	29.0	21.2	15.9	10.7		
	10%	WB	4.3	5.8	7.4	9.3	12.0	14.5	16.6	15.7	14.1	10.6	7.1	4.3		
		MCDB	8.7	12.0	16.6	19.6	23.9	29.4	31.8	31.4	28.8	19.9	13.8	8.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	13.1	14.0	16.0	16.1	16.4	18.8	19.8	20.0	19.5	17.7	15.4	12.6		
		MCDBR	15.9	17.5	19.7	20.2	20.3	21.5	21.0	20.9	21.6	20.5	18.9	14.6		
		MCWBR	9.7	9.8	9.8	9.1	7.8	7.6	6.9	7.5	8.9	9.6	10.4	8.8		
		MCDBR	13.8	15.9	17.9	18.3	18.0	19.8	18.3	18.9	19.6	17.7	17.6	13.6		
	5% WB	MCWBR	8.9	9.2	9.1	8.3	7.0	7.0	6.1	7.1	8.0	8.3	10.0	8.5		
(40) Clear-Sky Solar Irradiance	taub		0.249	0.257	0.266	0.292	0.309	0.306	0.315	0.307	0.290	0.266	0.251	0.247		
	taud		2.641	2.610	2.588	2.482	2.455	2.486	2.493	2.497	2.536	2.635	2.644	2.635		
	Ebn at Noon		955	987	1004	986	968	966	954	957	960	962	945	932		
	Edh at Noon		66	78	89	105	111	108	106	103	92	75	65	61		
(44) All-Sky Solar Radiation	RadAvg		2.37	3.38	4.81	6.23	7.25	8.25	7.95	7.18	5.96	4.24	2.79	2.00		
	RadStd		0.34	0.29	0.29	0.35	0.55	0.40	0.35	0.31	0.18	0.27	0.14	0.24		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(47) Regional (8 neighbors)		+0.36	N/A	N/A	+0.51	N/A	N/A	N/A	N/A	+92	+46		

Nomenclature: See separate page