

MONTEREY, CA, USA

WMO: 724915

Lat: 36.588N

Lon: 121.845W

Elev: 165

StdP: 14.61

Time Zone: -8.00 (NAP)

Period: 98-19

WBAN: 23259

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	36.8	38.9	21.0	15.9	48.7	25.1	19.3	49.3	20.5	54.7	17.9	55.7	4.9	100	0.473

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	14.1	79.2	60.0	74.5	59.4	71.6	59.2	63.4	72.5	62.2	70.6	61.2	68.8	5.7	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
60.3	78.6	65.8	58.7	74.2	64.7	57.4	70.8	63.7	28.8	72.2	27.9	70.5	27.1	68.8	82.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
16.9	14.8	12.6	DB	32.7	90.0	2.3	5.1	31.0	93.7	29.7	96.6	28.4	99.5	26.8	103.2
			WB	29.4	67.4	2.4	4.4	27.6	70.6	26.2	73.2	24.8	75.7	23.1	78.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	56.7	52.1	52.7	53.7	54.7	56.8	59.4	60.6	61.5	61.8	59.5	55.2	51.6
	DBStd	5.43	4.64	4.57	4.05	4.09	3.39	3.35	2.88	3.05	4.20	4.71	4.43	4.42
	HDD50	103	31	20	9	3	0	0	0	0	0	0	6	34
	HDD65	3113	402	346	351	314	257	175	139	116	117	185	296	415
	CDD50	2530	94	95	124	143	211	281	330	357	353	296	163	83
	CDD65	64	0	0	1	4	4	5	4	9	20	15	2	0
	CDH74	462	7	8	10	43	34	53	11	31	122	120	23	0
	CDH80	126	1	1	1	12	11	20	0	4	39	33	4	0
(14) Wind	WSAvg	5.8	4.9	5.7	6.0	6.8	7.0	6.9	6.4	5.9	5.1	4.8	4.7	5.1
(15) Precipitation	PrecAvg	17.9	3.6	3.5	2.7	1.3	0.5	0.2	0.0	0.0	0.0	0.9	1.8	3.3
	PrecMax	35.8	11.8	14.1	8.4	3.8	2.4	1.1	0.1	0.2	0.4	3.5	6.4	8.5
	PrecMin	7.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	6.0	3.1	2.8	2.3	1.1	0.6	0.2	0.0	0.0	0.1	1.1	1.5	2.2
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	73.7	74.5	74.1	80.1	78.6	81.1	75.2	78.0	85.2	84.1	77.2	69.5
		MCWB	54.3	57.0	56.5	59.0	58.9	60.9	62.7	62.9	63.7	60.2	58.3	53.5
	2%	DB	67.0	67.9	67.3	69.7	69.2	72.3	71.5	72.5	76.5	76.6	69.9	64.5
		MCWB	52.7	55.2	55.3	56.4	57.6	60.2	61.2	61.6	61.4	58.3	56.0	54.5
	5%	DB	63.1	63.6	63.7	64.2	65.2	68.3	68.5	69.8	72.2	71.0	65.8	62.2
		MCWB	53.4	54.1	54.7	54.9	56.3	58.9	60.1	60.9	60.6	57.9	55.5	54.5
	10%	DB	59.8	60.5	61.1	61.4	63.0	65.5	65.9	67.1	69.3	67.3	63.1	59.7
		MCWB	53.1	53.4	54.0	53.6	55.5	57.5	58.9	59.9	60.0	57.2	55.3	53.2
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	58.7	60.3	60.0	60.8	61.9	63.8	63.8	64.5	66.2	63.7	61.9	60.1
		MCDB	62.9	66.2	69.1	74.4	72.5	76.5	73.2	73.3	77.6	73.0	67.5	63.5
	2%	WB	57.0	57.8	57.9	57.8	59.0	61.1	61.9	62.7	63.4	61.9	59.5	58.1
		MCDB	61.3	64.1	64.2	66.4	66.6	70.1	70.0	70.3	72.6	70.0	65.6	61.7
	5%	WB	55.3	55.9	56.3	56.1	57.2	59.4	60.5	61.4	62.0	60.2	57.9	56.4
		MCDB	60.2	61.6	61.9	63.1	64.1	66.9	67.1	68.7	70.3	67.8	63.7	60.0
	10%	WB	53.7	54.2	54.6	54.4	55.8	58.1	59.3	60.2	60.5	58.7	56.4	54.5
		MCDB	58.8	59.3	59.8	60.5	62.1	64.6	64.9	66.3	67.8	65.8	61.7	58.2
(35) Mean Daily Temperature Range	5% DB	MDBR	16.3	14.8	14.3	13.3	12.3	12.9	11.8	11.9	14.1	16.0	16.2	15.8
		MCDBR	21.9	21.0	19.6	19.5	17.8	18.8	15.4	15.5	20.8	23.6	21.3	19.0
		MCWBR	13.1	12.2	11.4	10.9	9.4	9.5	7.4	7.8	10.6	12.9	12.4	11.7
	5% WB	MCDBR	16.5	17.1	16.8	17.1	16.3	17.2	14.7	14.6	18.3	18.8	16.8	13.4
		MCWBR	10.8	10.7	10.5	10.1	9.1	9.0	7.1	7.5	9.5	11.1	10.8	9.5
(40) Clear-Sky Solar Irradiance	taub		0.317	0.321	0.326	0.349	0.359	0.349	0.353	0.336	0.345	0.323	0.310	0.314
	taud		2.567	2.562	2.545	2.461	2.447	2.487	2.496	2.536	2.504	2.591	2.593	2.587
	Ebn at Noon		280	292	299	296	292	294	292	296	289	287	281	274
	Edh at Noon		24	27	30	35	36	35	34	32	31	26	23	23
(44) All-Sky Solar Radiation	RadAvg		836	1109	1558	1967	2245	2422	2234	2018	1761	1333	958	735
	RadStd		89	119	124	164	136	106	75	93	74	80	51	90

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	+0.86	N/A	-2.84	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (37 neighbors)	+0.72	N/A	-2.18	N/A	N/A	N/A	N/A	-223	+263	+63

Nomenclature: See separate page