

MONTEREY, CA, USA

WMO: 724915

Lat: 36.588N

Lon: 121.845W

Elev: 50

StdP: 100.72

Time Zone: -8.00 (NAP)

Period: 98-19

WBAN: 23259

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	2.7	3.9	-6.1	2.3	9.3	-3.8	2.8	9.6	9.1	12.6	8.0	13.2	2.2	100	0.473

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	7.8	26.2	15.6	23.6	15.2	22.0	15.1	17.5	22.5	16.8	21.4	16.2	20.5	2.6	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
15.7	11.2	18.8	14.8	10.6	18.2	14.1	10.1	17.6	49.2	22.3	47.1	21.4	45.2	20.4	27.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.5	6.6	5.6	0.4	32.2	1.3	2.8	-0.5	34.3	-1.3	35.9	-2.0	37.5	-2.9	39.5		
(5)			-1.5	19.7	1.3	2.5	-2.4	21.4	-3.2	22.9	-4.0	24.3	-5.0	26.0	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	13.7	11.1	11.5	12.1	12.6	13.8	15.2	15.9	16.4	16.5	15.3	12.9	10.9	(6)
(7)		DBStd	3.01	2.58	2.54	2.25	2.27	1.88	1.86	1.60	1.69	2.33	2.62	2.46	2.45	(7)
(8)		HDD10.0	57	17	11	5	2	0	0	0	0	0	0	3	19	(8)
(9)		HDD18.3	1729	223	192	195	174	143	97	77	64	65	103	164	231	(9)
(10)		CDD10.0	1406	52	53	69	79	117	156	183	198	196	164	91	46	(10)
(11)		CDD18.3	36	0	0	1	2	2	3	2	5	11	8	1	0	(11)
(12)		CDH23.3	257	4	4	6	24	19	29	6	17	68	67	13	0	(12)
(13)		CDH26.7	70	1	1	1	7	6	11	0	2	22	18	2	0	(13)
(14)	Wind	WSAvg	2.6	2.2	2.5	2.7	3.0	3.1	3.1	2.8	2.6	2.3	2.2	2.1	2.3	(14)
(15)	Precipitation	PrecAvg	455	92	89	69	34	12	4	1	1	23	46	83	(15)	
(16)		PrecMax	910	300	359	214	97	61	27	3	5	11	88	162	215	(16)
(17)		PrecMin	186	0	0	0	0	0	0	0	0	0	0	0	0	(17)
(18)		PrecStd	153	78	72	58	27	15	6	1	1	2	28	38	57	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	23.2	23.6	23.4	26.7	25.9	27.3	24.0	25.6	29.5	28.9	25.1	20.8	(19)
(20)			MCWB	12.4	13.9	13.6	15.0	15.0	16.0	17.1	17.1	17.6	15.7	14.6	11.9	(20)
(21)		2%	DB	19.5	20.0	19.6	20.9	20.7	22.4	21.9	22.5	24.7	24.8	21.1	18.0	(21)
(22)			MCWB	11.5	12.9	12.9	13.6	14.2	15.7	16.2	16.5	16.3	14.6	13.4	12.5	(22)
(23)		5%	DB	17.3	17.5	17.6	17.9	18.4	20.2	20.3	21.0	22.4	21.7	18.8	16.8	(23)
(24)			MCWB	11.9	12.3	12.6	12.7	13.5	14.9	15.6	16.1	15.9	14.4	13.0	12.5	(24)
(25)		10%	DB	15.5	15.8	16.2	16.3	17.2	18.6	18.9	19.5	20.7	19.6	17.3	15.4	(25)
(26)			MCWB	11.7	11.9	12.2	12.0	13.0	14.1	15.0	15.5	15.6	14.0	12.9	11.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.8	15.7	15.5	16.0	16.6	17.6	17.7	18.0	19.0	17.6	16.6	15.6	(27)
(28)			MCDWB	17.2	19.0	20.6	23.6	22.5	24.7	22.9	22.9	25.3	22.8	19.7	17.5	(28)
(29)		2%	WB	13.9	14.3	14.4	14.4	15.0	16.2	16.6	17.0	17.5	16.6	15.3	14.5	(29)
(30)			MCDWB	16.3	17.8	17.9	19.1	19.2	21.2	21.1	21.3	22.6	21.1	18.6	16.5	(30)
(31)		5%	WB	12.9	13.3	13.5	13.4	14.0	15.2	15.8	16.3	16.6	15.7	14.4	13.5	(31)
(32)			MCDWB	15.7	16.5	16.6	17.3	17.8	19.4	19.5	20.4	21.3	19.9	17.6	15.6	(32)
(33)		10%	WB	12.1	12.4	12.6	12.5	13.2	14.5	15.2	15.7	15.8	14.8	13.6	12.5	(33)
(34)			MCDWB	14.9	15.2	15.4	15.8	16.7	18.1	18.3	19.1	19.9	18.8	16.5	14.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.1	8.2	7.9	7.4	6.8	7.1	6.6	6.6	7.8	8.9	9.0	8.8	(35)
(36)			MCDBR	12.2	11.6	10.9	10.8	9.9	10.5	8.6	8.6	11.5	13.1	11.8	10.6	(36)
(37)			MCWBR	7.3	6.8	6.3	6.1	5.2	5.3	4.1	4.3	5.9	7.2	6.9	6.5	(37)
(38)		5% WB	MCDWB	9.1	9.5	9.3	9.5	9.1	9.6	8.2	8.1	10.2	10.4	9.3	7.5	(38)
(39)			MCWBR	6.0	6.0	5.8	5.6	5.0	5.0	4.0	4.2	5.3	6.2	6.0	5.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.317	0.321	0.326	0.349	0.359	0.349	0.353	0.336	0.345	0.323	0.310	0.314	(40)	
(41)		taud	2.567	2.562	2.545	2.461	2.447	2.487	2.496	2.536	2.504	2.591	2.593	2.587	(41)	
(42)		Ebn at Noon	883	921	944	933	922	928	921	934	910	906	885	863	(42)	
(43)		Edh at Noon	77	86	96	110	113	109	107	100	98	82	74	71	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.63	3.50	4.91	6.20	7.08	7.64	7.04	6.36	5.55	4.20	3.02	2.32	(44)	
(45)		RadStd	0.28	0.38	0.39	0.52	0.43	0.33	0.24	0.29	0.23	0.25	0.16	0.28	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.48	N/A	-1.58	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (37 neighbors)		+0.40	N/A	-1.21	N/A	N/A	N/A	N/A	-124	+146	+35

Nomenclature: See separate page