

SAN JOSE INTL, CA, USA

WMO: 724945

Lat: 37.359N

Lon: 121.924W

Elev: 51

StdP: 14.67

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 23293

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	36.0	38.3	19.6	14.7	52.8	24.3	18.5	53.7	24.8	54.5	21.7	54.5	2.4	150	0.456

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	20.8	91.4	66.1	87.7	65.2	83.9	64.2	68.9	85.6	67.4	82.9	66.1	80.7	10.3	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
62.9	86.0	74.8	61.3	81.1	73.2	60.3	78.2	71.9	33.0	85.5	31.7	82.5	30.7	80.8	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.7	17.9	16.3	32.1	98.9	3.1	3.4	29.9	101.3	28.1	103.3	26.4	105.3	24.1	107.7
			29.5	71.5	2.9	2.6	27.4	73.4	25.7	75.0	24.1	76.5	22.0	78.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	60.9	51.6	53.5	56.6	58.8	62.9	67.1	69.5	69.8	68.9	64.1	56.6	51.3
	DBStd	8.27	4.60	4.80	4.93	5.37	5.15	5.02	4.07	3.86	4.95	4.75	4.96	4.71
	HDD50	106	36	18	5	1	0	0	0	0	0	0	7	39
	HDD65	2102	416	321	262	199	104	27	4	2	11	75	256	425
	CDD50	4097	85	117	211	266	399	514	606	613	568	436	204	78
	CDD65	619	0	0	3	14	38	91	145	150	129	46	3	0
	CDH74	5261	0	6	51	193	403	863	1103	1062	1077	469	34	0
	CDH80	1765	0	0	4	52	140	321	342	337	431	134	4	0
	WSAvg	6.5	5.0	6.2	6.7	7.5	7.8	7.9	7.4	7.0	6.2	5.5	4.9	5.3
	PrecAvg	14.1	2.8	2.2	2.3	1.2	0.2	0.0	0.0	0.1	0.2	0.9	2.2	2.0
(15) Precipitation	PrecMax	32.6	7.4	6.6	6.4	3.9	1.7	0.6	0.7	0.7	1.0	4.6	6.2	5.0
	PrecMin	7.2	0.2	0.2	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2	0.0
	PrecStd	5.4	2.0	2.0	1.5	1.1	0.4	0.1	0.2	0.2	0.4	1.0	1.7	1.2
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	69.8	74.9	79.8	86.4	91.1	95.0	94.7	93.9	95.2	88.7	79.0	67.7
		MCWB	53.6	58.1	60.2	62.9	65.3	67.6	69.2	66.7	65.1	62.5	59.8	55.2
	2%	DB	65.2	69.5	74.2	79.6	83.7	88.4	88.2	88.4	90.3	83.8	72.8	64.2
		MCWB	54.6	56.1	57.6	60.4	62.2	65.9	67.6	66.5	64.6	60.6	57.6	54.0
	5%	DB	62.8	65.3	70.3	74.1	78.3	83.1	83.5	83.4	84.9	79.3	69.2	62.1
		MCWB	53.9	54.8	56.6	58.6	61.3	64.6	66.3	65.6	63.4	59.1	56.5	53.8
	10%	DB	60.4	62.4	66.5	69.6	73.4	78.7	80.1	79.8	79.8	74.8	65.6	60.0
		MCWB	52.9	53.7	55.1	56.9	59.6	63.2	65.4	65.0	63.1	58.8	55.3	53.0
	0.4%	WB	59.9	61.2	62.3	65.2	67.9	70.6	71.0	70.3	70.1	65.9	62.9	60.2
		MCDB	63.9	69.1	75.7	81.4	87.0	89.3	90.4	86.8	87.2	80.3	73.0	64.5
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	57.4	58.7	60.0	62.1	64.8	67.7	68.6	68.1	66.7	63.6	60.5	58.2
		MCDB	61.7	65.9	70.3	76.4	79.7	84.7	84.9	83.5	82.1	77.3	68.2	61.7
	5%	WB	55.5	56.7	58.2	59.7	62.5	65.8	67.2	66.6	65.2	62.0	59.0	56.3
		MCDB	60.0	63.4	67.4	71.6	75.6	81.2	81.8	80.9	80.9	74.3	66.0	59.8
	10%	WB	53.8	54.9	56.4	57.8	60.4	63.8	65.8	65.3	63.9	60.4	57.4	54.2
		MCDB	58.6	60.9	64.8	67.8	71.7	77.0	79.2	78.5	78.0	71.1	63.9	58.3
(35) Mean Daily Temperature Range	5% DB	MDBR	16.0	16.3	18.2	19.0	19.4	21.3	21.1	20.8	21.6	21.0	17.8	15.6
		MCDBR	19.9	21.9	24.7	27.3	27.7	28.6	26.6	27.2	29.8	28.2	22.9	18.3
		MCWBR	11.2	11.6	12.3	12.9	11.9	11.7	10.7	10.4	10.9	11.4	11.1	10.2
	5% WB	MCDBR	13.4	17.4	20.8	23.3	23.6	25.2	23.6	23.4	24.2	22.5	17.8	11.0
		MCWBR	8.9	10.2	11.3	12.1	11.4	11.7	10.5	9.9	10.0	10.0	9.7	7.6
(40) Clear-Sky Solar Irradiance	taub		0.324	0.332	0.337	0.360	0.372	0.363	0.367	0.350	0.356	0.333	0.322	0.323
	taud		2.533	2.511	2.489	2.398	2.385	2.418	2.418	2.459	2.432	2.534	2.542	2.546
	Ebn at Noon		275	286	295	292	288	290	288	292	284	282	273	267
	Edh at Noon		25	29	32	37	38	37	36	34	33	27	24	23
(44) All-Sky Solar Radiation	RadAvg		774	1073	1518	1964	2277	2496	2371	2127	1796	1327	915	685
	RadStd		102	125	134	161	141	101	72	82	67	80	54	95

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-241	+337	+108
(47) Regional (44 neighbors)	N/A	N/A	N/A	-2.11	N/A	N/A	N/A	N/A	-194	+239	N/A

Nomenclature: See separate page