

SAN JOSE INTL, CA, USA

WMO: 724945

Lat: 37.359N

Lon: 121.924W

Elev: 16

StdP: 101.14

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 23293

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	2.2	3.5	-6.9	2.1	11.5	-4.3	2.6	12.1	11.1	12.5	9.7	12.5	1.1	150	0.456

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.5	33.0	19.0	31.0	18.5	28.9	17.9	20.5	29.8	19.7	28.3	19.0	27.1	4.6	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.2	12.3	23.8	16.3	11.6	22.9	15.7	11.2	22.2	58.8	29.7	55.9	28.1	53.6	27.1	26.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8.8	8.0	7.3	0.1	37.2	1.7	1.9	-1.2	38.5	-2.2	39.6	-3.1	40.7	-4.4	42.1
			-1.4	22.0	1.6	1.5	-2.5	23.0	-3.5	23.9	-4.4	24.7	-5.6	25.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	16.1	10.9	12.0	13.7	14.9	17.1	19.5	20.9	21.0	20.5	17.8	13.7	10.7	(6)
	DBStd	4.59	2.56	2.67	2.74	2.98	2.86	2.79	2.26	2.15	2.75	2.64	2.76	2.62	(7)
	HDD10.0	59	20	10	3	1	0	0	0	0	0	0	4	22	(8)
	HDD18.3	1168	231	178	146	111	58	15	2	1	6	42	142	236	(9)
	CDD10.0	2276	47	65	117	148	222	286	337	341	316	242	113	43	(10)
	CDD18.3	344	0	0	2	8	21	51	81	83	72	26	2	0	(11)
	CDH23.3	2923	0	3	28	107	224	479	613	590	598	261	19	0	(12)
	CDH26.7	981	0	0	2	29	78	178	190	187	239	74	2	0	(13)
(14) Wind	WSAvg	2.9	2.2	2.8	3.0	3.4	3.5	3.5	3.3	3.1	2.8	2.5	2.2	2.4	(14)
(15) Precipitation	PrecAvg	357	71	56	59	30	5	1	1	2	6	23	56	50	(15)
	PrecMax	827	188	168	163	99	43	14	19	18	26	117	157	127	(16)
	PrecMin	184	4	4	2	1	0	0	0	0	0	0	4	1	(17)
	PrecStd	137	51	51	39	29	9	3	4	5	9	25	42	30	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	21.0	23.8	26.6	30.2	32.8	35.0	34.8	34.4	35.1	31.5	26.1	19.8	(19)
		MCWB	12.0	14.5	15.7	17.2	18.5	19.8	20.7	19.3	18.4	16.9	15.4	12.9	(20)
	2%	DB	18.5	20.9	23.4	26.4	28.7	31.3	31.2	31.3	32.4	28.8	22.7	17.9	(21)
		MCWB	12.6	13.4	14.2	15.8	16.8	18.9	19.8	19.2	18.1	15.9	14.2	12.2	(22)
	5%	DB	17.1	18.5	21.3	23.4	25.7	28.4	28.6	28.5	29.4	26.3	20.7	16.7	(23)
		MCWB	12.2	12.6	13.7	14.8	16.3	18.1	19.0	18.7	17.5	15.0	13.6	12.1	(24)
	10%	DB	15.8	16.9	19.2	20.9	23.0	26.0	26.7	26.5	26.6	23.8	18.7	15.5	(25)
		MCWB	11.6	12.0	12.8	13.8	15.3	17.3	18.6	18.3	17.3	14.9	13.0	11.7	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.5	16.2	16.8	18.4	20.0	21.4	21.7	21.3	21.2	18.8	17.2	15.7	(27)
		MCDB	17.7	20.6	24.3	27.4	30.6	31.8	32.5	30.4	30.7	26.8	22.8	18.1	(28)
	2%	WB	14.1	14.8	15.5	16.7	18.2	19.9	20.3	20.0	19.3	17.6	15.9	14.6	(29)
		MCDB	16.5	18.8	21.3	24.6	26.5	29.3	29.4	28.6	27.9	25.2	20.1	16.5	(30)
	5%	WB	13.1	13.7	14.5	15.4	16.9	18.8	19.5	19.2	18.5	16.7	15.0	13.5	(31)
		MCDB	15.5	17.5	19.7	22.0	24.2	27.3	27.7	27.2	27.2	23.5	18.9	15.5	(32)
	10%	WB	12.1	12.7	13.6	14.3	15.8	17.7	18.8	18.5	17.7	15.8	14.1	12.3	(33)
		MCDB	14.8	16.1	18.2	19.9	22.1	25.0	26.2	25.9	25.6	21.7	17.7	14.6	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	8.9	9.0	10.1	10.5	10.8	11.8	11.7	11.5	12.0	11.6	9.9	8.7	(35)
		MCDBR	11.1	12.2	13.7	15.2	15.4	15.9	14.8	15.1	16.6	15.7	12.7	10.2	(36)
	5% WB	MCWBR	6.2	6.5	6.8	7.1	6.6	6.5	5.9	5.8	6.1	6.3	6.1	5.7	(37)
		MCWBR	7.5	9.6	11.5	12.9	13.1	14.0	13.1	13.0	13.4	12.5	9.9	6.1	(38)
(40) Clear-Sky Solar Irradiance	taub		0.324	0.332	0.337	0.360	0.372	0.363	0.367	0.350	0.356	0.333	0.322	0.323	(40)
		taud	2.533	2.511	2.489	2.398	2.385	2.418	2.418	2.459	2.432	2.534	2.542	2.546	(41)
	Ebn at Noon		866	903	929	920	909	913	907	919	895	889	861	841	(42)
		Edh at Noon	78	90	100	116	120	116	115	108	105	86	76	73	(43)
(44) All-Sky Solar Radiation	RadAvg		2.44	3.38	4.79	6.19	7.18	7.87	7.47	6.71	5.66	4.18	2.88	2.16	(44)
	RadStd		0.32	0.39	0.42	0.51	0.44	0.32	0.23	0.26	0.21	0.25	0.17	0.30	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (44 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-134	+187	+60
	N/A	N/A	-1.17	N/A	N/A	N/A	N/A	-108	+133	N/A

Nomenclature: See separate page