

CAIRO, IL, USA

WMO: 724975

Lat: 37.064N

Lon: 89.219W

Elev: 98

StdP: 100.16

Time Zone: -6.00 (NAC)

Period: 04-19

WBAN: 93809

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -10.9	(c) -7.7	(d) -16.8	(e) 0.9	(f) -9.2	(g) -14.1	(h) 1.1	(i) -6.4	(j) 11.1	(k) 6.8	(l) 9.8	(m) 5.6	(n) 2.5	(o) 0	(p) 0.428

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.1	35.2	24.5	33.9	24.3	32.7	24.2	26.8	32.0	26.1	31.2	25.5	30.4	3.0	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.3	20.7	29.6	24.7	20.0	28.9	24.0	19.1	28.1	84.3	31.9	81.2	31.1	78.4	30.7	35.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 8.9	(b) 7.8	(c) 7.0	(e) -15.1	(f) 37.8	(g) 3.9	(h) 3.8	(i) -17.8	(j) 40.4	(k) -20.1	(l) 42.6	(m) -22.3	(n) 44.8	(o) -25.1	(p) 47.5		
(4) 8.9	(5) 7.8	(6) 7.0	(7) -15.3	(8) 28.5	(9) 3.9	(10) 2.0	(11) -18.1	(12) 29.9	(13) -20.3	(14) 31.1	(15) -22.5	(16) 32.2	(17) -25.3	(18) 33.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	15.2	2.4	4.1	9.9	15.6	20.9	25.8	26.5	25.4	21.8	15.6	8.8	4.4		
	DBStd	9.80	6.02	6.12	5.71	4.88	4.24	2.82	2.68	2.74	3.54	4.94	5.13	5.35		
	HDD10.0	786	244	181	73	11	0	0	0	0	0	8	82	188		
	HDD18.3	2139	493	398	267	108	26	1	0	0	11	116	287	432		
	CDD10.0	2668	9	17	70	178	337	474	511	479	353	180	46	14		
	CDD18.3	979	0	0	6	26	105	224	252	221	114	31	2	0		
	CDH23.3	9689	0	0	33	206	928	2384	2658	2139	1039	291	11	0		
	CDH26.7	4032	0	0	3	38	326	1081	1191	927	388	79	1	0		
(14) Wind	WSAvg	2.7	3.5	3.4	3.6	3.5	2.8	2.3	1.9	1.6	1.7	2.4	2.8	3.0		
(15) Precipitation	PrecAvg	1216	75	92	119	116	131	95	97	104	89	77	103	111		
	PrecMax	1537	252	285	322	240	259	227	234	295	239	200	206	287		
	PrecMin	757	18	27	28	32	46	13	10	5	13	0	29	18		
	PrecStd	212	55	57	69	59	58	53	54	62	55	53	55	70		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	19.1	22.0	27.1	29.8	33.8	37.4	37.7	37.0	33.9	31.2	24.9	20.1		
		MCWB	16.6	17.2	18.3	20.1	21.5	23.3	25.2	25.3	24.2	22.3	17.3	17.7		
	2%	DB	17.4	19.1	23.8	27.6	31.9	35.1	35.1	34.8	32.3	28.9	22.2	17.8		
		MCWB	15.0	15.8	17.1	18.9	21.8	23.7	25.2	25.0	24.0	21.1	16.1	15.4		
	5%	DB	14.5	16.5	21.4	25.9	30.1	33.7	33.6	32.9	30.9	27.0	19.9	15.9		
		MCWB	11.7	13.0	16.0	18.0	20.7	23.2	25.2	25.0	23.4	19.2	15.7	13.1		
	10%	DB	12.2	13.9	18.9	23.8	28.4	32.3	32.3	31.8	29.0	24.1	17.5	12.9		
		MCWB	9.7	10.9	14.3	17.2	20.4	23.0	24.9	24.6	22.3	18.2	13.3	10.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	17.1	18.4	19.7	22.1	24.1	26.6	27.8	27.9	25.9	23.8	20.0	17.9		
		MCDB	18.5	21.1	24.1	27.2	29.8	31.7	32.9	33.9	31.3	29.0	22.3	19.4		
	2%	WB	15.4	16.4	18.2	20.7	23.1	25.6	26.9	26.8	25.1	22.3	17.9	16.3		
		MCDB	17.2	19.3	22.8	25.5	28.6	31.1	31.9	32.3	30.6	26.8	20.5	17.8		
	5%	WB	12.6	14.1	16.7	19.4	22.3	25.0	26.3	26.0	24.3	21.1	15.9	13.6		
		MCDB	14.0	15.8	20.5	23.9	27.6	30.6	31.3	31.1	29.1	24.7	18.8	15.3		
	10%	WB	9.7	11.0	15.2	18.2	21.6	24.4	25.6	25.3	23.4	19.5	13.8	11.0		
		MCDB	11.3	13.6	18.1	22.4	26.5	30.0	30.4	29.9	27.5	23.2	16.9	12.8		
(35) Mean Daily Temperature Range	MDBR		8.7	9.1	10.2	11.3	10.9	10.9	10.1	10.8	12.2	12.5	10.8	8.6		
	5% DB	MCDBR	11.5	12.3	12.8	13.2	12.9	12.8	11.4	12.4	13.7	14.5	13.7	11.3		
		MCWBR	9.7	9.4	8.1	6.6	4.8	4.0	4.0	5.3	6.2	7.0	8.9	9.4		
	5% WB	MCDBR	10.2	11.1	11.2	10.6	10.5	10.1	9.8	10.9	11.9	11.8	10.9	9.9		
		MCWBR	9.6	9.5	7.9	6.5	4.6	4.1	4.3	5.2	5.9	6.3	9.1	9.3		
(40) Clear-Sky Solar Irradiance	taub		0.319	0.329	0.364	0.400	0.431	0.442	0.482	0.477	0.412	0.358	0.323	0.312		
	taud		2.461	2.415	2.377	2.274	2.246	2.226	2.140	2.145	2.318	2.452	2.495	2.486		
	Ebn at Noon		870	904	900	881	855	843	806	801	839	860	858	854		
	Edh at Noon		84	99	113	132	138	141	152	148	118	94	80	77		
(44) All-Sky Solar Radiation	RadAvg		2.19	2.79	3.86	5.06	5.71	6.43	6.21	5.69	4.76	3.60	2.46	1.86		
	RadStd		0.21	0.36	0.34	0.33	0.48	0.40	0.37	0.30	0.29	0.39	0.26	0.16		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (28 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page