

DANSVILLE, NY, USA

WMO: 724988

Lat: 42.571N

Lon: 77.713W

Elev: 685

StdP: 14.34

Time Zone: -5.00 (NAE)

Period: 01-19

WBAN: 94704

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	2.1	6.9	-6.6	4.0	5.0	-2.0	5.1	8.6	21.9	27.0	19.8	26.7	6.0	160	0.501

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.9	90.2	72.4	87.8	70.9	85.0	69.8	75.0	85.4	73.4	83.3	72.1	81.4	7.2	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
71.9	120.9	80.0	70.3	114.4	78.4	69.0	109.3	77.4	38.7	85.7	37.4	83.4	36.2	81.4	80.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
19.0	16.8	15.0	-4.0	94.0	4.5	2.9	-7.2	96.1	-9.9	97.8	-12.4	99.4	-15.8	101.5		
			DB													
			WB	-4.7	77.4	4.3	2.0	-7.8	78.8	-10.3	80.0	-12.7	81.1	-15.8	82.5	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	50.1	26.2	28.7	35.7	47.8	59.6	67.8	72.4	70.4	64.3	52.7	41.8	32.8
	DBStd	18.40	12.00	10.20	11.04	9.77	9.09	6.66	5.37	5.33	7.05	8.66	9.10	9.25
	HDD50	2855	741	600	462	156	17	0	0	0	0	71	273	535
	HDD65	6117	1203	1017	908	523	221	46	5	14	97	391	695	997
	CDD50	2903	3	3	20	89	314	533	694	632	428	156	28	3
	CDD65	687	0	0	0	6	52	129	234	181	75	10	0	0
	CDH74	6313	0	0	7	114	570	1239	2178	1437	666	101	1	0
	CDH80	2067	0	0	0	27	179	417	781	443	204	16	0	0
Wind	WSAvg	6.5	7.1	7.1	7.7	7.7	6.5	6.0	5.5	5.4	5.7	6.2	6.6	6.9
Precipitation	PrecAvg	28.8	1.5	1.3	1.7	2.4	2.7	3.3	3.0	3.1	3.2	2.4	2.5	1.9
	PrecMax	38.9	3.7	3.1	3.1	4.6	7.0	9.9	7.5	6.7	7.1	5.6	5.5	3.9
	PrecMin	20.7	0.2	0.1	0.6	0.9	0.7	0.4	0.5	1.1	0.5	0.2	0.4	0.3
	PrecStd	5.0	0.8	0.6	0.7	0.9	1.4	1.7	1.5	1.3	1.3	1.2	1.1	0.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	61.0	62.9	73.3	83.8	89.2	91.8	93.6	92.0	90.4	82.1	70.1	62.8
		MCWB	53.5	50.9	58.8	63.1	69.1	72.6	74.4	73.2	72.0	67.2	57.2	53.8
	2%	DB	54.3	54.5	64.5	76.9	85.2	88.5	90.3	88.2	85.6	76.6	64.4	55.0
		MCWB	48.9	46.0	52.8	59.7	66.7	70.9	73.2	71.8	70.6	63.0	54.8	49.5
	5%	DB	47.7	48.5	58.2	70.8	80.7	85.1	87.7	84.9	81.5	71.7	61.1	50.1
		MCWB	42.9	41.8	49.5	55.9	65.4	69.5	71.7	70.5	68.2	62.5	52.9	45.2
	10%	DB	42.8	42.7	53.2	65.5	75.9	81.3	84.3	81.9	77.2	66.5	56.3	45.9
		MCWB	38.4	37.1	45.4	53.8	62.5	67.6	70.1	69.4	66.2	58.7	49.8	41.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	54.7	54.2	60.4	65.9	72.5	75.1	77.4	76.1	75.2	70.0	60.2	56.1
		MCDB	59.7	60.3	70.3	78.9	85.4	86.7	89.4	86.8	85.0	77.5	65.6	61.1
	2%	WB	48.7	47.4	55.2	61.5	69.5	73.1	75.3	74.3	72.4	66.5	56.7	50.2
		MCDB	53.1	53.6	62.1	73.3	80.8	84.3	86.2	83.6	81.9	73.3	63.2	54.6
	5%	WB	43.2	42.2	50.7	58.4	67.4	71.4	73.7	72.7	70.2	62.8	53.7	45.7
		MCDB	47.6	48.6	56.9	69.0	77.1	82.0	83.6	81.4	78.5	69.9	59.8	49.5
	10%	WB	38.5	37.3	45.9	54.7	65.0	69.4	72.2	71.1	68.1	59.7	50.3	41.8
		MCDB	42.6	41.9	52.8	63.5	73.6	78.0	81.1	79.1	75.4	65.6	56.0	45.9
Mean Daily Temperature Range	5% DB	MDBR	15.2	16.1	18.4	21.7	22.5	20.9	20.9	20.1	20.8	18.2	16.5	13.1
		MCDBR	19.8	24.3	26.1	31.3	26.9	25.3	23.9	23.5	25.0	25.1	24.1	19.9
		MCWBR	15.9	17.9	16.7	17.8	13.0	11.7	10.2	10.5	12.0	14.2	16.0	15.4
	5% WB	MCDBR	18.8	22.8	23.6	27.3	23.5	21.6	20.4	19.6	21.1	21.9	20.8	18.6
		MCWBR	15.9	18.1	16.3	16.9	12.4	11.1	9.8	9.7	10.9	14.0	15.7	15.6
Clear-Sky Solar Irradiance	taub		0.308	0.323	0.347	0.379	0.402	0.448	0.446	0.436	0.376	0.359	0.315	0.297
	taud		2.349	2.307	2.338	2.307	2.286	2.182	2.196	2.214	2.368	2.409	2.499	2.455
	Ebn at Noon		262	277	284	282	277	263	262	261	271	261	260	258
	Edh at Noon		26	32	35	39	41	46	45	43	34	29	23	22
All-Sky Solar Radiation	RadAvg		427	689	1044	1398	1680	1787	1813	1626	1306	802	508	345
	RadStd		37	81	107	152	170	153	146	96	128	81	69	52

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (43 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+139	N/A

Nomenclature: See separate page