

TETERBORO, NJ, USA

WMO: 725025

Lat: 40.850N

Lon: 74.061W

Elev: 9

StdP: 14.69

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 94741

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.4	15.7	-6.7	3.8	14.4	-2.1	4.9	19.1	25.4	32.5	22.8	29.4	10.3	330	0.477

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.1	92.6	74.1	90.0	72.9	87.6	71.8	77.3	87.4	75.8	84.8	74.5	82.9	10.2	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
74.4	128.4	81.5	73.0	122.5	80.2	72.0	118.4	79.6	40.6	87.3	39.2	85.1	37.9	82.7	86.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
20.8	18.6	16.7	DB	6.3	97.4	5.5	3.2	2.3	99.7	-0.9	101.6	-4.0	103.3	-8.0	105.6	
			WB	4.2	80.1	5.0	2.1	0.5	81.6	-2.4	82.8	-5.2	84.1	-8.9	85.6	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	54.8	31.8	34.3	41.7	52.7	62.4	71.7	77.1	75.4	68.6	57.0	46.4	37.6	
	DBStd	17.48	9.91	9.00	8.68	8.08	7.49	6.45	5.13	5.07	6.54	7.80	8.16	8.57	
	HDD50	1937	569	443	284	57	2	0	0	0	0	22	163	397	
	HDD65	4868	1030	860	723	378	143	16	0	1	37	270	559	851	
	CDD50	3704	4	4	26	139	386	652	842	788	558	239	54	12	
	CDD65	1159	0	0	1	10	62	218	377	324	145	21	1	0	
	CDH74	10119	0	1	9	127	601	1882	3629	2750	992	126	2	0	
	CDH80	3544	0	0	1	35	194	651	1436	945	262	20	0	0	
Wind	WSAvg	7.4	8.4	8.5	8.9	8.3	7.1	6.8	6.5	6.0	6.4	6.7	7.3	7.8	
Precipitation	PrecAvg	46.5	3.4	2.8	4.0	3.8	3.7	4.1	4.1	4.6	4.0	3.9	3.5	3.9	
	PrecMax	66.1	7.0	5.4	10.2	11.3	8.2	9.0	9.4	15.4	11.3	14.8	6.3	7.3	
	PrecMin	34.4	1.5	0.8	0.7	1.3	1.1	0.6	0.6	1.2	0.8	0.0	1.1	0.9	
	PrecStd	7.3	1.3	1.3	2.0	2.1	1.5	2.1	2.0	2.8	2.6	3.1	1.4	1.5	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	62.3	63.9	74.7	84.5	90.2	93.6	97.2	94.9	90.7	82.5	71.9	65.9	
		MCWB	56.8	54.4	60.0	64.4	70.4	74.5	76.1	76.4	72.7	68.0	61.3	58.7	
	2%	DB	56.1	56.7	65.8	77.1	85.4	90.2	93.2	90.9	86.4	77.5	66.5	59.7	
		MCWB	52.4	48.4	53.4	59.7	67.8	73.3	74.2	74.0	70.3	66.5	58.4	54.4	
	5%	DB	50.1	51.9	60.2	71.6	81.1	87.1	90.4	88.1	82.4	73.2	63.3	54.6	
		MCWB	45.1	44.7	50.0	57.4	66.0	71.5	73.2	72.3	69.6	64.2	56.6	50.0	
	10%	DB	45.6	46.8	54.9	66.3	76.2	83.6	87.7	85.2	79.8	69.9	59.6	50.4	
		MCWB	41.1	40.8	46.8	54.1	63.1	68.8	72.3	70.7	68.3	61.4	53.2	45.1	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	58.6	58.0	61.9	67.7	72.8	77.2	79.4	79.0	77.3	72.5	64.8	60.2
			MCDB	61.1	62.8	73.6	81.0	85.8	88.9	91.8	90.2	84.6	77.5	68.4	64.0
2%		WB	53.0	50.4	56.3	63.4	70.3	75.3	77.4	77.1	74.9	69.0	61.5	55.3	
		MCDB	55.8	55.7	63.1	73.2	81.6	86.0	88.3	86.5	80.9	75.2	64.9	58.5	
5%		WB	46.0	45.5	51.7	60.0	68.2	73.6	75.9	75.5	73.1	66.0	57.9	50.8	
		MCDB	48.9	49.4	58.0	68.3	77.7	83.5	85.4	83.4	78.9	71.8	61.7	54.5	
10%		WB	41.5	41.5	47.8	56.4	65.5	71.7	74.5	73.9	70.9	63.0	54.2	46.0	
		MCDB	45.3	46.8	54.5	64.1	74.3	80.4	83.5	81.1	77.2	68.0	58.6	49.2	
Mean Daily Temperature Range	5% DB	MDBR	13.7	15.0	16.0	18.2	18.4	17.6	17.1	16.8	17.2	17.2	15.8	13.2	
		MCDBR	19.1	21.4	23.6	26.2	24.9	21.5	20.2	19.6	20.1	21.6	20.2	18.9	
		MCWBR	16.7	16.0	15.4	13.9	11.6	9.4	7.7	7.7	9.0	12.1	14.5	16.2	
	5% WB	MCDBR	18.2	19.4	21.7	22.9	22.1	19.2	17.3	16.3	16.1	18.2	17.6	17.5	
		MCWBR	17.2	16.3	16.2	14.5	11.6	9.8	8.1	7.7	9.7	12.7	15.5	16.9	
Clear-Sky Solar Irradiance	taub	0.315	0.329	0.361	0.384	0.431	0.491	0.495	0.479	0.403	0.363	0.332	0.315		
	taud	2.448	2.412	2.388	2.360	2.257	2.126	2.129	2.165	2.351	2.472	2.517	2.513		
	Ebn at Noon	267	280	282	282	269	252	250	250	264	264	259	259		
	Edh at Noon	25	30	34	38	43	49	48	45	35	28	23	22		
All-Sky Solar Radiation	RadAvg	586	871	1178	1512	1679	1841	1884	1643	1364	943	660	497		
	RadStd	48	87	97	150	173	169	95	106	134	96	58	48		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+1.06	N/A	N/A	N/A	N/A	N/A	N/A	-218	+329	+200
(47)	Regional (64 neighbors)	+0.72	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+209	+121

Nomenclature: See separate page