

NEW YORK LA GUARDIA, NY, USA

WMO: 725030

Lat: 40.779N

Lon: 73.880W

Elev: 3

StdP: 101.28

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 14732

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-10.2	-7.8	-20.0	0.6	-9.0	-17.9	0.8	-6.3	14.3	-0.2	12.7	-2.0	7.5	300	0.554

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.4	33.7	23.3	32.1	22.5	30.6	22.0	24.9	30.7	24.2	29.2	23.6	28.3	5.2	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.3	18.1	27.4	22.7	17.4	26.9	22.0	16.7	26.5	75.6	30.9	72.7	29.5	70.1	28.2	28.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
12.0	10.8	9.3	-13.0	36.6	3.1	1.7	-15.2	37.8	-17.0	38.8	-18.8	39.8	-21.0	41.0		
			-14.3	26.2	2.8	0.9	-16.3	26.8	-17.9	27.3	-19.4	27.8	-21.4	28.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	13.5	1.0	2.2	5.9	11.8	17.2	22.6	25.8	25.1	21.4	15.2	9.2	4.3	(6)
(7)		DBStd	9.59	5.45	4.91	4.71	4.24	4.05	3.66	2.88	2.78	3.35	4.07	4.35	4.68	(7)
(8)		HDD10.0	931	283	223	144	26	1	0	0	0	5	65	184		(8)
(9)		HDD18.3	2487	538	453	386	200	72	7	0	0	10	113	273	434	(9)
(10)		CDD10.0	2224	3	3	16	81	224	377	491	468	342	168	42	9	(10)
(11)		CDD18.3	740	0	0	1	5	37	134	233	210	102	17	1	0	(11)
(12)		CDH23.3	5824	0	0	3	51	285	1029	2157	1696	539	63	1	0	(12)
(13)		CDH26.7	1936	0	0	0	14	87	347	817	543	118	9	0	0	(13)
(14)	Wind	WSAvg	4.9	5.6	5.5	5.6	5.1	4.6	4.3	4.1	4.0	4.4	4.8	5.1	5.4	(14)
(15)	Precipitation	PrecAvg	1238	94	83	108	105	107	98	113	107	112	98	109	101	(15)
(16)		PrecMax	2046	280	157	268	356	260	261	311	314	292	425	328	265	(16)
(17)		PrecMin	718	15	18	20	35	16	5	11	5	12	4	9	15	(17)
(18)		PrecStd	258	53	35	53	56	61	56	66	63	65	72	68	56	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.1	17.5	22.3	28.8	32.3	34.6	36.2	35.2	32.2	27.9	21.5	18.1	(19)
(20)		0.4%	MCWB	12.3	11.7	14.2	18.3	20.6	23.3	24.2	24.5	22.4	19.9	16.4	13.7	(20)
(21)		2%	DB	13.2	13.6	17.9	24.1	29.1	32.3	34.0	32.7	29.6	25.0	18.9	15.2	(21)
(22)		2%	MCWB	10.9	9.1	11.2	15.0	19.7	22.4	23.4	23.2	21.5	19.1	14.7	12.3	(22)
(23)		5%	DB	10.6	10.9	14.9	20.9	26.6	30.4	32.4	31.1	27.8	22.9	17.2	13.0	(23)
(24)		5%	MCWB	8.0	7.2	9.3	13.3	18.4	21.3	22.8	22.5	20.8	18.2	13.3	10.4	(24)
(25)		10%	DB	8.3	8.8	12.4	18.3	24.0	28.5	30.8	29.6	26.3	21.1	15.7	10.9	(25)
(26)		10%	MCWB	5.4	5.3	8.0	11.5	16.8	20.4	22.5	21.9	20.2	16.6	12.3	8.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.7	13.7	15.8	19.1	22.4	24.7	25.8	25.9	24.6	22.3	17.9	15.1	(27)
(28)		0.4%	MCDWB	15.3	16.2	20.8	26.8	29.0	31.1	32.8	32.2	28.3	24.9	20.3	16.7	(28)
(29)		2%	WB	11.5	10.3	12.8	16.6	20.9	23.7	25.0	24.9	23.7	20.6	15.9	12.9	(29)
(30)		2%	MCDWB	12.8	12.6	16.3	22.4	27.2	29.9	31.3	30.1	26.9	23.6	17.7	14.7	(30)
(31)		5%	WB	8.2	7.6	10.4	14.7	19.6	22.8	24.3	24.2	22.8	19.1	14.5	10.9	(31)
(32)		5%	MCDWB	10.3	10.3	13.6	18.9	25.2	28.4	29.8	28.7	25.9	22.1	16.5	12.9	(32)
(33)		10%	WB	5.8	5.5	8.5	12.8	18.1	21.8	23.6	23.5	21.7	17.5	12.7	8.4	(33)
(34)		10%	MCDWB	7.9	8.4	12.1	16.9	22.9	26.7	28.7	27.7	25.1	20.4	15.1	10.5	(34)
(35)	Mean Daily Temperature Range	MDBR	6.1	6.8	7.3	8.2	8.2	7.8	7.4	6.9	6.6	6.6	6.0	5.6	(35)	
(36)		5% DB	MCDBR	9.0	9.9	10.6	12.2	11.5	10.1	9.1	8.3	8.1	8.4	7.7	8.2	(36)
(37)		5% DB	MCWBR	8.1	7.7	7.0	6.4	5.5	4.3	3.5	3.5	4.0	4.8	6.1	7.8	(37)
(38)		5% WB	MCDBR	8.9	9.5	10.1	11.1	10.8	9.2	8.0	7.2	6.8	7.6	7.1	8.1	(38)
(39)		5% WB	MCWBR	8.7	8.4	7.9	7.0	5.8	4.7	3.8	3.7	4.6	5.6	6.9	8.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.318	0.330	0.362	0.386	0.434	0.491	0.496	0.480	0.404	0.364	0.334	0.318	(40)	
(41)		taud	2.454	2.425	2.395	2.363	2.258	2.136	2.133	2.171	2.355	2.477	2.519	2.517	(41)	
(42)		Ebn at Noon	839	881	888	887	847	797	788	789	832	833	816	812	(42)	
(43)		Edh at Noon	78	93	107	119	135	153	152	142	111	88	74	69	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.86	2.76	3.75	4.81	5.34	5.86	5.97	5.25	4.33	3.00	2.10	1.58	(44)	
(45)		RadStd	0.15	0.28	0.31	0.48	0.55	0.54	0.30	0.34	0.40	0.30	0.18	0.15	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+95	+70	(46)
(47)	Regional (65 neighbors)	+0.40	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+116	+67	(47)

Nomenclature: See separate page