

BRIDGEPORT SIKORSKY, CT, USA

WMO: 725040

Lat: 41.164N

Lon: 73.127W

Elev: 5

StdP: 14.69

Time Zone: -5.00 (NAE)

Period: 96-19

WBAN: 94702

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.8	15.3	-7.7	3.6	14.3	-3.1	4.7	18.5	27.4	30.9	24.8	30.5	11.0	350	0.512

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.0	88.3	73.2	85.4	72.0	83.0	70.8	76.3	83.6	75.1	81.3	73.8	79.5	10.8	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
74.1	127.1	80.1	73.0	122.4	78.8	71.9	117.8	77.8	39.6	83.9	38.4	81.5	37.3	79.6	81.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 24.3	20.6	18.5	DB	5.0	94.5	5.3	3.6	1.1	97.1	-2.0	99.2	-5.0	101.2	-8.9	103.9	(4)
(5)			WB	3.0	78.8	4.8	1.4	-0.5	79.8	-3.2	80.6	-5.9	81.4	-9.4	82.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	53.3	31.0	33.2	39.6	49.8	59.6	69.1	75.0	74.1	67.5	56.2	45.7	37.0	(6)
(7)		DBStd	16.87	9.28	7.97	7.74	6.71	6.40	5.99	4.82	4.78	6.01	7.36	7.52	8.11	(7)
(8)		HDD50	2082	589	472	334	82	2	0	0	0	0	26	169	408	(8)
(9)		HDD65	5193	1054	891	789	458	195	29	0	1	42	287	580	867	(9)
(10)		CDD50	3272	1	1	10	76	300	573	775	748	525	217	40	6	(10)
(11)		CDD65	906	0	0	0	2	28	151	310	284	117	14	0	0	(11)
(12)		CDH74	5516	0	0	2	20	147	821	2146	1838	510	32	0	0	(12)
(13)		CDH80	1318	0	0	0	3	27	194	601	420	69	4	0	0	(13)
(14)	Wind	WSAvg	8.8	9.5	9.4	10.1	9.7	8.7	7.8	7.5	7.4	8.4	9.0	9.0	9.1	(14)
(15)	Precipitation	PrecAvg	41.6	3.1	2.9	3.9	3.7	3.9	3.3	3.6	3.7	3.5	3.0	3.5	3.4	(15)
(16)		PrecMax	73.9	11.2	6.7	9.2	10.7	9.5	17.7	12.8	8.4	7.4	7.0	10.2	7.9	(16)
(17)		PrecMin	23.0	0.4	0.4	0.7	0.7	0.4	0.4	0.5	0.7	0.6	0.3	0.4	0.8	(17)
(18)		PrecStd	9.4	2.0	1.3	1.9	2.0	2.0	3.0	2.6	2.0	2.0	1.6	2.1	1.8	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.9	56.2	65.4	76.5	83.4	89.3	93.0	91.3	86.1	78.2	66.4	60.3	(19)
MCWB			51.5	47.8	52.9	58.6	66.9	72.4	75.0	75.7	73.0	67.9	60.8	54.0	(20)	
2%		DB	50.2	50.9	58.6	68.8	78.0	85.1	89.1	87.0	81.7	73.4	62.9	55.8	(21)	
		MCWB	46.1	45.4	48.8	54.7	64.6	69.9	73.5	73.4	70.3	66.9	57.3	52.1	(22)	
5%		DB	46.8	47.2	53.9	64.2	73.8	81.8	86.0	84.5	79.1	70.4	60.6	52.4	(23)	
		MCWB	42.5	42.3	46.4	52.6	62.2	68.9	72.5	72.2	69.4	64.0	55.6	49.5	(24)	
10%		DB	43.8	44.0	50.2	60.4	70.0	78.8	83.1	82.0	76.9	67.7	57.8	49.3	(25)	
		MCWB	40.0	39.3	43.7	50.4	60.2	67.5	71.4	71.1	68.6	61.6	53.3	45.3	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.0	51.4	56.2	62.8	70.1	75.1	78.1	78.3	76.1	71.4	63.3	56.7	(27)
MCD B			54.2	53.3	62.5	71.8	79.4	84.6	88.8	87.0	81.9	74.3	66.0	59.2	(28)	
2%		WB	47.4	46.6	51.2	58.4	67.4	73.1	76.3	76.4	74.2	68.5	59.7	53.0	(29)	
		MCD B	49.2	49.4	56.0	64.6	74.9	81.2	84.7	82.9	78.3	72.1	61.9	54.6	(30)	
5%		WB	43.4	42.9	47.7	55.2	64.7	71.4	75.1	75.2	72.5	65.5	56.9	50.3	(31)	
		MCD B	45.6	46.2	52.5	60.7	71.3	78.3	82.1	80.8	76.3	69.3	59.4	52.4	(32)	
10%		WB	40.4	40.1	44.8	52.4	62.2	69.7	73.8	73.9	70.7	63.1	53.9	46.1	(33)	
		MCD B	43.4	43.3	49.2	58.1	67.9	75.6	79.9	79.0	74.9	66.8	56.9	48.8	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	12.8	13.4	14.0	15.2	14.9	14.4	14.0	13.3	14.2	14.6	13.8	12.2	(35)
MCD BR			15.6	16.9	18.9	22.0	21.3	18.5	17.1	15.4	15.4	16.1	15.9	14.9	(36)	
MCWBR			13.9	13.2	12.5	11.6	10.5	8.3	7.0	7.3	8.7	11.1	13.3	14.3	(37)	
5% WB		MCD BR	15.3	15.8	17.5	18.8	19.1	16.0	14.2	12.6	12.1	14.0	13.9	14.6	(38)	
		MCWBR	14.8	13.8	13.5	12.2	10.7	7.9	6.8	6.7	8.4	11.2	13.5	15.0	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.309	0.317	0.341	0.377	0.426	0.473	0.488	0.464	0.391	0.349	0.320	0.307	(40)	
taud		2.481	2.461	2.444	2.378	2.272	2.179	2.148	2.206	2.381	2.514	2.547	2.542	(41)		
Ebn at Noon		269	284	289	284	271	257	252	254	268	269	264	261	(42)		
Edh at Noon		24	28	32	37	42	46	47	43	34	27	23	21	(43)		
(44)	All-Sky Solar Radiation	RadAvg	586	864	1185	1524	1702	1858	1897	1686	1382	938	654	491	(44)	
(45)		RadStd	47	80	95	159	167	176	101	104	115	91	54	46	(45)	

Historical Trends

		Heating		Cooling		Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+263	+144
(47) Regional (69 neighbors)		+0.70	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+194	+106

Nomenclature: See separate page