

TAUNTON, MA, USA

WMO: 725068

Lat: 41.876N

Lon: 71.021W

Elev: 43

StdP: 14.67

Time Zone: -5.00 (NAE)

Period: 98-19

WBAN: 54777

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 5.2	(c) 10.2	(d) -10.3	(e) 3.2	(f) 10.4	(g) -5.8	(h) 4.0	(i) 15.3	(j) 21.9	(k) 30.0	(l) 19.5	(m) 33.5	(n) 4.4	(o) 280	(p) 0.486

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.3	90.4	73.7	87.4	71.9	84.3	70.5	76.6	85.7	75.0	82.5	73.6	80.0	8.1	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
73.5	124.6	80.1	72.6	121.2	79.0	71.8	117.6	77.8	39.9	85.5	38.4	82.9	37.2	80.2	81.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.6	16.5	14.5	DB	-2.4	96.0	6.6	2.8	-7.2	98.0	-11.0	99.7	-14.7	101.2	-19.5	103.2
			WB	-3.2	79.1	6.4	1.4	-7.8	80.2	-11.6	81.0	-15.2	81.8	-19.9	82.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	50.8	28.8	31.3	37.7	48.1	57.9	66.5	72.5	70.9	63.7	52.8	43.3	34.7
	DBStd	17.00	10.34	9.05	8.55	7.54	7.53	6.84	5.68	5.92	7.16	8.09	8.41	9.43
	HDD50	2498	660	527	393	123	13	0	0	0	1	62	235	484
	HDD65	5843	1123	944	848	509	246	63	7	14	110	389	650	940
	CDD50	2782	2	2	10	66	258	495	698	648	411	148	35	9
	CDD65	654	0	0	0	2	27	108	240	197	70	10	0	0
	CDH74	6051	0	0	2	46	317	1009	2238	1841	548	50	0	0
	CDH80	1913	0	0	0	10	93	317	791	575	121	6	0	0
Wind	WSAvg	5.8	6.5	6.7	7.2	6.9	6.0	5.5	5.1	4.5	4.5	5.4	5.8	5.9
Precipitation	PrecAvg	46.7	3.8	3.5	4.3	4.0	3.9	3.3	3.5	3.9	4.1	3.8	4.4	4.4
	PrecMax	64.2	8.7	7.0	10.5	8.7	8.9	11.3	8.0	8.8	9.0	9.1	8.2	9.8
	PrecMin	27.3	0.6	0.8	0.4	1.3	0.4	0.2	0.8	1.3	0.7	0.9	1.0	0.7
	PrecStd	7.8	2.0	1.6	2.2	1.9	2.0	2.3	1.7	1.7	2.2	1.9	2.1	2.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	61.0	60.4	68.3	81.6	88.5	92.1	94.7	93.1	88.2	79.4	69.4	63.5
		MCWB	57.7	54.2	54.4	63.3	68.5	73.6	76.3	75.9	73.4	66.8	61.8	58.5
	2%	DB	54.7	54.7	60.9	72.3	81.8	87.5	90.7	88.9	83.2	74.1	65.3	59.1
		MCWB	50.3	49.5	50.7	56.4	64.6	71.9	73.8	73.7	69.4	65.6	60.1	55.3
	5%	DB	49.7	50.3	55.6	66.6	76.9	83.5	87.7	85.8	80.1	70.5	62.1	54.7
		MCWB	45.1	45.0	47.7	53.8	63.1	69.4	72.4	71.5	68.6	63.4	56.1	51.2
	10%	DB	44.7	45.8	51.9	62.5	72.3	80.2	84.3	82.9	76.7	67.2	58.6	50.4
		MCWB	40.2	40.3	45.3	52.0	60.1	67.2	71.1	70.5	67.4	60.7	53.7	46.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	58.3	55.9	58.0	64.9	71.4	76.7	78.8	78.5	75.6	70.9	64.4	60.5
		MCDB	60.7	58.6	64.0	75.7	84.0	87.8	91.1	89.6	82.7	76.9	67.0	62.6
	2%	WB	51.9	51.0	53.3	60.4	68.1	74.1	76.7	76.5	73.3	67.7	61.4	55.8
		MCDB	54.0	53.8	57.2	67.8	78.3	83.6	86.8	84.5	78.4	72.2	64.1	58.5
	5%	WB	45.8	46.0	49.8	57.2	65.5	71.9	75.0	75.0	71.9	64.9	57.7	51.8
		MCDB	48.7	49.4	54.9	63.6	74.1	79.8	83.0	81.5	76.8	69.1	61.0	54.3
	10%	WB	40.5	41.1	45.7	53.8	62.7	69.9	73.5	73.6	70.0	62.0	54.2	46.5
		MCDB	44.2	45.4	50.4	59.6	68.8	76.6	80.1	79.2	74.9	66.4	57.5	49.4
Mean Daily Temperature Range	5% DB	MDBR	17.4	18.6	18.9	21.2	21.4	21.0	21.3	21.9	22.4	21.3	19.6	17.5
		MCDBR	22.3	23.1	24.8	28.8	28.5	26.2	24.0	23.9	24.3	23.6	21.5	21.1
		MCWBR	19.7	18.6	16.5	15.4	13.7	12.3	9.9	10.5	13.1	15.3	16.6	19.6
	5% WB	MCDBR	21.4	22.3	21.6	22.9	23.9	21.5	19.4	18.4	18.0	19.4	18.7	21.0
		MCWBR	20.2	20.3	17.2	15.2	13.1	11.2	9.2	9.2	11.1	14.6	16.9	20.8
Clear-Sky Solar Irradiance	taub	0.299	0.308	0.332	0.371	0.409	0.458	0.480	0.436	0.373	0.339	0.313	0.300	
	taud	2.504	2.489	2.471	2.386	2.317	2.218	2.162	2.273	2.428	2.532	2.566	2.561	
	Ebn at Noon	272	287	291	285	275	261	253	262	273	272	265	263	
	Edh at Noon	23	27	31	36	40	44	47	41	32	26	22	20	
All-Sky Solar Radiation	RadAvg	574	852	1172	1510	1681	1822	1892	1701	1378	927	631	480	
	RadStd	42	79	84	161	172	174	106	84	97	82	46	49	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (67 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+173	+85

Nomenclature: See separate page