

TAUNTON, MA, USA

WMO: 725068

Lat: 41.876N

Lon: 71.021W

Elev: 13

StdP: 101.17

Time Zone: -5.00 (NAE)

Period: 98-19

WBAN: 54777

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.9	-12.1	-23.5	0.5	-12.0	-21.0	0.6	-9.3	9.8	-1.1	8.7	0.8	2.0	280	0.486

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.8	32.4	23.2	30.8	22.2	29.1	21.4	24.8	29.8	23.9	28.0	23.1	26.7	3.6	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
23.0	17.8	26.7	22.6	17.3	26.1	22.1	16.8	25.5	75.0	29.7	71.4	28.3	68.7	26.8	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.3	7.4	6.5	DB	-19.1	35.6	3.7	1.5	-21.8	36.7	-23.9	37.6	-25.9	38.5	-28.6	39.6	(4)
(5)			WB	-19.6	26.2	3.6	0.8	-22.1	26.8	-24.2	27.2	-26.2	27.7	-28.8	28.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.4	-1.8	-0.4	3.1	8.9	14.4	19.2	22.5	21.6	17.6	11.5	6.3	1.5	(6)	
	DBStd	9.44	5.74	5.03	4.75	4.19	4.18	3.80	3.16	3.29	3.98	4.50	4.67	5.24	(7)	
	HDD10.0	1388	367	293	218	68	7	0	0	0	1	34	131	269	(8)	
	HDD18.3	3246	624	524	471	283	137	35	4	8	61	216	361	522	(9)	
	CDD10.0	1546	1	1	6	37	143	275	388	360	228	82	19	5	(10)	
	CDD18.3	363	0	0	0	1	15	60	133	109	39	6	0	0	(11)	
	CDH23.3	3362	0	0	1	26	176	561	1243	1023	304	28	0	0	(12)	
(13)	CDH26.7	1063	0	0	0	6	52	176	439	319	67	3	0	0	(13)	
(14) Wind	WSAvg	2.6	2.9	3.0	3.2	3.1	2.7	2.4	2.3	2.0	2.0	2.4	2.6	2.6	(14)	
(15) Precipitation	PrecAvg	1187	96	88	109	101	98	84	90	99	104	96	111	111	(15)	
	PrecMax	1630	220	178	267	220	226	286	204	224	228	231	208	249	(16)	
	PrecMin	694	16	21	10	34	9	4	20	32	17	24	25	18	(17)	
	PrecStd	199	51	40	57	48	52	58	42	43	57	49	54	60	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.1	15.8	20.2	27.6	31.4	33.4	34.8	33.9	31.2	26.3	20.8	17.5	(19)	
		MCWB	14.3	12.3	12.4	17.4	20.3	23.1	24.6	24.4	23.0	19.3	16.6	14.7	(20)	
	2%	DB	12.6	12.6	16.1	22.4	27.7	30.8	32.6	31.6	28.4	23.4	18.5	15.1	(21)	
		MCWB	10.2	9.7	10.4	13.6	18.1	22.2	23.2	23.2	20.8	18.7	15.6	12.9	(22)	
	5%	DB	9.8	10.2	13.1	19.2	25.0	28.6	30.9	29.9	26.7	21.4	16.7	12.6	(23)	
		MCWB	7.3	7.2	8.7	12.1	17.3	20.8	22.4	21.9	20.4	17.5	13.4	10.7	(24)	
	10%	DB	7.1	7.7	11.1	16.9	22.4	26.8	29.0	28.3	24.8	19.6	14.8	10.2	(25)	
		MCWB	4.6	4.6	7.4	11.1	15.6	19.6	21.7	21.4	19.7	16.0	12.1	7.8	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.6	13.3	14.5	18.3	21.9	24.8	26.0	25.8	24.2	21.6	18.0	15.8	(27)	
		MCDB	16.0	14.8	17.8	24.3	28.9	31.0	32.9	32.0	28.2	25.0	19.4	17.0	(28)	
	2%	WB	11.1	10.5	11.9	15.8	20.1	23.4	24.8	24.7	23.0	19.8	16.3	13.2	(29)	
		MCDB	12.2	12.1	14.0	19.9	25.7	28.7	30.5	29.2	25.8	22.3	17.8	14.7	(30)	
	5%	WB	7.7	7.8	9.9	14.0	18.6	22.2	23.9	23.9	22.2	18.3	14.3	11.0	(31)	
		MCDB	9.3	9.7	12.7	17.5	23.4	26.5	28.3	27.5	24.9	20.6	16.1	12.4	(32)	
	10%	WB	4.7	5.0	7.6	12.1	17.1	21.1	23.1	23.1	21.1	16.7	12.3	8.0	(33)	
		MCDB	6.8	7.5	10.2	15.3	20.4	24.8	26.7	26.2	23.8	19.1	14.2	9.7	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	9.6	10.3	10.5	11.8	11.9	11.6	11.8	12.2	12.5	11.8	10.9	9.7	(35)	
		MCDBR	12.4	12.8	13.8	16.0	15.9	14.5	13.3	13.3	13.5	13.1	12.0	11.7	(36)	
	5% WB	MCWBR	10.9	10.3	9.2	8.5	7.6	6.8	5.5	5.8	7.3	8.5	9.2	10.9	(37)	
		MCWBR	11.9	12.4	12.0	12.7	13.3	11.9	10.8	10.2	10.0	10.8	10.4	11.7	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.299	0.308	0.332	0.371	0.409	0.458	0.480	0.436	0.373	0.339	0.313	0.300	(40)	
		taud	2.504	2.489	2.471	2.386	2.317	2.218	2.162	2.273	2.428	2.532	2.566	2.561	(41)	
	Ebn at Noon		857	905	918	899	868	823	799	825	860	857	836	828	(42)	
		Edh at Noon	72	86	98	115	127	140	147	128	102	82	68	64	(43)	
(44) All-Sky Solar Radiation	RadAvg		1.81	2.69	3.69	4.76	5.30	5.74	5.96	5.36	4.34	2.92	1.99	1.51	(44)	
	RadStd		0.13	0.25	0.27	0.51	0.54	0.55	0.34	0.27	0.31	0.26	0.14	0.16	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (67 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+96	+47

Nomenclature: See separate page