

DANBURY, CT, USA

WMO: 725086

Lat: 41.371N

Lon: 73.483W

Elev: 139

StdP: 99.66

Time Zone: -5.00 (NAE)

Period: 98-19

WBAN: 54734

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-15.7	-12.7	-23.2	0.5	-13.0	-20.9	0.6	-10.3	9.1	-0.4	8.3	-0.8	2.1	290	0.476

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.7	31.3	22.7	29.8	22.1	28.4	21.3	24.4	28.9	23.6	27.6	22.8	26.5	3.7	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.9	18.0	26.5	22.3	17.3	25.8	21.6	16.5	25.0	74.0	28.9	70.8	27.5	67.7	26.6	27.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.0	7.2	6.2	DB	-19.8	34.1	3.1	1.6	-22.0	35.2	-23.8	36.2	-25.5	37.1	-27.8	38.3	(4)
(5)			WB	-19.9	26.0	3.2	0.8	-22.2	26.6	-24.1	27.1	-25.9	27.6	-28.2	28.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.1	-2.7	-1.4	2.9	9.2	14.7	19.4	22.2	21.4	17.8	11.3	5.6	0.5
	DBStd	9.71	5.77	5.10	4.96	4.52	4.13	3.50	2.81	2.85	3.69	4.45	4.50	5.04
	HDD10.0	1492	396	318	227	66	6	0	0	0	0	37	146	296
	HDD18.3	3338	653	551	479	276	129	29	3	6	55	222	383	552
	CDD10.0	1541	1	1	6	43	151	281	379	354	233	78	13	3
	CDD18.3	347	0	0	0	2	16	61	124	102	38	4	0	0
	CDH23.3	2844	0	0	1	46	184	515	1043	769	263	23	0	0
	CDH26.7	756	0	0	0	12	44	133	315	194	54	3	0	0
Wind	WSAvg	2.6	2.8	2.9	3.2	3.1	2.6	2.4	2.2	2.0	2.1	2.5	2.6	2.6
Precipitation	PrecAvg	1252	90	78	109	103	99	108	110	116	119	106	106	107
	PrecMax	1650	185	202	273	223	168	230	202	272	320	380	174	157
	PrecMin	838	42	37	23	40	24	27	37	47	22	8	37	33
	PrecStd	190	35	35	53	46	36	57	47	55	73	76	33	32
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.9	15.6	20.9	28.5	30.6	32.3	33.3	32.8	30.9	26.1	20.1	17.5
		MCWB	12.7	11.8	13.1	17.4	20.6	23.1	24.1	24.1	22.4	19.1	15.1	13.3
	2%	DB	11.8	12.0	17.0	23.8	27.8	30.0	31.5	30.4	28.0	23.0	17.6	13.8
		MCWB	9.7	8.6	10.5	14.7	19.4	22.0	23.2	22.8	21.0	18.4	14.3	11.6
	5%	DB	7.9	8.9	13.7	20.6	25.3	28.0	29.9	28.7	26.3	21.2	15.9	11.3
		MCWB	5.7	5.4	8.4	13.1	18.0	21.0	22.3	21.8	20.2	17.3	12.5	9.3
	10%	DB	5.6	6.2	11.0	17.7	22.7	26.4	28.3	27.5	24.4	19.0	13.6	8.6
		MCWB	3.0	3.1	7.0	11.6	16.5	19.8	21.6	21.0	19.4	15.5	10.6	6.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.2	13.4	14.9	18.6	22.3	24.5	25.7	25.5	24.1	21.6	17.3	15.0
		MCDB	14.3	15.0	18.3	25.9	28.4	29.7	31.2	30.6	28.1	23.7	19.0	16.6
	2%	WB	9.8	8.9	11.7	16.7	20.6	23.4	24.5	24.2	22.8	19.8	15.2	12.0
		MCDB	11.4	11.0	14.8	22.4	25.5	28.2	29.4	27.9	25.9	22.3	17.0	13.5
	5%	WB	6.0	5.5	9.3	14.7	19.4	22.4	23.5	23.4	21.8	18.0	13.3	9.4
		MCDB	8.0	8.1	12.9	18.9	23.6	26.6	27.7	27.0	24.7	20.4	15.2	11.4
	10%	WB	3.2	3.3	7.1	12.5	17.9	21.2	22.8	22.4	20.7	16.2	11.1	6.5
		MCDB	5.1	5.9	10.4	16.1	21.5	24.7	26.5	25.6	23.3	18.4	13.0	8.3
Mean Daily Temperature Range	5% DB	MDBR	9.1	9.9	10.1	11.5	11.4	10.8	10.7	10.4	11.1	10.7	10.2	8.7
		MCDBR	11.5	13.2	14.4	16.5	14.8	12.7	12.2	11.7	12.5	12.7	12.7	11.6
		MCWBR	10.0	10.1	9.4	8.8	7.6	6.4	5.4	5.3	6.6	8.0	9.5	10.3
	5% WB	MCDBR	11.5	12.2	12.6	14.1	12.5	11.1	10.1	9.3	9.4	10.3	10.7	11.2
		MCWBR	10.4	10.3	9.5	8.5	7.1	6.2	5.2	4.8	5.8	7.5	9.5	10.6
Clear-Sky Solar Irradiance	taub	0.303	0.315	0.340	0.367	0.411	0.462	0.476	0.453	0.381	0.347	0.318	0.302	
	taud	2.442	2.422	2.421	2.387	2.286	2.178	2.152	2.205	2.381	2.494	2.530	2.520	
	Ebn at Noon	851	896	909	904	867	820	803	811	853	849	831	827	
	Edh at Noon	78	92	104	115	131	146	149	137	107	85	71	67	
All-Sky Solar Radiation	RadAvg	1.83	2.71	3.71	4.74	5.29	5.78	5.95	5.25	4.31	2.91	2.04	1.52	
	RadStd	0.14	0.25	0.29	0.50	0.51	0.53	0.32	0.33	0.38	0.29	0.17	0.15	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (70 neighbors)	+0.40	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+111	+61

Nomenclature: See separate page