

ELMIRA CORNING, NY, USA

WMO: 725156

Lat: 42.159N

Lon: 76.892W

Elev: 955

StdP: 14.20

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 14748

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -0.8	(c) 4.1	(d) -9.2	(e) 3.5	(f) 1.2	(g) -4.4	(h) 4.5	(i) 6.6	(j) 25.0	(k) 30.1	(l) 21.9	(m) 25.8	(n) 3.7	(o) 250	(p) 0.517

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.6	89.6	71.7	86.5	70.4	83.8	69.1	74.6	84.3	73.0	82.2	71.5	80.2	9.7	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
71.9	122.0	79.6	70.2	115.1	77.7	68.6	108.9	76.3	38.7	84.5	37.2	82.3	35.9	80.1	84.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.2	17.8	15.8	-9.4	94.5	6.2	3.3	-13.8	96.9	-17.4	98.9	-20.9	100.7	-25.4	103.2
			-9.8	77.9	6.1	2.0	-14.2	79.3	-17.7	80.5	-21.2	81.6	-25.6	83.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	48.1	24.4	26.6	34.4	46.0	57.4	66.1	70.1	68.8	61.9	50.3	39.1	30.5		
	DBStd	18.23	11.61	10.54	10.28	8.71	8.29	6.48	5.48	5.32	7.12	8.15	8.50	9.22		
	HDD50	3192	795	656	495	176	22	0	0	0	3	99	340	606		
	HDD65	6672	1259	1075	949	571	264	65	16	24	142	461	776	1070		
	CDD50	2494	1	1	11	58	251	482	624	582	360	108	14	2		
	CDD65	497	0	0	0	2	28	97	175	141	49	5	0	0		
	CDH74	5180	0	0	10	86	441	1040	1752	1306	490	54	1	0		
	CDH80	1625	0	0	2	21	129	321	606	397	143	6	0	0		
(14) Wind	WSAvg	5.9	6.8	6.9	7.1	7.1	6.0	5.2	4.8	4.5	4.7	5.5	6.0	6.3		
(15) Precipitation	PrecAvg	34.2	2.0	1.9	2.6	3.0	3.2	3.9	3.3	3.1	3.4	2.7	2.9	2.2		
	PrecMax	46.9	4.9	4.3	7.0	8.7	7.0	11.0	8.6	8.9	8.1	6.9	5.7	4.6		
	PrecMin	23.1	0.4	0.1	0.2	0.9	0.9	0.8	1.1	1.0	0.5	0.2	0.9	0.8		
	PrecStd	6.1	1.1	0.9	1.4	1.5	1.5	1.9	1.8	1.8	1.8	1.5	1.3	1.0		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	60.4	61.5	73.4	82.7	88.4	91.2	93.4	91.8	89.6	79.9	68.3	62.8		
		MCWB	54.9	50.6	57.9	61.9	69.1	73.6	73.4	72.5	69.8	66.0	57.8	55.3		
	2%	DB	51.9	52.4	63.8	75.2	83.7	87.4	89.6	87.9	84.1	74.3	63.2	54.0		
		MCWB	46.7	44.2	51.5	57.6	66.2	70.8	72.3	71.1	68.9	63.0	54.8	48.9		
	5%	DB	45.2	46.2	56.9	68.7	79.1	83.7	86.3	84.2	79.6	70.0	59.1	48.4		
		MCWB	41.3	40.0	47.7	54.1	64.1	69.3	71.1	69.7	66.6	60.1	52.0	44.2		
	10%	DB	40.1	41.5	51.5	63.4	74.1	80.5	83.2	81.4	75.2	65.0	54.4	44.2		
		MCWB	36.5	36.5	44.2	51.7	61.4	67.4	69.5	68.5	64.9	57.9	48.6	40.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	55.8	52.2	59.7	64.5	72.0	75.9	77.3	76.2	74.1	69.3	60.2	56.3		
		MCDB	59.5	58.2	71.1	78.1	84.6	85.8	88.6	86.2	83.8	76.0	65.3	61.5		
	2%	WB	47.1	45.3	53.6	59.8	68.8	73.4	75.0	73.6	71.3	65.4	56.9	49.5		
		MCDB	50.1	51.3	60.6	70.2	79.3	83.3	84.9	82.1	80.1	72.0	62.0	52.8		
	5%	WB	41.7	40.9	49.1	56.8	66.1	71.4	73.2	72.0	69.1	61.8	53.1	44.8		
		MCDB	45.3	45.8	56.9	66.6	75.5	80.6	82.4	80.4	75.7	67.5	57.7	48.1		
	10%	WB	37.0	37.0	44.2	53.1	63.6	69.4	71.6	70.5	67.0	58.5	49.0	40.3		
		MCDB	40.0	41.4	50.3	61.0	72.4	77.1	80.0	78.3	73.1	64.6	54.3	43.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	17.2	18.6	20.2	23.7	24.6	23.3	23.6	23.0	23.0	21.4	18.7	15.2		
		MCDBR	21.6	25.6	30.6	35.2	31.7	28.1	27.1	26.6	28.2	29.3	27.1	21.2		
	5% WB	MCWBR	18.2	19.1	19.9	19.8	16.2	13.8	12.1	12.2	14.2	17.9	18.8	17.1		
		MCDWR	20.8	23.0	28.1	29.4	26.9	24.5	23.2	22.5	22.4	24.0	23.0	19.5		
(40) Clear-Sky Solar Irradiance	taub		0.304	0.322	0.351	0.370	0.397	0.445	0.451	0.441	0.368	0.357	0.314	0.295		
	taud		2.366	2.318	2.329	2.339	2.300	2.189	2.183	2.199	2.389	2.417	2.495	2.460		
	Ebn at Noon		265	278	283	285	279	264	261	260	274	263	262	260		
	Edh at Noon		26	32	36	38	41	46	46	43	33	29	23	22		
(44) All-Sky Solar Radiation	RadAvg		462	736	1068	1401	1657	1768	1804	1607	1292	823	537	372		
	RadStd		39	93	100	159	167	159	135	96	140	90	70	53		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.72	N/A	N/A	N/A	N/A	N/A	N/A	-209	+182	+70
(47) Regional (30 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+171	N/A

Nomenclature: See separate page