

ALBANY INTL, NY, USA

WMO: 725180

Lat: 42.747N

Lon: 73.799W

Elev: 280

StdP: 14.55

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 14735

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-0.7	4.3	-11.9	2.9	1.5	-7.1	3.8	6.1	27.3	22.2	25.0	22.1	6.8	290	0.523

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.9	89.1	72.9	86.3	71.1	83.7	69.8	75.4	84.9	73.8	82.1	72.4	80.3	9.2	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
72.4	121.3	80.2	71.0	115.6	78.6	69.6	109.9	77.3	38.9	85.3	37.5	82.1	36.2	80.2	83.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
23.9	20.3	18.2	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			-7.8	94.1	6.7	2.8	-12.7	96.1	-16.6	97.7	-20.4	99.3	-25.3	101.4
			-8.6	78.6	6.5	1.6	-13.2	79.8	-17.0	80.7	-20.6	81.6	-25.3	82.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	49.3	23.8	26.7	35.4	47.7	59.1	68.0	72.8	71.1	63.6	51.3	40.3	30.3
	DBStd	18.94	11.66	10.13	9.91	8.71	7.76	6.37	5.14	5.23	7.09	7.84	8.66	9.09
	HDD50	3085	812	654	465	141	10	0	0	0	1	79	311	612
	HDD65	6418	1276	1073	919	523	218	41	4	10	110	428	741	1075
	CDD50	2830	1	1	12	73	293	540	707	653	408	120	20	2
	CDD65	686	0	0	0	5	36	131	245	198	67	4	0	0
	CDH74	5466	0	0	11	76	378	1069	2034	1421	450	27	0	0
	CDH80	1572	0	0	2	20	102	314	649	374	109	2	0	0
Wind	WSAvg	7.5	8.5	8.8	9.3	9.0	7.6	6.8	6.2	5.6	5.8	6.7	7.8	8.0
Precipitation	PrecAvg	37.4	2.6	2.2	3.0	3.1	3.4	3.5	3.5	3.3	3.0	3.2	2.9	
	PrecMax	47.7	6.5	5.0	5.9	8.0	7.9	7.4	7.6	7.3	11.1	9.0	8.1	6.7
	PrecMin	22.9	0.4	0.2	0.3	0.6	1.1	0.7	0.5	1.5	0.4	0.2	0.9	0.7
	PrecStd	6.3	1.4	1.0	1.2	1.3	1.6	1.7	1.9	1.5	2.0	1.9	1.6	1.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	57.9	59.1	72.1	83.0	87.3	91.7	93.2	90.8	88.2	77.6	68.2	59.3
		MCWB	55.6	50.4	57.6	62.5	68.4	73.8	75.0	74.6	72.5	65.1	59.5	53.5
	2%	DB	49.4	50.1	61.9	74.3	82.9	87.2	89.5	86.9	83.1	72.5	62.9	52.4
		MCWB	44.7	43.4	52.2	57.9	66.8	71.3	73.3	72.2	69.8	63.6	56.4	48.5
	5%	DB	43.4	44.8	55.3	68.3	78.1	83.4	86.4	84.1	79.1	68.5	58.3	47.4
		MCWB	40.1	39.3	46.4	54.9	63.5	69.1	71.8	70.8	68.3	60.5	52.2	43.4
	10%	DB	39.3	40.6	50.1	63.0	73.5	80.3	83.6	81.5	75.5	64.2	54.0	43.1
		MCWB	35.8	36.3	43.2	51.1	60.9	67.3	70.1	69.5	66.3	57.3	48.6	39.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	55.8	54.1	59.5	65.7	72.0	76.2	77.9	77.1	74.5	68.8	62.2	54.6
		MCDB	57.4	58.5	68.4	75.8	83.8	87.4	89.1	87.1	82.7	73.7	65.8	57.9
	2%	WB	45.7	44.1	53.4	60.7	69.0	73.8	75.7	74.8	72.2	65.3	57.7	49.1
		MCDB	47.7	49.1	60.4	71.2	79.2	82.7	85.5	83.0	79.8	71.4	62.1	52.1
	5%	WB	40.5	39.8	47.9	56.7	66.2	72.0	74.1	73.2	70.1	61.6	53.2	44.1
		MCDB	43.4	44.3	53.4	65.7	74.6	80.2	82.8	80.4	77.0	67.5	57.1	47.3
	10%	WB	36.3	36.6	43.5	52.3	63.5	69.7	72.5	71.6	68.1	58.3	49.5	39.5
		MCDB	39.0	40.3	49.5	61.2	71.0	77.2	80.6	78.6	73.9	63.1	53.6	42.5
Mean Daily Temperature Range	5% DB	MDBR	14.8	15.9	17.0	19.8	20.2	19.0	18.9	18.6	19.1	17.8	15.4	13.1
		MCDBR	16.6	20.3	25.5	28.8	26.4	23.1	21.6	20.8	21.8	22.9	20.4	17.0
		MCWBR	14.9	15.4	16.4	15.8	13.8	10.9	9.6	9.4	11.2	14.0	15.6	15.2
	5% WB	MCDBR	16.3	18.3	23.1	24.8	22.6	19.9	18.3	17.5	18.5	20.1	18.1	16.7
		MCWBR	15.3	15.2	17.0	15.8	13.5	10.8	9.6	9.2	10.6	14.3	15.4	15.8
Clear-Sky Solar Irradiance	taub	0.303	0.324	0.343	0.360	0.400	0.450	0.468	0.441	0.380	0.355	0.319	0.300	
	taud	2.351	2.290	2.356	2.384	2.311	2.198	2.158	2.225	2.374	2.445	2.497	2.449	
	Ebn at Noon	263	275	285	288	278	263	256	259	269	263	258	256	
	Edh at Noon	26	32	35	36	40	45	47	42	34	28	23	22	
All-Sky Solar Radiation	RadAvg	495	778	1128	1424	1632	1761	1827	1625	1324	825	555	391	
	RadStd	43	81	97	160	171	155	130	86	115	89	59	45	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.90	N/A	N/A	N/A	N/A	N/A	N/A	-247	+234	+122
(47)	Regional (41 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+166	+72

Nomenclature: See separate page