

ALBANY INTL, NY, USA

WMO: 725180

Lat: 42.747N

Lon: 73.799W

Elev: 85

StdP: 100.30

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 14735

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-18.1	-15.4	-24.4	0.4	-16.9	-21.7	0.5	-14.4	12.2	-5.4	11.2	-5.5	3.1	290	0.523

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.5	31.7	22.7	30.1	21.7	28.7	21.0	24.1	29.4	23.2	27.8	22.4	26.8	4.1	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.5	17.3	26.8	21.7	16.5	25.9	20.9	15.7	25.2	72.7	29.6	69.3	27.9	66.3	26.8	28.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.7	9.1	8.1	-22.1	34.5	3.7	1.6	-24.8	35.6	-27.0	36.5	-29.1	37.4	-31.8	38.5		
(5)			-22.5	25.9	3.6	0.9	-25.1	26.5	-27.2	27.1	-29.2	27.6	-31.8	28.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.6	-4.5	-3.0	1.9	8.7	15.1	20.0	22.7	21.7	17.5	10.7	4.6	-0.9		
	DBStd	10.52	6.48	5.63	5.51	4.84	4.31	3.54	2.86	2.91	3.94	4.36	4.81	5.05		
	HDD10.0	1714	451	363	258	78	6	0	0	0	1	44	173	340		
	HDD18.3	3566	709	596	511	291	121	23	2	6	61	238	412	597		
	CDD10.0	1572	1	1	7	41	163	300	393	363	227	67	11	1		
	CDD18.3	381	0	0	0	3	20	73	136	110	37	2	0	0		
	CDH23.3	3037	0	0	6	42	210	594	1130	789	250	15	0	0		
	CDH26.7	873	0	0	1	11	57	174	361	208	61	1	0	0		
(14) Wind	WSAvg	3.3	3.8	3.9	4.2	4.0	3.4	3.0	2.8	2.5	2.6	3.0	3.5	3.6		
(15) Precipitation	PrecAvg	949	66	55	77	78	87	89	90	84	77	82	74	74		
	PrecMax	1212	164	128	150	202	201	187	192	186	281	229	205	171		
	PrecMin	582	11	6	7	15	27	18	12	37	11	5	23	19		
	PrecStd	160	36	25	31	34	41	44	47	38	51	48	41	37		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.4	15.0	22.3	28.4	30.7	33.2	34.0	32.7	31.2	25.3	20.1	15.2		
		MCWB	13.1	10.2	14.2	17.0	20.2	23.2	23.9	23.7	22.5	18.4	15.3	12.0		
	2%	DB	9.7	10.1	16.6	23.5	28.3	30.7	31.9	30.5	28.4	22.5	17.1	11.3		
		MCWB	7.0	6.3	11.2	14.4	19.3	21.9	22.9	22.3	21.0	17.5	13.6	9.1		
	5%	DB	6.3	7.1	13.0	20.2	25.6	28.5	30.2	29.0	26.2	20.3	14.6	8.6		
		MCWB	4.5	4.0	8.0	12.7	17.5	20.6	22.1	21.5	20.1	15.8	11.2	6.3		
	10%	DB	4.0	4.8	10.0	17.2	23.1	26.8	28.7	27.5	24.2	17.9	12.2	6.2		
		MCWB	2.1	2.4	6.2	10.6	16.0	19.6	21.1	20.8	19.1	14.0	9.2	3.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.2	12.3	15.3	18.7	22.2	24.5	25.5	25.0	23.6	20.4	16.8	12.6		
		MCDB	14.1	14.7	20.2	24.3	28.8	30.8	31.7	30.6	28.2	23.2	18.8	14.4		
	2%	WB	7.6	6.7	11.9	16.0	20.5	23.2	24.3	23.8	22.3	18.5	14.3	9.5		
		MCDB	8.7	9.5	15.8	21.8	26.2	28.2	29.7	28.3	26.6	21.9	16.7	11.2		
	5%	WB	4.7	4.3	8.8	13.7	19.0	22.2	23.4	22.9	21.2	16.5	11.8	6.7		
		MCDB	6.3	6.8	11.9	18.7	23.7	26.8	28.2	26.9	25.0	19.7	14.0	8.5		
	10%	WB	2.4	2.6	6.4	11.3	17.5	21.0	22.5	22.0	20.0	14.6	9.7	4.1		
		MCDB	3.9	4.6	9.7	16.2	21.7	25.1	27.0	25.9	23.3	17.3	12.0	5.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	8.2	8.8	9.4	11.0	11.2	10.6	10.5	10.3	10.6	9.9	8.6	7.3		
		MCDBR	9.2	11.3	14.2	16.0	14.7	12.8	12.0	11.6	12.1	12.7	11.3	9.5		
	5% WB	MCWBR	8.3	8.6	9.1	8.8	7.7	6.1	5.3	5.2	6.2	7.8	8.6	8.5		
		MCWBR	9.0	10.2	12.8	13.8	12.5	11.1	10.2	9.7	10.3	11.1	10.0	9.3		
(40) Clear-Sky Solar Irradiance	taub		0.303	0.324	0.343	0.360	0.400	0.450	0.468	0.441	0.380	0.355	0.319	0.300		
	taud		2.351	2.290	2.356	2.384	2.311	2.198	2.158	2.225	2.374	2.445	2.497	2.449		
	Ebn at Noon		830	868	899	907	875	828	808	818	849	828	814	806		
	Edh at Noon		82	102	109	115	127	143	147	133	106	88	71	69		
(44) All-Sky Solar Radiation	RadAvg		1.56	2.45	3.56	4.49	5.14	5.55	5.76	5.12	4.17	2.60	1.75	1.23		
	RadStd		0.14	0.26	0.31	0.50	0.54	0.49	0.41	0.27	0.36	0.28	0.19	0.14		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.50	N/A	N/A	N/A	N/A	N/A	N/A	-137	+130	+68
(47) Regional (41 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+92	+40

Nomenclature: See separate page