

GRIFFISS INTL, NY, USA

WMO: 725196

Lat: 43.234N

Lon: 75.412W

Elev: 158

StdP: 99.44

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 64775

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-21.8	-18.2	-24.9	0.4	-21.2	-21.9	0.5	-17.3	12.0	-4.2	11.0	-4.5	1.6	320	0.523

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.4	31.0	22.4	29.6	21.6	28.1	20.7	24.0	28.8	23.0	27.5	22.1	26.2	3.9	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.4	17.5	26.2	21.5	16.5	25.4	20.7	15.6	24.5	72.3	28.7	68.7	27.6	65.5	26.2	27.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.0	8.6	7.6	-27.0	33.7	3.1	1.7	-29.2	35.0	-31.0	36.0	-32.7	36.9	-34.9	38.2
			-27.2	25.4	3.0	1.1	-29.3	26.2	-31.1	26.9	-32.8	27.5	-35.0	28.3

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	8.4	-6.4	-4.9	-0.1	7.4	14.3	18.7	21.6	20.4	16.9	10.5	3.7	-1.9
	DBStd	10.88	6.88	6.40	5.94	5.18	4.75	3.57	2.86	2.85	4.13	4.52	4.81	5.49
	HDD10.0	1983	507	417	319	111	13	0	0	0	1	49	198	369
	HDD18.3	3903	765	650	572	329	142	38	6	13	77	246	440	627
	CDD10.0	1409	0	1	6	33	147	262	358	323	208	64	7	1
	CDD18.3	289	0	0	0	2	18	49	106	78	34	3	0	0
	CDH23.3	2419	0	0	3	41	213	449	887	550	257	18	0	0
	CDH26.7	646	0	0	0	8	52	126	263	127	68	2	0	0
Wind	WSAvg	3.0	3.5	3.6	3.7	3.8	3.0	2.8	2.3	2.3	2.3	2.8	3.1	3.4
Precipitation	PrecAvg	1121	85	71	89	90	101	106	100	97	113	86	104	103
	PrecMax	1565	173	224	154	175	214	267	220	194	282	191	190	211
	PrecMin	911	34	16	34	35	18	14	30	34	19	4	34	47
	PrecStd	172	37	37	29	36	52	53	54	38	52	35	37	45
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.3	15.3	22.0	27.5	30.4	32.5	33.4	31.5	31.2	26.0	19.1	13.4
		MCWB	10.2	11.4	13.4	16.5	20.5	23.6	24.3	23.2	22.7	19.5	13.3	11.2
	2%	DB	7.5	9.2	15.1	23.9	28.1	30.0	31.3	29.6	28.5	22.1	16.0	9.9
		MCWB	5.4	5.9	9.6	14.8	19.3	21.5	22.7	22.0	21.6	17.2	11.8	7.6
	5%	DB	4.8	5.7	11.4	20.1	25.9	27.9	29.5	28.0	26.5	20.0	13.5	7.7
		MCWB	3.2	3.7	7.3	12.9	18.0	20.0	21.9	21.0	20.7	16.2	10.1	6.3
	10%	DB	2.7	3.2	8.3	16.8	23.2	25.9	28.0	26.5	24.0	17.8	11.3	5.2
		MCWB	1.3	1.5	5.2	10.9	16.4	19.0	21.1	20.4	19.2	14.7	8.5	3.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.4	12.4	15.2	18.3	22.2	24.6	25.4	24.4	24.1	21.1	14.7	11.5
		MCDB	12.1	15.1	20.0	25.1	28.0	31.2	31.1	28.8	28.3	22.8	17.4	13.2
	2%	WB	6.0	6.5	10.9	16.0	20.7	22.8	24.2	23.2	22.6	18.6	12.5	8.2
		MCDB	7.0	9.1	15.0	21.3	26.2	28.0	29.1	27.5	27.2	20.9	15.3	9.6
	5%	WB	3.3	3.9	7.8	13.9	19.2	21.5	23.2	22.3	21.4	16.8	10.7	6.2
		MCDB	4.5	5.6	10.8	19.2	23.8	25.6	27.6	26.3	25.3	19.3	13.0	7.6
	10%	WB	1.5	1.7	5.3	11.6	17.7	20.3	22.2	21.4	20.1	15.0	8.7	4.1
		MCDB	2.6	3.1	8.5	15.9	22.0	24.2	26.3	25.0	23.3	17.6	10.9	5.2
Mean Daily Temperature Range	5% DB	MDBR	9.2	9.5	9.7	11.8	12.7	11.5	11.4	11.1	11.4	9.7	8.8	7.2
		MCDBR	9.6	12.2	14.1	17.4	15.7	14.4	12.9	12.6	13.3	12.7	12.5	9.2
		MCWBR	8.4	9.7	9.2	9.6	8.2	7.1	5.9	6.1	7.0	7.9	8.7	8.2
	5% WB	MCDBR	8.9	11.3	12.1	15.8	13.2	11.9	10.7	10.5	11.8	10.3	10.7	8.7
		MCWBR	8.0	9.4	8.7	9.3	7.6	6.5	5.4	5.6	6.6	7.3	8.2	8.2
Clear-Sky Solar Irradiance	taub	0.301	0.309	0.350	0.370	0.400	0.440	0.454	0.436	0.379	0.358	0.317	0.296	
	taud	2.304	2.288	2.301	2.343	2.302	2.213	2.182	2.221	2.367	2.428	2.487	2.406	
	Ebn at Noon	823	883	888	896	873	836	818	821	847	821	810	801	
	Edh at Noon	84	101	114	119	128	140	143	133	107	89	71	70	
All-Sky Solar Radiation	RadAvg	1.38	2.24	3.46	4.35	5.19	5.54	5.69	5.07	4.07	2.45	1.57	1.05	
	RadStd	0.16	0.28	0.31	0.54	0.55	0.49	0.51	0.27	0.39	0.27	0.19	0.14	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (29 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page