

ONEIDA COUNTY AP, NY, USA

WMO: 725197

Lat: 43.145N

Lon: 75.384W

Elev: 711

StdP: 14.32

Time Zone: -5.00 (NAE)

Period: 94-06

WBAN: 94794

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-5.7	0.8	-13.6	2.7	-3.2	-8.1	3.7	1.9	26.2	23.5	24.1	22.4	6.4	280	0.552

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.9	87.5	72.8	84.4	70.9	82.0	69.4	75.3	83.4	73.5	80.9	71.8	78.9	8.2	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
72.8	125.1	78.9	71.1	117.7	77.9	69.6	111.7	76.1	39.1	83.5	37.5	81.3	36.0	78.9	85.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	20.8	18.7	17.1	DB	-12.1	91.7	7.0	2.6	-17.1	93.6	-21.2	95.1	-25.1	96.5	-30.2	98.4
(5)				WB	-12.6	78.9	6.9	2.7	-17.5	80.9	-21.5	82.5	-25.3	84.0	-30.3	86.0

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	47.2	21.7	24.8	32.5	44.9	56.4	66.5	70.1	69.1	61.4	49.7	39.5	28.7	
	DBStd	19.09	13.20	10.72	10.48	8.90	7.75	7.05	5.24	5.38	6.86	8.03	9.14	9.79	
	HDD50	3466	877	705	552	199	26	0	0	0	3	109	334	661	
	HDD65	6983	1342	1125	1010	604	287	68	12	23	147	476	765	1124	
	CDD50	2458	1	0	8	48	223	496	624	591	347	99	19	2	
	CDD65	499	0	0	1	3	19	114	171	149	40	2	0	0	
	CDH74	3887	0	0	10	45	217	939	1349	1053	257	17	0	0	
	CDH80	1014	0	0	2	9	47	272	363	265	56	0	0	0	
Wind	WSAvg	8.4	9.8	9.8	9.6	9.3	8.4	7.2	6.8	6.2	7.0	8.1	9.0	9.2	
Precipitation	PrecAvg	44.1	3.3	2.8	3.5	3.5	4.0	4.2	3.9	3.8	4.4	3.4	4.1	4.1	
	PrecMax	61.6	6.8	8.8	6.1	6.9	8.4	10.5	8.7	7.6	11.1	7.5	7.5	8.3	
	PrecMin	35.9	1.3	0.6	1.3	1.4	0.7	0.6	1.2	1.3	0.7	0.2	1.3	1.9	
	PrecStd	6.8	1.5	1.5	1.1	1.4	2.0	2.1	2.1	1.5	2.0	1.4	1.5	1.8	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	56.6	54.7	72.9	81.0	84.5	89.7	90.2	90.4	86.0	76.6	68.0	61.3	
		MCWB	53.6	46.1	58.1	60.2	67.5	74.6	75.7	73.3	68.6	64.0	58.5	53.0	
	2%	DB	48.2	47.7	60.6	70.9	80.3	86.4	86.9	86.1	80.8	71.7	63.3	51.9	
		MCWB	44.6	41.5	51.1	55.6	64.8	71.8	74.1	71.5	68.6	60.5	54.6	46.4	
	5%	DB	43.0	43.4	53.7	65.8	75.1	83.2	84.0	82.4	76.5	66.7	58.6	46.3	
		MCWB	39.8	38.3	45.7	53.2	61.3	70.1	71.7	70.2	66.4	58.4	52.3	42.1	
	10%	DB	38.3	39.2	47.6	60.6	70.4	79.6	81.4	79.9	73.0	62.7	53.1	41.1	
		MCWB	35.8	35.2	42.2	49.8	59.1	68.5	69.5	68.9	64.6	55.6	48.7	37.6	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.8	47.2	59.6	63.4	70.8	76.8	79.4	76.7	73.0	66.3	60.2	54.5
			MCDB	56.4	50.7	72.4	76.6	81.9	86.0	85.5	85.3	79.8	72.2	65.3	59.0
2%		WB	45.1	41.9	52.6	58.8	66.8	74.4	75.9	74.0	70.4	62.1	57.1	47.9	
		MCDB	46.9	46.2	59.8	67.7	75.7	83.1	83.2	81.4	76.8	69.2	61.6	50.9	
5%		WB	40.1	38.9	46.6	54.8	64.2	72.4	73.9	72.3	68.3	59.1	52.8	42.5	
		MCDB	42.6	43.1	52.7	62.8	71.6	80.1	81.3	79.1	74.2	65.7	56.5	46.0	
10%		WB	36.2	35.7	42.0	51.1	61.5	70.0	72.0	70.9	66.2	56.7	48.8	37.9	
		MCDB	38.4	39.0	47.3	58.6	68.8	76.8	79.0	77.2	71.8	61.8	53.5	40.7	
Mean Daily Temperature Range	5% DB	MDBR	14.2	15.3	15.6	18.8	19.8	19.4	18.9	19.4	18.7	16.7	13.5	12.2	
		MCDBR	17.4	18.2	24.8	29.2	27.4	23.6	21.4	22.2	22.5	23.7	21.1	17.7	
		MCWBR	15.1	14.0	16.3	17.6	14.4	11.6	10.8	10.4	11.8	14.5	14.7	14.2	
	5% WB	MCDBR	17.3	16.4	23.2	24.6	22.9	20.3	18.9	18.5	18.7	20.5	17.8	16.9	
		MCWBR	15.5	13.4	16.5	16.8	13.4	11.4	10.6	9.8	11.0	13.5	14.6	14.6	
Clear-Sky Solar Irradiance	taub	0.299	0.307	0.346	0.365	0.396	0.437	0.451	0.432	0.375	0.355	0.314	0.294		
	taud	2.312	2.296	2.313	2.354	2.309	2.217	2.188	2.227	2.373	2.431	2.492	2.414		
	Ebn at Noon	262	281	283	286	279	266	261	262	270	262	259	256		
	Edh at Noon	27	32	36	37	40	44	45	42	34	28	23	22		
All-Sky Solar Radiation	RadAvg	443	716	1103	1381	1645	1754	1805	1608	1291	782	503	337		
	RadStd	49	89	98	169	174	155	158	87	124	87	60	45		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (26 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+153	N/A

Nomenclature: See separate page